

Nuclear Regulatory Commission

§ 72.120

(1) Planned discharges of radioactive materials, radon and its decay products excepted, to the general environment,

(2) Direct radiation from ISFSI or MRS operations, and

(3) Any other radiation from uranium fuel cycle operations within the region.

(b) Operational restrictions must be established to meet as low as is reasonably achievable objectives for radioactive materials in effluents and direct radiation levels associated with ISFSI or MRS operations.

(c) Operational limits must be established for radioactive materials in effluents and direct radiation levels associated with ISFSI or MRS operations to meet the limits given in paragraph (a) of this section.

[53 FR 31658, Aug. 19, 1988, as amended at 63 FR 54562, Oct. 13, 1998]

§ 72.106 Controlled area of an ISFSI or MRS.

(a) For each ISFSI or MRS site, a controlled area must be established.

(b) Any individual located on or beyond the nearest boundary of the controlled area may not receive from any design basis accident the more limiting of a total effective dose equivalent of 0.05 Sv (5 rem), or the sum of the deep-dose equivalent and the committed dose equivalent to any individual organ or tissue (other than the lens of the eye) of 0.5 Sv (50 rem). The lens dose equivalent may not exceed 0.15 Sv (15 rem) and the shallow dose equivalent to skin or any extremity may not exceed 0.5 Sv (50 rem). The minimum distance from the spent fuel, high-level radioactive waste, or reactor-related GTCC waste handling and storage facilities to the nearest boundary of the controlled area must be at least 100 meters.

(c) The controlled area may be traversed by a highway, railroad or waterway, so long as appropriate and effective arrangements are made to control traffic and to protect public health and safety.

[53 FR 31658, Aug. 19, 1988, as amended at 63 FR 54562, Oct. 13, 1998; 66 FR 51842, Oct. 11, 2001]

§ 72.108 Spent fuel, high-level radioactive waste, or reactor-related greater than Class C waste transportation.

The proposed ISFSI or MRS must be evaluated with respect to the potential impact on the environment of the transportation of spent fuel, high-level radioactive waste, or reactor-related GTCC waste within the region.

[66 FR 51842, Oct. 11, 2001]

Subpart F—General Design Criteria

§ 72.120 General considerations.

(a) As required by § 72.24, an application to store spent fuel or reactor-related GTCC waste in an ISFSI or to store spent fuel, high-level radioactive waste, or reactor-related GTCC waste in an MRS must include the design criteria for the proposed storage installation. These design criteria establish the design, fabrication, construction, testing, maintenance and performance requirements for structures, systems, and components important to safety as defined in § 72.3. The general design criteria identified in this subpart establish minimum requirements for the design criteria for an ISFSI or an MRS. Any omissions in these general design criteria do not relieve the applicant from the requirement of providing the necessary safety features in the design of the ISFSI or MRS.

(b) The ISFSI must be designed to store spent fuel and/or solid reactor-related GTCC waste.

(1) Reactor-related GTCC waste may not be stored in a cask that also contains spent fuel. This restriction does not include radioactive materials that are associated with fuel assemblies (e.g., control rod blades or assemblies, thimble plugs, burnable poison rod assemblies, or fuel channels);

(2) Liquid reactor-related GTCC wastes may not be received or stored in an ISFSI; and

(3) If the ISFSI is a water-pool type facility, the reactor-related GTCC waste must be in a durable solid form with demonstrable leach resistance.