

Subpart D—Equipment

§211.63 Equipment design, size, and location.

Equipment used in the manufacture, processing, packing, or holding of a drug product shall be of appropriate design, adequate size, and suitably located to facilitate operations for its intended use and for its cleaning and maintenance.

§211.65 Equipment construction.

(a) Equipment shall be constructed so that surfaces that contact components, in-process materials, or drug products shall not be reactive, additive, or absorptive so as to alter the safety, identity, strength, quality, or purity of the drug product beyond the official or other established requirements.

(b) Any substances required for operation, such as lubricants or coolants, shall not come into contact with components, drug product containers, closures, in-process materials, or drug products so as to alter the safety, identity, strength, quality, or purity of the drug product beyond the official or other established requirements.

§211.67 Equipment cleaning and maintenance.

(a) Equipment and utensils shall be cleaned, maintained, and, as appropriate for the nature of the drug, sanitized and/or sterilized at appropriate intervals to prevent malfunctions or contamination that would alter the safety, identity, strength, quality, or purity of the drug product beyond the official or other established requirements.

(b) Written procedures shall be established and followed for cleaning and maintenance of equipment, including utensils, used in the manufacture, processing, packing, or holding of a drug product. These procedures shall include, but are not necessarily limited to, the following:

- (1) Assignment of responsibility for cleaning and maintaining equipment;
- (2) Maintenance and cleaning schedules, including, where appropriate, sanitizing schedules;
- (3) A description in sufficient detail of the methods, equipment, and materials used in cleaning and maintenance

operations, and the methods of disassembling and reassembling equipment as necessary to assure proper cleaning and maintenance;

(4) Removal or obliteration of previous batch identification;

(5) Protection of clean equipment from contamination prior to use;

(6) Inspection of equipment for cleanliness immediately before use.

(c) Records shall be kept of maintenance, cleaning, sanitizing, and inspection as specified in §§211.180 and 211.182.

[43 FR 45077, Sept. 29, 1978, as amended at 73 FR 51931, Sept. 8, 2008]

§211.68 Automatic, mechanical, and electronic equipment.

(a) Automatic, mechanical, or electronic equipment or other types of equipment, including computers, or related systems that will perform a function satisfactorily, may be used in the manufacture, processing, packing, and holding of a drug product. If such equipment is so used, it shall be routinely calibrated, inspected, or checked according to a written program designed to assure proper performance. Written records of those calibration checks and inspections shall be maintained.

(b) Appropriate controls shall be exercised over computer or related systems to assure that changes in master production and control records or other records are instituted only by authorized personnel. Input to and output from the computer or related system of formulas or other records or data shall be checked for accuracy. The degree and frequency of input/output verification shall be based on the complexity and reliability of the computer or related system. A backup file of data entered into the computer or related system shall be maintained except where certain data, such as calculations performed in connection with laboratory analysis, are eliminated by computerization or other automated processes. In such instances a written record of the program shall be maintained along with appropriate validation data. Hard copy or alternative systems, such as duplicates, tapes, or microfilm, designed to assure that backup data are exact and complete and that it is secure from alteration,