

If you own or operate	Then you must
2. For new or reconstructed GDF, or new storage tank(s) at an existing affected facility subject to §63.11118.	<p>Where:</p> <p>Pf = Minimum allowable final pressure, inches of water.                      v = Total ullage affected by the test, gallons.                      e = Dimensionless constant equal to approximately 2.718.                      2 = The initial pressure, inches water.</p> <p>Equip your gasoline storage tanks with a dual-point vapor balance system, as defined in §63.11132, and comply with the requirements of item 1 in this Table.</p>

[73 FR 1945, Jan. 10, 2008, as amended at 73 FR 35944, June 25, 2008]

TABLE 2 TO SUBPART CCCCC OF PART 63—APPLICABILITY CRITERIA AND MANAGEMENT PRACTICES FOR GASOLINE CARGO TANKS UNLOADING AT GASOLINE DISPENSING FACILITIES WITH MONTHLY THROUGHPUT OF 100,000 GALLONS OF GASOLINE OR MORE

If you own or operate	Then you must
A gasoline cargo tank .....	<p>Not unload gasoline into a storage tank at a GDF subject to the control requirements in this subpart unless the following conditions are met:</p> <p>(i) All hoses in the vapor balance system are properly connected,                      (ii) The adapters or couplers that attach to the vapor line on the storage tank have closures that seal upon disconnect,                      (iii) All vapor return hoses, couplers, and adapters used in the gasoline delivery are vapor-tight,                      (iv) All tank truck vapor return equipment is compatible in size and forms a vapor-tight connection with the vapor balance equipment on the GDF storage tank, and                      (v) All hatches on the tank truck are closed and securely fastened.                      (vi) The filling of storage tanks at GDF shall be limited to unloading by vapor-tight gasoline cargo tanks. Documentation that the cargo tank has met the specifications of EPA Method 27 shall be carried on the cargo tank.</p>

TABLE 3 TO SUBPART CCCCC OF PART 63—APPLICABILITY OF GENERAL PROVISIONS

Citation	Subject	Brief description	Applies to subpart CCCCC
§ 63.1 .....	Applicability .....	Initial applicability determination; applicability after standard established; permit requirements; extensions, notifications.	Yes, specific requirements given in § 63.11111.
§ 63.1(c)(2) .....	Title V Permit .....	Requirements for obtaining a title V permit from the applicable permitting authority.	Yes, § 63.11111(f) of subpart CCCCC exempts identified area sources from the obligation to obtain title V operating permits.
§ 63.2 .....	Definitions .....	Definitions for part 63 standards .....	Yes, additional definitions in § 63.11132.
§ 63.3 .....	Units and Abbreviations	Units and abbreviations for part 63 standards ....	Yes.
§ 63.4 .....	Prohibited Activities and Circumvention.	Prohibited activities; Circumvention, severability	Yes.
§ 63.5 .....	Construction/Reconstruction.	Applicability; applications; approvals .....	Yes.
§ 63.6(a) .....	Compliance with Standards/Operation & Maintenance—Applicability.	General Provisions apply unless compliance extension; General Provisions apply to area sources that become major.	Yes.
§ 63.6(b)(1)–(4) .....	Compliance Dates for New and Reconstructed Sources.	Standards apply at effective date; 3 years after effective date; upon startup; 10 years after construction or reconstruction commences for CAA section 112(f).	Yes.
§ 63.6(b)(5) .....	Notification .....	Must notify if commenced construction or reconstruction after proposal.	Yes.
§ 63.6(b)(6) .....	[Reserved].		
§ 63.6(b)(7) .....	Compliance Dates for New and Reconstructed Area Sources That Become Major.	Area sources that become major must comply with major source standards immediately upon becoming major, regardless of whether required to comply when they were an area source.	No.