

§ 415.345

SUBPART AH—CHROME PIGMENTS

Pollutant or pollutant property	PSES effluent limitations	
	Maximum for any 1 day	Average of daily values for 30 consecutive days
	Milligrams per liter (mg/l)	
Chromium (T)	2.9	1.2
Lead (T)	3.4	1.4
Zinc (T)	2.9	1.2

In cases where POTWs find it necessary to impose mass limitations, the following equivalent mass limitations are provided as an alternate: The limitations for Chromium(T), Lead(T), and Zinc(T) are the same as specified in §415.342

§ 415.345 New source performance standards (NSPS).

Any new source subject to this subpart must achieve the following new source performance standards (NSPS): The limitations are the same as specified in § 415.342.

§ 415.346 Pretreatment standards for new sources (PSNS).

Except as provided in 40 CFR 403.7, any new source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following Pretreatment Standards for New Sources (PSNS): The limitations are the same as specified in §415.344.

[47 FR 55227, Dec. 8, 1982]

§ 415.347 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best conventional pollutant control technology (BCT): The limitations are the same for TSS and pH as specified in §415.342.

[47 FR 55227, Dec. 8, 1982]

40 CFR Ch. I (7-1-09 Edition)

Subpart AI—Chromic Acid Production Subcategory

§ 415.350 Applicability; description of the chromic acid production subcategory.

The provisions of this subpart are applicable to discharges resulting from the production of chromic acid in facilities which also manufacture sodium dichromate.

§ 415.351 Specialized definitions. [Reserved]

§ 415.352 Effluent limitations guidelines representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT).

Except as provided in 40 CFR 125.30 through 125.32, any existing point source subject to this subpart must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of the best practicable control technology currently available (BPT): There shall be no discharge of process wastewater pollutants to navigable waters, except as provided for in §415.172.

§§ 415.353–415.355 [Reserved]

§ 415.356 Pretreatment standards for new sources (PSNS).

Except as provided in 40 CFR 403.7, any new source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for new sources (PSNS): The limitations are the same as specified in §415.352.

[49 FR 33421, Aug. 22, 1984]

Subpart AJ—Copper Salts Production Subcategory

SOURCE: 49 FR 33421, Aug. 22, 1984, unless otherwise noted.