

§ 423.16

40 CFR Ch. I (7-1-09 Edition)

(2) Neither free available chlorine nor total residual chlorine may be discharged from any unit for more than two hours in any one day and not more than one unit in any plant may discharge free available or total residual chlorine at any one time unless the utility can demonstrate to the Regional Administrator or State, if the State has NPDES permit issuing authority, that the units in a particular location cannot operate at or below this level of chlorination.

(j)(1) The quantity of pollutants discharged in cooling tower blowdown shall not exceed the quantity determined by multiplying the flow of cooling tower blowdown times the concentration listed below:

Pollutant or pollutant property	NSPS effluent limitations	
	Maximum concentration (mg/l)	Average concentration (mg/l)
Free available chlorine .....	0.5	0.2

  

Pollutant or pollutant property	Maximum for any 1 day (mg/l)	Average of daily values for 30 consecutive days shall not exceed
		(mg/l)
The 126 priority pollutants (Appendix A) contained in chemicals added for cooling tower maintenance, except:		
Chromium, total .....	( <sup>1</sup> ) 0.2	( <sup>1</sup> ) 0.2
Zinc, total .....	1.0	1.0

<sup>1</sup> No detectable amount.

(2) Neither free available chlorine nor total residual chlorine may be discharged from any unit for more than two hours in any one day and not more than one unit in any plant may discharge free available or total residual chlorine at any one time unless the utility can demonstrate to the Regional Administrator or State, if the State has NPDES permit issuing authority, that the units in a particular location cannot operate at or below this level of chlorination.

(3) At the permitting authority's discretion, instead of the monitoring in 40 CFR 122.11(b), compliance with the limitations for the 126 priority pollutants in paragraph (j)(1) of this section may be determined by engineering calculations which demonstrate that the regulated pollutants are not detectable in

the final discharge by the analytical methods in 40 CFR part 136.

(k) Subject to the provisions of § 423.15(l), the quantity or quality of pollutants or pollutant parameters discharged in coal pile runoff shall not exceed the limitations specified below:

Pollutant or pollutant property	NSPS effluent limitations for any time
TSS .....	Not to exceed 50 mg/l.

(l) Any untreated overflow from facilities designed, constructed, and operated to treat the coal pile runoff which results from a 10 year, 24 hour rainfall event shall not be subject to the limitations in § 423.15(k).

(m) At the permitting authority's discretion, the quantity of pollutant allowed to be discharged may be expressed as a concentration limitation instead of the mass based limitation specified in paragraphs (c) through (j) of this section. Concentration limits shall be based on the concentrations specified in this section.

(n) In the event that waste streams from various sources are combined for treatment or discharge, the quantity of each pollutant or pollutant property controlled in paragraphs (a) through (m) of this section attributable to each controlled waste source shall not exceed the specified limitation for that waste source.

(The information collection requirements contained in paragraphs (h)(2), (i)(2), and (j)(2) were approved by the Office of Management and Budget under control number 2040-0040. The information collection requirements contained in paragraph (j)(3) were approved under control number 2040-0033.)

[47 FR 52304, Nov. 19, 1982, as amended at 48 FR 31404, July 8, 1983]

**§ 423.16 Pretreatment standards for existing sources (PSES).**

Except as provided in 40 CFR 403.7 and 403.13, any existing source subject to this subpart which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and achieve the following pretreatment standards for existing sources (PSES) by July 1, 1984:

(a) There shall be no discharge of polychlorinated biphenol compounds such as those used for transformer fluid.

**Environmental Protection Agency**

**Pt. 423, App. A**

(b) The pollutants discharged in chemical metal cleaning wastes shall not exceed the concentration listed in the following table:

Pollutant or pollutant property	PSNS pretreatment standards
	Maximum for 1 day (mg/l)
Copper, total .....	1.0

(c) [Reserved—Nonchemical Metal Cleaning Wastes].

(d)(1) The pollutants discharged in cooling tower blowdown shall not exceed the concentration listed in the following table:

Pollutant or pollutant property	PSNS pretreatment standards
	Maximum for any time (mg/l)
The 126 priority pollutants (Appendix A) contained in chemicals added for cooling tower maintenance, except:	( <sup>1</sup> )
Chromium, total .....	0.2
Zinc, total .....	1.0

<sup>1</sup> No detectable amount.

(2) At the permitting authority's discretion, instead of the monitoring in 40 CFR 122.11(b), compliance with the limitations for the 126 priority pollutants in paragraph (d)(1) of this section may be determined by engineering calculations which demonstrate that the regulated pollutants are not detectable in the final discharge by the analytical methods in 40 CFR part 136.

**§ 423.17 Pretreatment standards for new sources (PSNS).**

Except as provided in 40 CFR 403.7, any new source subject to this subpart part which introduces pollutants into a publicly owned treatment works must comply with 40 CFR part 403 and the following pretreatment standards for new sources (PSNS).

(a) There shall be no discharge of polychlorinated biphenyl compounds such as those used for transformer fluid.

(b) The pollutants discharged in chemical metal cleaning wastes shall not exceed the concentration listed in the following table:

Pollutant or pollutant property	PSNS pretreatment standards
	Maximum for 1 day (mg/l)
Copper, total .....	1.0

(c) [Reserved—Nonchemical Metal Cleaning Wastes].

(d)(1) The pollutants discharged in cooling tower blowdown shall not exceed the concentration listed in the following table:

Pollutant or pollutant property	PSNS pretreatment standards
	Maximum for any time (mg/l)
The 126 priority pollutants (Appendix A) contained in chemicals added for cooling tower maintenance, except:	
Chromium, total .....	0.2
Zinc, total .....	1.0

(2) At the permitting authority's discretion, instead of the monitoring in 40 CFR 122.11(b), compliance with the limitations for the 126 priority pollutants in paragraph (d)(1) of this section may be determined by engineering calculations which demonstrate that the regulated pollutants are not detectable in the final discharge by the analytical methods in 40 CFR part 136.

(e) There shall be no discharge of wastewater pollutants from fly ash transport water.

**APPENDIX A TO PART 423—126 PRIORITY POLLUTANTS**

- 001 Acenaphthene
- 002 Acrolein
- 003 Acrylonitrile
- 004 Benzene
- 005 Benzidine
- 006 Carbon tetrachloride
- (tetrachloromethane)
- 007 Chlorobenzene
- 008 1,2,4-trichlorobenzene
- 009 Hexachlorobenzene
- 010 1,2-dichloroethane
- 011 1,1,1-trichloroethane
- 012 Hexachloroethane
- 013 1,1-dichloroethane
- 014 1,1,2-trichloroethane
- 015 1,1,1,2-tetrachloroethane
- 016 Chloroethane
- 018 Bis(2-chloroethyl) ether
- 019 2-chloroethyl vinyl ether (mixed)
- 020 2-chloronaphthalene
- 021 2,4, 6-trichlorophenol
- 022 Parachlorometa cresol
- 023 Chloroform (trichloromethane)