

TABLE 4 TO SUBPART JJJ OF PART 62—CLASS II EMISSION LIMITS FOR EXISTING SMALL MUNICIPAL WASTE COMBUSTION UNITS<sup>A</sup>

For these pollutants	You must meet these emission limits <sup>b</sup>	Using these averaging times	And determine compliance by these methods
<b>1. Organics</b>			
<b>Dioxins/furans (total mass basis)</b>	125 nanograms per dry standard cubic meter	3-run average (minimum run duration is 4 hours)	Stack test
<b>2. Metals</b>			
<b>Cadmium</b>	0.10 milligrams per dry standard cubic meter	3-run average (run duration specified in test method)	Stack test
<b>Lead</b>	1.6 milligrams per dry standard cubic meter	3-run average (run duration specified in test method)	Stack test
<b>Mercury</b>	0.080 milligrams per dry standard cubic meter -or- 85 percent reduction of potential mercury emissions	3-run average (run duration specified in test method)	Stack test
<b>Opacity</b>	10 percent	Thirty 6-minute averages	Stack test
<b>Particulate Matter</b>	70 milligrams per dry standard cubic meter	3-run average (run duration specified in test method)	Stack test
<b>3. Acid gases</b>			
<b>Hydrogen Chloride</b>	250 parts per million by volume -or- 50 percent reduction of potential hydrogen chloride emissions	3-run average (minimum run duration is 1 hour)	Stack test

<sup>a</sup> Class II units mean all small municipal combustion units subject to this subpart that are located at municipal waste combustion plants with aggregate plant combustion capacity less than or equal to 250 tons per day of municipal solid waste. See §62.15410 for definitions.

<sup>b</sup> All emission limits (except for opacity) measured at 7 percent oxygen.

For these pollutants	You must meet these emission limits <sup>b</sup>	Using these averaging times	And determine compliance by these methods
<b>3. Acid gases</b>			
<b>Nitrogen Oxides</b>	500 parts per million by dry volume	See footnote c	See footnote c
<b>Sulfur Dioxide</b>	77 parts per million by dry volume -or- 50 percent reduction of potential sulfur dioxides emissions	24-hour daily block geometric average concentration -or- percent reduction	Continuous emission monitoring system
<b>4. Other</b>			
<b>Fugitive Ash</b>	Visible emissions for no more than 5 percent of hourly observation period	Three 1-hour observation periods	Visible emission test

<sup>a</sup> Class II units mean all small municipal combustion units subject to this subpart that are located at municipal waste combustion plants with aggregate plant combustion capacity less than or equal to 250 tons per day of municipal solid waste. See §62.15410 for definitions.

<sup>b</sup> All emission limits (except for opacity) are measured at 7 percent oxygen.

<sup>c</sup> No monitoring, testing, recordkeeping or reporting is required to demonstrate compliance with the nitrogen oxides limit for Class II units.