

such doors shall be numbered in accordance with § 78.47-35 of this subchapter.

(ii) All doors, except those that are kept normally closed, shall be of a type which are capable of release from the control station and from a position at the door. The release mechanism shall be so designed that the door will automatically close in the event of disruption to the control system; however, approved power operated watertight doors will be considered acceptable for this purpose. Holdback hooks, or other means of permanently holding the door open, not subject to control station release, will not be permitted. When double swing doors are permitted, they shall have a latch arrangement which is automatically engaged by the operation of the door release system.

(iii) Double doors shall be so arranged that either door may be closed and latched independently.

(iv) For additional requirements for stairway doors, see § 72.05-20(s).

(c) Doors in "B" Class bulkheads shall meet the following requirements:

(1) Doors may be of solid or hollow steel or equivalent metal construction or may be of steel or equivalent metal frame with glass panes or may be of approved incombustible materials of such construction as specifically approved by the Commandant.

(2) No restriction as to the area of glass will be made for such doors, but all glass shall be of the wire-inserted type.

(3) The lower half of such doors may contain vent grilles or louvers with a net area not to exceed 2 square feet.

(4) Doors shall have a latch with a minimum throw of $\frac{3}{8}$ inch which can be operated from either side of the door. Double swing doors, where permitted for the proper utility of the space, may have the latch normally inoperative.

(5) The bottoms of doors may be undercut not to exceed 1 inch above the door sill or top of approved deck covering. Rugs and carpets shall not pass through doorways but linoleum and similar covering may do so.

(6) Door frames shall be of rigid construction, and shall provide at least a $\frac{1}{2}$ inch doorstop at the sides and top, except:

(i) Double doors capable of independent operation and latching may have a clearance between the doors not to exceed $\frac{1}{8}$ inch. However, if one door must always be closed first, a door stop of at least $\frac{1}{2}$ inch shall be provided for the second door.

(ii) Double swing doors, where permitted, may have a maximum clearance of $\frac{1}{8}$ inch at the tops and sides.

(d) Doors in bulkheads required to be Class C shall be of approved incombustible materials.

§ 72.05-30 Windows and airports.

(a) For the purpose of this subpart, all glass in windows or airports shall be at least $\frac{1}{4}$ inch thick. However, greater thickness may be required for strength purposes in certain locations. All glass shall be fitted in steel or equivalent metal frames and shall be retained by steel or equivalent metal glazing beads or angles.

(b) Where wire-inserted glass is required, and the single wire type is employed, the strands shall run horizontally and shall be not more than 2 inches apart.

(c) Windows in Class B-0 bulkheads shall be fitted with wire inserted glass. Such windows opening onto passageways may not extend below the normal height of the storm rails.

(d) Windows in Class B-15 bulkheads shall be fitted with wire inserted glass. In addition, such windows shall be fitted with a suitable steel or equivalent metal shutter capable of being operated manually as well as automatically by means of a fusible link.

(e) Windows in interior "A" Class bulkheads shall be fitted with suitable steel or equivalent metal shutter capable of being operated manually as well as automatically from the control station by the same system used for the fire doors as noted in § 72.05-25(b)(9)(ii). The metal shutter shall be insulated to meet the applicable bulkhead requirements.

(f) Windows or air ports opening onto lifeboat embarkation or lowering spaces from service, cargo, or machinery spaces, or from control or accommodation spaces other than those containing only incombustible veneers and trim and fire resistant furnishings, shall be fitted with wire inserted glass.

§ 72.05-35

Other windows or air ports opening onto open decks or enclosed promenades need not have wire inserted glass.

(g) Skylights to spaces containing auxiliary internal combustion machinery having an aggregate horsepower of 1,000 or more, and to boiler and main engine rooms, shall be capable of being closed from outside the space. If glass is fitted in such skylights, it shall be of the wire inserted type. The glass panels shall be fitted with permanently attached shutters of steel or equivalent metal.

§ 72.05-35 Hatch covers and shifting boards.

(a) Wood hatch covers may be used between cargo spaces. Hatch covers in other locations shall meet the requirements for deck construction noted in tables 72.05-10 (f) and (g).

(b) Tonnage openings in "A" Class bulkheads shall be closed by means of steel plates.

§ 72.05-40 Insulation, other than for structural fire protection.

(a) Any insulation installed for heat and comfort, refrigeration (including air conditioning), or for any other purpose, and all material incidental to its installation, shall be approved Incombustible Materials. This paragraph shall not apply to such insulation installed in cargo spaces, refrigerated storerooms, individual refrigerator boxes, nor to pipe and machinery coverings or laggings within the machinery spaces.

(b) [Reserved]

§ 72.05-45 Paint.

(a) An excessive number of coats of paint will be discouraged unless non-combustible paint is used.

(b) Nitrocellulose or other highly flammable or noxious fume-producing paints or lacquers shall not be used.

§ 72.05-50 Ventilation.

(a) Where the term *duct* is used in this section, it shall include trunks, plenums, and any other type of ventilation piping, chambers, or duct work.

(b) Where automatic fire dampers are required, they shall be designed to operate at approximately 165 degrees F.

46 CFR Ch. I (10-1-10 Edition)

for normal locations, and approximately 212 degrees F. for locations such as galleys. The dampers shall be so designed as to close against the anticipated draft in the duct. The damper shall be made accessible for periodic inspection by means of a hinged or bolted plate in the duct. The damper and the portion of duct containing the damper shall be constructed of at least 1/8 inch steel plate suitably stiffened. No insulation need be applied to the damper blade.

(c) Where ventilation ducts are required to meet bulkhead requirements, the space within the duct shall be considered to be the same as the space served by the ventilator, and the duct shall be insulated to meet the applicable requirements of tables 72.05-10(d) and 72.05-10(e).

(d) All ventilation systems shall be designed, where practicable, so that all ducts leading to the various enclosures are kept within the main vertical zones. No duct may serve spaces in more than one main vertical zone.

(e) Where of necessity, ducts pass through main vertical zone bulkheads, automatic fire dampers shall be fitted adjacent to the bulkhead. The duct between the bulkhead and the damper shall meet the applicable bulkhead requirements. The damper shall be fitted on at least one side of the bulkhead with a visible indicator showing whether the damper is in the open or closed position. The indicator may be connected to the manual operating device rather than the damper blade so that it might show as being open when it had automatically closed, but could never be open if the indicator showed it to be closed. The damper shall be capable of being manually closed from both sides of the bulkhead. The operating positions for the damper shall be marked as required by § 78.47-53 of this subchapter.

(f) Vent ducts serving stairway enclosures shall serve no other spaces.

(g) Ventilation ducts serving cargo or main machinery spaces which pass through accommodation spaces or safety areas shall be fitted with an automatic fire damper adjacent to the point of entry. Between the bulkhead or deck and the damper, and in addition, on vertical ducts for a distance of