

## § 108.413

### § 108.413 Fusible element fire detection system.

(a) A fusible element fire detection system may be installed.

(b) The arrangements for the system must be acceptable to the Commandant.

#### FIRE MAIN SYSTEM

### § 108.415 Fire pump: General.

A fire main system must have at least two independently driven fire pumps that can each deliver water at a continuous pitot tube pressure of at least 3.5 kilograms per square centimeter (approximately 50 pounds per square inch) at least two fire hose nozzles that are connected to the highest two fire hydrants on the unit. Alternative designs that meet the pressure requirement of this paragraph will be considered for column stabilized and self elevating units.

### § 108.417 Fire pump components and associated equipment.

(a) Each fire pump in a fire main system must have a relief valve on its discharge side that is set to relieve at 1.75 kilograms per square centimeter (approximately 25 pounds per square inch) in excess of the pump discharge pressure necessary to meet the pressure required in §108.415 for the pump or 8.6 kilograms per square centimeters (approximately 125 pounds per square inch), whichever is greater. A relief valve may be omitted if the pump operating under shut off condition is not capable of developing the pressure described in §108.415 plus 1.75 kilograms per square centimeter (25 pounds per square inch).

(b) Each fire pump in a fire main system must have a pressure gauge on its discharge side.

(c) Fire pumps may be used for other purposes. One of the required pumps must be kept available for use on the fire system at all times. If a fire pump is used in a system other than the fire main system, except for branch lines connected to the fire main for deck washing, each pipe connecting the other system must be connected to the pump discharge through a shut off valve at a manifold near the pump. If the fire pump exceeds the pressure in

## 46 CFR Ch. I (10-1-10 Edition)

§108.417(a), the pipe leading from the discharge manifold to other portions of the fire main system must have a reducing station and a pressure gauge in addition to the pressure gauge required by paragraph (b) of this section.

(d) If a fire pump has a reducing station, the relief valve required by paragraph (a) of this section for the pump and the additional pressure gauge required in paragraph (c) of this section must not be located on the discharge side of the reducing station.

(e) An oil line must not be connected to a fire pump.

[CGD 73-251, 43 FR 56808, Dec. 4, 1978, as amended by CGD 95-028, 62 FR 51208, Sept. 30, 1997]

### § 108.419 Fire main capacity.

The diameter of the fire main must be sufficient for the effective distribution of the maximum required discharge from two fire pumps operating simultaneously.

### § 108.421 Location of fire pumps and associated equipment.

Each fire pump required by §108.415, and the source of power, controls, sea connections for the fire pump, and booster pumps, if installed, must be installed in locations where, if a fire occurs in an enclosed space, all of the fire pumps on the unit are not made inoperative, except that if compliance with this requirement is impracticable, a gas type extinguishing system may be installed to protect at least one of the fire pumps, its source of power, and controls.

### § 108.423 Fire hydrants and associated equipment.

(a) A fire main system must have enough fire hydrants so that each accessible space may be sprayed with at least two spray patterns of water.

(b) In a main machinery space, except a shaft alley with no assigned space for stowage of combustibles, each spray pattern of water must be from one length of fire hose and each must be from a separate outlet. In all other spaces at least one spray pattern of water must be from one length of fire hose.

(c) No outlet on a fire hydrant may point above the horizontal.