

**Coast Guard, DHS**

**§ 108.495**

**§ 108.493 Location.**

(a) Each unit must have the hand portable and semiportable fire extinguishers prescribed in Table 108.495(a) of this subpart and installed in the locations prescribed in the table.

(b) Each portable and semi-portable fire extinguisher must be visible and readily accessible.

(c) The location, size, and number of each portable and semiportable fire extinguisher on a unit must be acceptable to the appropriate OCMI. The OCMI may require extinguishers in addition to those prescribed in Table 108.495(a) if he considers them necessary for fire protection on the unit.

(d) Each hand portable and semiportable fire extinguisher that has a nameplate which states that it is to be protected from freezing, must be located where freezing temperatures do not occur.

**§ 108.495 Spare charges.**

(a) Each unit must have enough spare charges for 50 percent of the hand portable fire extinguishers required under Table 108.495(a) of this subpart that are rechargeable by personnel on the unit.

(b) If a unit has extinguishers that cannot be recharged by personnel on unit, it must also have at least one spare extinguisher for each classification and variety of those extinguishers.

**TABLE 108.495(a)—HAND PORTABLE FIRE EXTINGUISHERS AND SEMI-PORTABLE FIRE-EXTINGUISHING SYSTEMS**

Space	Classification (see table 108.495(b))	Quantity and location
<b>SAFETY AREAS</b>		
Wheelhouse and control room .....	C-I .....	2 in vicinity of exit.
Stairway and elevator enclosure .....	.....	None required.
Corridors .....	A-II .....	1 in each corridor not more than 150 ft (45 m) apart. (May be located in stairways.)
Lifeboat embarkation and lowering stations .....	.....	None required.
Radio room .....	C-I .....	2 in vicinity of exit.
<b>ACCOMMODATIONS</b>		
Staterooms, toilet spaces, public spaces, offices, lockers, small storerooms, and pantries, open decks, and similar spaces.	.....	None required.
<b>SERVICE SPACES</b>		
Galleys .....	B-II or C-II .....	1 for each 2,500 ft <sup>2</sup> (232 m <sup>2</sup> ) or fraction thereof suitable for hazards involved.
Paint and lamp rooms .....	B-II .....	1 outside each room in vicinity of exit.
Storerooms .....	A-II .....	1 for each 2,500 ft <sup>2</sup> (232 m <sup>2</sup> ) or fraction thereof located in vicinity of exits, either inside or outside the spaces.
Work shop and similar spaces .....	C-II .....	1 outside each space in vicinity of an exit.
<b>MACHINERY SPACES</b>		
Oil-fired boilers: Spaces containing oil-fired boilers, either main or auxiliary, or their fuel oil units.	B-II .....	2 required in each space.
Internal combustion or gas turbine propelling machinery spaces.	B-V .....	1 required in each space.
	B-II .....	1 for each 1,000 brake horsepower but not less than 2 nor more than 6 in each space.
	B-III .....	1 required in each space. See note 1.
	C-II .....	1 for each motor or generator.
Motors or generators of electric propelling machinery that do not have an enclosed ventilating system.	.....	None required.
Motors and generators of electric propelling machinery that have enclosed ventilating systems.	.....	None required.
<b>AUXILIARY SPACES</b>		
Internal combustion engines or gas turbine .....	B-II .....	Outside the space containing engines or turbines in vicinity of exit.
Electric emergency motors or generators .....	C-II .....	1 outside the space containing motors or generators in vicinity of exit.
Steam driven auxiliary machinery .....	.....	None required.
Trunks to machinery spaces .....	.....	Do.
Fuel tanks .....	.....	Do.
<b>MISCELLANEOUS AREAS</b>		
Helicopter landing decks .....	B-V .....	1 at each access route.