

## Coast Guard, DHS

## § 95.05–10

SOURCE: CGFR 65–50, 30 FR 17001, Dec. 30, 1965, unless otherwise noted.

### Subpart 95.01—Application

#### § 95.01–1 General.

(a) The provisions of this part shall apply to all vessels except as specifically noted in this part.

#### § 95.01–2 Incorporation by reference.

(a) Certain material is incorporated by reference into this part with the approval of the Director of the Federal Register under 5 U.S.C. 552(a) and 1 CFR part 51. To enforce any edition other than that specified in this section, the Coast Guard must publish notice of change in the FEDERAL REGISTER and the material must be available to the public. All approved material is available for inspection at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030 or go to [http://www.archives.gov/federal\\_register/code\\_of\\_federal\\_regulations/ibr\\_locations.html](http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html). Also, it is available for inspection at the Coast Guard, Office of Design and Engineering Standards (CG-521), 2100 2nd St. SW., Stop 7126, Washington, DC 20593-7126, 202-372-1405, and is available from the sources listed below.

(b) American Society for Testing and Materials (ASTM), 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, telephone 610-832-9585, <http://www.astm.org>.

(1) ASTM F 1121-87 (1993), Standard Specification for International Shore Connections for Marine Fire Applications, incorporation by reference approved for § 95.10-10.

(2) [Reserved]

(c) National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02269-9101, telephone 800-344-3555, <http://www.nfpa.org>.

(1) NFPA 13-1996, Standard for the Installation of Sprinkler Systems, incorporation by reference approved for § 95.30-1.

(2) [Reserved]

[USCG-2009-0702, 74 FR 49232, Sept. 25, 2009]

#### § 95.01–5 Equipment installed but not required.

(a) Where fire detecting or extinguishing systems or equipment are not required, but are installed, the system or equipment and its installation shall meet the requirements of this part.

### Subpart 95.05—Fire Detecting and Extinguishing Equipment, Where Required

#### § 95.05–1 Fire detecting, manual alarm, and supervised patrol systems.

(a) Fire detecting, manual alarm, and supervised patrol systems are not required except in special cases; but if installed, the systems shall meet the applicable requirements of part 76 of subchapter H (Passenger Vessels) of this chapter.

(b) In each compartment containing explosives, and in adjacent cargo compartments, there shall be provided a smoke detecting or other suitable type fire detecting system.

(c) Enclosed spaces which are “specially suitable for vehicles” shall be fitted with an approved fire or smoke detecting system.

[CGFR 66-33, 31 FR 15285, Dec. 6, 1966]

#### § 95.05–5 Fire main system.

(a) Fire pumps, hydrants, hose, and nozzles shall be installed on the following vessels:

(1) On all self-propelled vessels.

(2) On all barges with sleeping accommodations for more than 12 persons.

(b) The arrangements and details of the fire main system shall be as set forth in subpart 95.10.

#### § 95.05–10 Fixed fire extinguishing systems.

(a) Approved fire extinguishing systems may be used or required in locations delineated in this section on the following vessels. Previously approved installations may be retained as long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection.

(1) On all self-propelled vessels other than yachts and fishing vessels.

(2) On all barges with sleeping accommodations for more than 12 persons.