

**Coast Guard, DHS**

**§ 154.1150**

accumulated water in subfreezing temperatures.

(f) Each water spray system must have a dirt strainer that is located at the water spray system manifold or pump.

**§ 154.1130 Sections.**

(a) If a water spray system is divided into sections, each section must at least include the entire deck area bounded by the length of a cargo tank and the full beam of the vessel.

(b) If a water spray system is divided into sections, the control valves must be at a single manifold that is aft of the cargo area.

**§ 154.1135 Pumps.**

(a) Water to the water spray system must be supplied by:

- (1) A pump that is only for the use of the system;
- (2) A fire pump; or
- (3) A pump specially approved by the Commandant (CG-522).

(b) Operation of a water spray system must not interfere with simultaneous operation of the fire main system at its required capacity. There must be a valved cross-connection between the two systems.

(c) Except as allowed under paragraph (d) of this section, each pump for each water spray system must have the capacity to simultaneously supply all areas named in §154.1110.

(d) If the water spray system is divided into sections, the pump under paragraph (a) of this section must have the capacity to simultaneously supply the required discharge density under §154.1115(a) for:

- (1) The areas in §§154.1110(f) through (h) and 154.1115(b); and
- (2) The largest section that includes the required protection under §154.1110 (a), (b), and (c).

[CGD 74-289, 44 FR 26009, May 3, 1979, as amended by CGD 82-063b, 48 FR 4782, Feb. 3, 1983]

**FIREFIGHTING SYSTEM: DRY CHEMICAL**

**§ 154.1140 Dry chemical system: General.**

Each liquefied flammable gas carrier must have a dry chemical firefighting system that meets §§154.1145 through

154.1170, Part 56 and Subpart 162.039 of this chapter.

**§ 154.1145 Dry chemical supply.**

(a) A vessel with a cargo carrying capacity less than 1000 m<sup>3</sup> (35,300 ft.<sup>3</sup>) must have at least one self-contained dry chemical storage unit for the cargo area with an independent inert gas pressurizing source adjacent to each unit.

(b) A vessel with a cargo carrying capacity of 1000 m<sup>3</sup> (35,300 ft.<sup>3</sup>) or more must have at least two self-contained dry chemical storage units for the cargo area with an independent inert gas pressurizing source adjacent to each unit.

(c) A vessel with bow and stern loading and discharge areas must have at least one self-contained dry chemical storage unit with an independent inert gas pressurizing source adjacent to the unit for each area.

(d) Each dry chemical storage unit and associated piping must be designed for:

- (1) Sequential discharge of each hose line and each monitor for 45 seconds; and
- (2) Simultaneous discharge of all hose lines and monitors for 45 seconds.

(e) Each fully charged dry chemical storage unit must have the greater of the following:

- (1) Enough dry chemical to provide for sequential discharge of each attached hose and monitor for 45 seconds.
- (2) Enough dry chemical to provide for simultaneous discharge of all attached hoses and monitors for 45 seconds.

**§ 154.1150 Distribution of dry chemical.**

(a) All locations on the above deck cargo area and the cargo piping outside that cargo area must be protected by:

- (1) At least two dry chemical hand hose lines; or
- (2) At least one dry chemical hand hose line and one dry chemical monitor.

(b) At least one dry chemical storage unit and hand hose line or monitor must be at the after end of the cargo areas.