

**Environmental Protection Agency**

**Pt. 62, Subpt. JJJ, Table 5**

**TABLE 5 TO SUBPART JJJ OF PART 62—CARBON MONOXIDE EMISSION LIMITS FOR EXISTING SMALL MUNICIPAL WASTE COMBUSTION UNITS**

<b>For these municipal waste combustion units</b>	<b>You must meet the carbon monoxide limits<sup>a</sup></b>	<b>Using these averaging times<sup>b</sup></b>
<b>1. Fluidized bed</b>	100 parts per million by dry volume	4-hour
<b>2. Fluidized bed, mixed fuel, (wood/refuse-derived fuel)</b>	200 parts per million by dry volume	24-hour <sup>c</sup>
<b>3. Mass burn rotary refractory</b>	100 parts per million by dry volume	4-hour
<b>4. Mass burn rotary waterwall</b>	250 parts per million by dry volume	24-hour
<b>5. Mass burn waterwall and refractory</b>	100 parts per million by dry volume	4-hour
<b>6. Mixed fuel-fired, (pulverized coal/refuse-derived fuel)</b>	150 parts per million by dry volume	4-hour
<b>7. Modular starved-air and excess air</b>	50 parts per million by dry volume	4-hour
<b>8. Spreader stoker, mixed fuel-fired (coal/refuse-derived fuel)</b>	200 parts per million by dry volume	24-hour daily
<b>9. Stoker, refuse-derived fuel</b>	200 parts per million by dry volume	24-hour daily

<sup>a</sup> All emission limits (except for opacity) are measured at 7 percent oxygen. Compliance is determined by continuous emission monitoring systems.

<sup>b</sup> Block averages, arithmetic mean. See §62.15410 for definitions.

<sup>c</sup> 24-hour block average, geometric mean.