

of a Federal agency includes the chief executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., a Regional Administrator of the EPA).

(4) For affected sources (as defined in this part) applying for or subject to a title V permit: "responsible official" shall have the same meaning as defined in part 70 of this chapter or Federal title V regulations (42 U.S.C. 7661), whichever is applicable.

Water treatment chemicals means any combination of chemical substances used to treat water in cooling towers, including corrosion inhibitors, antiscalants, dispersants, and any other chemical substances used to treat water.

§ 63.402 Standard.

No owner or operator of an IPCT shall use chromium-based water treatment chemicals in any affected IPCT.

§ 63.403 Compliance dates.

The requirements of § 63.402 of this subpart shall be applied on the following schedule:

(a) For existing IPCT's, the compliance date shall be 18 months after September 8, 1994.

(b) For new IPCT's that have an initial startup before September 8, 1994, the compliance date shall be September 8, 1994.

(c) For new IPCT's that have an initial startup on or after September 8, 1994, the compliance date shall be the date of the initial startup.

§ 63.404 Compliance demonstrations.

No routine monitoring, sampling, or analysis is required. In accordance with section 114 of the Act, the Administrator or delegated authority can require cooling water sample analysis of an IPCT if there is information to indicate that the IPCT is not in compliance with the requirements of § 63.402 of this subpart. The owner or operator of an IPCT may demonstrate compliance through recordkeeping in accordance with paragraph (c) of this section in lieu of a water sample analysis. If cooling water sample analysis is required:

(a) The water sample analysis shall be conducted in accordance with Meth-

od 7196, Chromium, Hexavalent (Colorimetric), contained in the Third Edition of "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods," EPA Publication SW-846, (November 1986) and its Revision I, (December 1987), which are available for the cost of \$110.00 from the Government Printing Office, Superintendent of Documents, Washington, DC 20402, (202) 783-3238 (document number 955-001-00000-1; or Method 3500-Cr D, Colorimetric Method, contained in the 18th Edition of "Standard Methods for the Examination of Water and Wastewater" (1992), which is available from the American Public Health Association, 1015 15th Street, NW., Washington, DC 20005. These methods were approved for incorporation by reference by the Director of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. Copies may be inspected as a part of Docket A-91-65, located at the Air and Radiation Docket and Information Center, room M1500, EPA Central Docket Section, 401 M St., SW., Washington, DC. Copies may be inspected at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html.

(b) On or after 3 months after the compliance date, a cooling water sample residual hexavalent chromium concentration equal to or less than 0.5 parts per million by weight shall indicate compliance with § 63.402. Alternatively, an owner or operator may demonstrate compliance through record keeping in accordance with paragraph (c).

(c) To demonstrate compliance with § 63.402, in lieu of the water sample analysis provided for in paragraph (a) of this section, the owner or operator of each IPCT may maintain records of water treatment chemical purchases, including invoices and other documentation that includes invoices and other documentation that includes date(s) of purchase or shipment, trade name or other information to identify composition of the product, and quantity of the product.