

this case, there must be a neutral over-current relay and alarm system that is set to function at a current value not more than the neutral rating.

(2) *Equalizer buses.* For each three-wire generator, the circuit breaker must protect against a short circuit on the equalizer bus.

(j) *Circuit breaker reclosing.* Generator circuit breakers must not automatically close after tripping.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 81-030, 53 FR 17847, May 18, 1988; CGD 94-108, 61 FR 28277, June 4, 1996; 62 FR 23908, May 1, 1997]

§ 111.12-13 Propulsion generator protection.

For general requirements, see § 111.35-1 of this chapter.

Subpart 111.15—Storage Batteries and Battery Chargers: Construction and Installation

§ 111.15-1 General.

Each battery must meet the requirements of this subpart.

[CGD 94-108, 61 FR 28277, June 4, 1996]

§ 111.15-2 Battery construction.

(a) A battery cell, when inclined at 40 degrees from the vertical, must not spill electrolyte.

(b) Each fully charged lead-acid battery must have a specific gravity that meets section 22 of IEEE 45-2002 (incorporated by reference; see 46 CFR 110.10-1).

(c) Batteries must not evolve hydrogen at a rate exceeding that of a similar size lead-acid battery under similar charging condition.

(d) Batteries must be constructed to take into account the environmental conditions of a marine installation, including temperature, vibration, and shock.

[CGD 94-108, 61 FR 28277, June 4, 1996, as amended by USCG-2003-16630, 73 FR 65196, Oct. 31, 2008]

§ 111.15-3 Battery categories.

(a) A battery installation is classified as one of three types, based upon power output of the battery charger, as follows:

(1) *Large.* A large battery installation is one connected to a battery charger that has an output of more than 2 kw computed from the highest possible charging current and the rated voltage of the battery installation.

(2) *Moderate.* A moderate battery installation is one connected to a battery charger that has an output of between 0.2 kw and 2 kw computed from the highest possible charging current and the rated voltage of the battery installation.

(3) *Small.* A small battery installation is one connected to a battery charger that has an output of less than 0.2 kw computed from the highest possible charging current and the rated voltage of the battery installation.

(b) Batteries that generate less hydrogen under normal charging and discharging conditions than an equivalent category of lead-acid batteries (e.g., sealed batteries) may have their battery category reduced to an equivalent category of lead-acid batteries.

[CGD 74-125A, 47 FR 15236, Apr. 8, 1982, as amended by CGD 94-108, 61 FR 28278, June 4, 1996]

§ 111.15-5 Battery installation.

(a) *Large batteries.* Each large battery installation must be in a room that is only for batteries or a box on deck. Installed electrical equipment must meet the hazardous location requirements in subpart 111.105 of this part.

(b) *Moderate batteries.* Each moderate battery installation must be in a battery room, in a box on deck, or in a box or locker in another space such as an engine room, storeroom, or similar space, except if a moderate battery installation is in a ventilated compartment such as the engine room and is protected from falling objects, a box or locker is not required. A moderate battery installation must not be in a sleeping space. An engine cranking battery for one or more engines must be as close as possible to the engine or engines.

(c) *Small batteries.* Small size battery installations must not be located in poorly-ventilated spaces, such as closets, or in living spaces, such as state-rooms.

(d) *Battery trays.* Each battery tray must be chocked with wood strips or