

(i) The containers are each separated from each other by the distance required by paragraph (c) of this section; or

(ii) The containers are subdivided by intervening barriers that prevent mixing, such as diking.

(4) Where two or more containers of incompatible energetic liquids are stored within an intraline distance of each other, paragraph (d) of this section applies.

(c) *Determination of separation distances for compatible energetic liquids.* A launch site operator must determine separation distances for compatible energetic liquids as follows:

(1) To determine each intraline, public area, and public traffic route distance, a launch site operator must use the following tables in appendix E of this part:

(i) Table E-7 for hydrogen peroxide in concentrations of greater than 91 percent; and

(ii) Table E-8 for hydrazine and liquid hydrogen.

(2) For liquid hydrogen and hydrazine, a launch site operator must use the “intra-line distance to compatible energetic liquids” for the energetic liquid that requires the greater distance under table E-8 of appendix E of this part as the minimum separation distance between compatible energetic liquids.

(d) *Determination of separation distances for incompatible energetic liquids.* If incompatible energetic liquids are stored within an intraline distance of each other, a launch site operator must determine the explosive equivalent in pounds of the combined liquids as provided by paragraph (d)(2) of this section unless intervening barriers prevent mixing.

(1) If intervening barriers prevent mixing, a launch site operator must separate the incompatible energetic liquids by no less than the intraline distance that tables E-7 and E-8 of appendix E of this part apply to compatible energetic liquids using the quantity or energetic liquid requiring the greater separation distance.

(2) A launch site operator must use the formulas provided in table E-5 of appendix E of this part, to determine the explosive equivalent in pounds of

the combined incompatible energetic liquids. A launch site operator must then use the explosive equivalent in pounds requiring the greatest separation distance to determine the minimum separation distance between each explosive hazard facility and all other explosive hazard facilities and each public area and public traffic route as required by tables E-1, E-2 and E-3 of appendix E of this part.

[Docket No. FAA-2011-0105, 77 FR 55114, Sept. 7, 2012]

**§ 420.67 Separation distance requirements for handling incompatible energetic liquids that are co-located.**

(a) *Separation of energetic liquids and determination of distances.* Where incompatible energetic liquids are co-located in a launch or reentry vehicle tank or other vessel, a launch site operator must separate each explosive hazard facility from each other explosive hazard facility, each public area, and each public traffic route in accordance with the minimum separation distance determined under this section for each explosive hazard facility.

(b) *Quantity.* For each explosive hazard facility, a launch site operator must determine the total quantity of all energetic liquids as follows:

(1) The quantity of energetic liquid in a launch or reentry vehicle tank is the net weight in pounds of the energetic liquid. The determination of quantity must include any energetic liquid in associated piping to any point where positive means exist for:

(i) Interrupting the flow through the pipe; or

(ii) Interrupting a reaction in the pipe in the event of a mishap.

(2) A launch site operator must convert each energetic liquid's quantity from gallons to pounds using the conversion factors provided by table E-6 of appendix E of this part and the following equation:

Pounds of energetic liquid = gallons × density of energetic liquid (pounds per gallon).

(c) *Determination of separation distances for incompatible energetic liquids.* A launch site operator must determine separation distances for incompatible energetic liquids as follows:

§ 420.69

14 CFR Ch. III (1–1–13 Edition)

(1) A launch site operator must use the formulas provided in table E-5 of appendix E of this part, to determine the explosive equivalent in pounds of the combined incompatible energetic liquids; and

(2) A launch site operator must then use the explosive equivalent in pounds to determine the minimum separation distance between each explosive hazard facility and all other explosive hazard facilities and each public area and public traffic route as required by tables E-1, E-2 and E-3 of appendix E of this part. Where two explosive hazard facilities contain different quantities, the launch site operator must use the quantity of liquid propellant requiring the greatest separation distance to determine the minimum separation distance between the two explosive hazard facilities.

(d) *Separation distance by weight and table.* For each explosive hazard facility, a launch site operator must:

(1) For an explosive equivalent weight from one pound through and including 450 pounds, determine the distance to any public area and public traffic route following table E-1 of appendix E of this part;

(2) For explosive equivalent weight greater than 450 pounds, determine the distance to any public area and public traffic route following table E-2 of appendix E of this part;

(3) Separate each public area containing any member of the public in the open by a distance equal to  $-1133.9 + [389 * \ln(\text{NEW})]$ , where the NEW is greater than 450 pounds and less than 501,500 pounds;

(4) Separate each explosive hazard facility from all other explosive hazard facilities of a single customer using the intraline distance provided by table E-3 of appendix E of this part; and

(5) For explosive hazard facilities used by different customers, use the greater public area distance to separate the facilities from each other.

[Docket No. FAA-2011-0105, 77 FR 55115, Sept. 7, 2012]

**§ 420.69 Separation distance requirements for co-location of division 1.1 and 1.3 explosives with liquid propellants.**

(a) *Separation of energetic liquids and explosives and determination of distances.* A launch site operator must separate each explosive hazard facility from each other explosive hazard facility, each public traffic route, and each public area in accordance with the minimum separation distance determined under this section for each explosive hazard facility where division 1.1 and 1.3 explosives are co-located with liquid propellants. A launch site operator must determine each minimum separation distance from an explosive hazard facility where division 1.1 and 1.3 explosives and liquid propellants are to be located together, to each other explosive hazard facility, public traffic route, and public area as described in paragraphs (b) through (e) of this section.

(b) *Liquid propellants and division 1.1 explosives located together.* For liquid propellants and division 1.1 explosives located together, a launch site operator must:

(1) Determine the explosive equivalent weight of the liquid propellants by following § 420.67(c);

(2) Add the explosive equivalent weight of the liquid propellants and the net explosive weight of division 1.1 explosives to determine the combined net explosive weight;

(3) Use the combined net explosive weight to determine the distance to each public area, public traffic route, and each other explosive hazard facility by following tables E-1, E-2, and E-3 of appendix E of this part; and

(4) Separate each public area containing any member of the public in the open by a distance equal to  $-1133.9 + [389 * \ln(\text{NEW})]$ , where the net explosive weight is greater than 450 pounds and less than 501,500 pounds.

(c) *Liquid propellants and division 1.3 explosives located together.* For liquid propellants and division 1.3 explosives located together, a launch site operator must separate each explosive hazard facility from each other explosive hazard facility, public area, and public traffic route using either of the following two methods: