

§ 200.942

24 CFR Ch. II (4-1-13 Edition)

*federal_register/
code_of_federal_regulations/
ibr_locations.html.*

(b) *Labeling.* Under the procedures set forth in §200.935(d)(6) concerning labeling of a product, the administrator's validation mark and the manufacturer's certification of compliance with the applicable standards are issued by the administrator to the manufacturer. Each sealed insulating glass unit shall be marked as conforming to UM 82a. The label shall be located on each sealed insulating unit so that it is available for inspection. The label shall include the manufacturer's name and plant location.

(c) *Periodic tests and quality assurance inspections.* Under the procedures set forth in §200.935(d)(8) concerning periodic tests and quality assurance inspections, the frequency of testing for a product shall be described in the specific building product certification program. In the case of sealed insulating glass units, testing and inspection shall be conducted as follows:

(1) At least once a year, the administrator shall visit the manufacturer's facility to select a sample, of the maximum size commercially available, for testing in a laboratory approved by the administrator.

(2) The administrator shall also review the quality assurance procedures twice a year to assure that they are being followed by the manufacturer.

[58 FR 67674, Dec. 22, 1993]

§ 200.942 Supplementary specific procedural requirements under HUD building product standards and certification program for carpet and carpet with attached cushion.

(a) *Applicable standards.* (1) Carpet and carpet with attached cushion certified for this program shall be designed, manufactured and tested in accordance with the following standards:

- (i) AATCC 20A-81—Fiber Analysis: Quantitative;
- (ii) AATCC 16E-82—Colorfastness to Light: Water-Cooled Xenon-Arc Lamp, Continuous Light;
- (iii) AATCC 8-85—Colorfastness to Crocking: AATCC Crockmeter Method;
- (iv) AATCC 24-85—Insect, Resistance to Textiles to;

(v) ASTM D1335-67 (Reapproved 1972)—Standard Test Method for Tuft Bind of Pile Floor Coverings;

(vi) ASTM D3676-78 (Reapproved 1983)—Standard Specification for Rubber Cellular Cushion Used for Carpet or Rug Underlay;

(vii) ASTM E648-78—Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source;

(viii) ASTM D2646-79—Standard Methods of Testing Backing Fabrics;

(ix) ASTM D3936-80—Standard Test Method for Delamination Strength of Secondary Backing of Pile Floor Coverings;

(x) ASTM D297-81—Standard Methods for Rubber Products—Chemical Analysis;

(xi) ASTM D418-82—Standard Methods of Testing Pile Yarn Floor Covering Construction; and

(xii) National Bureau of Standards DOC FF 1-70. (ASTM D2859-76)—Standard Test Method for Flammability of Finished Textile Floor Covering Materials.

(2) These standards have been approved by the Director of the Federal Register for incorporation by reference. They are available from the (i) American Association of Textile Chemists and Colorists (AATCC), P.O. Box 12215, Research Triangle Park, NC 27709;

(ii) American Society for Testing and Materials (ASTM), 1916 Race Street, Philadelphia, PA 19103; and

(iii) U.S. Department of Commerce, National Bureau of Standards, Washington, DC 20234.

The standards are also available for inspection at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html.

*federal_register/
code_of_federal_regulations/
ibr_locations.html.*

(b) *Labeling.* (1) Under the procedures set forth in §202.935(d)(6), concerning labeling of a product, the administrator's validation mark and the manufacturer's certification of compliance with the applied standard is required to be on the certification label issued by the administrator to the manufacturer. In

the case of carpet and carpet with attached cushion, the following additional information shall be included on the certification label, mark or stamp:

(i) Manufacturer's name or code identifying the manufacturing plant location; and

(ii) Manufacturer's statement of compliance with UM 44d.

(2) The certification mark shall be applied to each carpet at intervals of at least every six feet, not less than one foot from the edge.

(c) *Periodic tests and quality control inspections.* (1) Five samples of carpet and carpet with attached cushion shall be tested annually by the administrator or by an administrator-approved laboratory. Three samples of each certified quality shall be taken from the plant annually. Of these, two shall be interim samples (taken every six months) and one an annual sample. In addition, two samples of each certified quality shall be taken annually from sources other than the manufacturer, *i.e.*, brought in the market place from distributors or stores, not from the factory. The administrator shall select samples for testing, and testing shall be conducted, in accordance with the applicable standards in a laboratory accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) of the National Bureau of Standards, U.S. Department of Commerce.

(2) The administrator shall visit the manufacturer's facility at least once every six months to assure that the initially accepted quality control procedures continue to be followed.

[51 FR 17928, May 16, 1986]

§ 200.943 Supplementary specific requirements under the HUD building product standards and certification program for the grademarking of lumber.

(a) *Applicable standard.* (1) In accordance with UM 38j, lumber shall be grademarked in compliance with the U.S. Department of Commerce Voluntary Product Standard PS 20-94 American Softwood Lumber Standard.

(2) This standard has been approved by the Director of the Federal Register for incorporation by reference in accordance with 5 U.S.C. 552(a) and 1 CFR

part 51. It is available from the U.S. Department of Commerce, NIST, Office of Voluntary Product Standards, Gaithersburg, MD 20899.

(b) *Labeling.* Under the procedures set forth in § 200.935(d)(6) concerning labeling of a product, the administrator's validation mark and the manufacturer's certification of compliance with the applicable standard are required on the certification label issued by the administrator to the manufacturer. However, in the case of grademarking of lumber, the following information shall be included on the certification label or mark:

(1) The registered symbol which identifies the grading agency;

(2) Species or species combination;

(3) Grade;

(4) Identification of the applicable grading rules when not indicated by the species identification or agency symbol;

(5) Mill or grader;

(6) For members which are less than 5 inches in nominal thickness, indication that the lumber was green or dry at the time of dressing;

(7) Indication that the lumber was finger jointed; and

(8) The certification mark shall be affixed to each piece of lumber.

(c) *Periodic tests and quality assurance.* Periodic tests and quality assurance inspections shall be carried out by the American Lumber Standard Committee as defined in PS 20-94.

[63 FR 5423, Feb. 2, 1998]

§ 200.944 Supplementary specific requirements under the HUD building product standards and certification program for plywood and other performance rated wood-based structural-use panels.

(a)(1) All plywood made to specifications of Voluntary Product Standard, PS 1-83, "Construction and Industrial Plywood" (published by the U.S. Department of Commerce, National Bureau of Standards (May 1984)) and grade marked as PS 1-83 shall conform to the requirements of PS 1-83, except that all veneers may be D-grade. A copy of PS