

| Item of equipment          | Control requirement <sup>a</sup>  |
|----------------------------|---|
| Manhole <sup>b</sup> ..... | (b) TFSC with a vent to either a process or to a control device meeting the requirements of § 63.1256(h)(2); or<br>(c) Water seal with submerged discharge or barrier to protect discharge from wind.   |
| Lift station .....         | (a) TFSC; or<br>(b) TFSC with a vent to either a process or to a control device meeting the requirements of § 63.1256(h)(2); or<br>(c) If the item is vented to the atmosphere, use a TFSC with a properly operating water seal at the entrance or exit to the item to restrict ventilation in the collection system. The vent pipe shall be at least 90 cm in length and not exceeding 10.2 cm in nominal inside diameter. |
| Trench .....               | (a) TFSC; or<br>(b) TFSC with a vent to either a process or to a control device meeting the requirements of § 63.1256(h)(2); or<br>(c) If the item is vented to the atmosphere, use a TFSC with a properly operating water seal at the entrance or exit to the item to restrict ventilation in the collection system. The vent pipe shall be at least 90 cm in length and not exceeding 10.2 cm in nominal inside diameter. |
| Pipe .....                 | Each pipe shall have no visible gaps in joints, seals, or other emission interfaces.  |
| Oil/Water separator .....  | (a) Equip with a fixed roof and route vapors to a process or equip with a closed-vent system that routes vapors to a control device meeting the requirements of § 63.1256(h)(2); or<br>(b) Equip with a floating roof that meets the equipment specifications of § 60.693(a)(1)(i), (a)(1)(ii), (a)(2), (a)(3), and (a)(4).   |
| Tank .....                 | Maintain a fixed roof and consider vents as process vents. <sup>c</sup>   |

<sup>a</sup> Where a tightly fitting solid cover is required, it shall be maintained with no visible gaps or openings, except during periods of sampling, inspection, or maintenance.

<sup>b</sup> Manhole includes sumps and other points of access to a conveyance system.

<sup>c</sup> A fixed roof may have openings necessary for proper venting of the tank, such as pressure/vacuum vent, j-pipe vent.

[65 FR 52616, Aug. 29, 2000]

TABLE 6 TO SUBPART GGG OF PART 63—WASTEWATER—COMPLIANCE OPTIONS FOR WASTEWATER TANKS

| Capacity, m <sup>3</sup> | Maximum true vapor pressure, kPa | Control requirements |
|--------------------------|----------------------------------|----------------------|
| <75 .....                | .....                            | § 63.1256(b)(1).     |
| >75 and <151 .....       | <13.1                            | § 63.1256(b)(1).     |
| .....                    | >13.1                            | § 63.1256(b)(2).     |
| >151 .....               | <5.2                             | § 63.1256(b)(1).     |
| .....                    | >5.2                             | § 63.1256(b)(2).     |

TABLE 7 TO SUBPART GGG OF PART 63—WASTEWATER—INSPECTION AND MONITORING REQUIREMENTS FOR WASTE MANAGEMENT UNITS

| To comply with         | Inspection or monitoring requirement  | Frequency of inspection or monitoring                         | Method                                |
|------------------------|---|---|---------------------------------------|
| TANKS:                 |   |   |                                       |
| 63.1256(b)(3)(i) ..... | Inspect fixed roof and all openings for leaks.  | Initially Semiannually .....                                  | Visual.                               |
| 63.1256(b)(4) .....    | Inspect floating roof in accordance with §§ 63.120(a)(2) and (a)(3).                  | See §§ 63.120(a)(2) and (a)(3).                               | Visual.                               |
| 63.1256(b)(5) .....    | Measure floating roof seal gaps in accordance with §§ 63.120(b)(2)(i) through (b)(4). | .....   | See § 63.120(b)(2)(i) through (b)(4). |
| .....                  | —Primary seal gaps .....  | Initially Once every 5 years (annually if no secondary seal). |                                       |
| .....                  | —Secondary seal gaps .....  | Initially Semiannually .....                                  |                                       |
| 63.1256(b)(7) .....    | Inspect wastewater tank for control equipment failures and improper work practices.   | Initially Semiannually .....                                  | Visual.                               |
| 63.1256(b)(8) .....    |   |   |                                       |