

§ 141.62

40 CFR Ch. I (7-1-17 Edition)

CAS No.	Contaminant	MCL (mg/l)
(2) 116-06-3	Aldicarb	0.003
(3) 1646-87-3	Aldicarb sulfoxide	0.004
(4) 1646-87-4	Aldicarb sulfone	0.002
(5) 1912-24-9	Atrazine	0.003
(6) 1563-66-2	Carbofuran	0.04
(7) 57-74-9	Chlordane	0.002
(8) 96-12-8	Dibromochloropropane	0.0002
(9) 94-75-7	2,4-D	0.07
(10) 106-93-4	Ethylene dibromide	0.00005
(11) 76-44-8	Heptachlor	0.0004
(12) 1024-57-3	Heptachlor epoxide	0.0002
(13) 58-89-9	Lindane	0.0002
(14) 72-43-5	Methoxychlor	0.04
(15) 1336-36-3	Polychlorinated biphenyls	0.0005
(16) 87-86-5	Pentachlorophenol	0.001
(17) 8001-35-2	Toxaphene	0.003
(18) 93-72-1	2,4,5-TP	0.05
(19) 50-32-8	Benzo[a]pyrene	0.0002
(20) 75-99-0	Dalapon	0.2
(21) 103-23-1	Di(2-ethylhexyl) adipate	0.4
(22) 117-81-7	Di(2-ethylhexyl) phthalate	0.006
(23) 88-85-7	Dinoseb	0.007
(24) 85-00-7	Diquat	0.02
(25) 145-73-3	Endothall	0.1
(26) 72-20-8	Endrin	0.002
(27) 1071-53-6	Glyphosate	0.7
(28) 118-74-1	Hexachlorobenzene	0.001
(29) 77-47-4	Hexachlorocyclopentadiene	0.05
(30) 23135-22-0	Oxamyl (Vydate)	0.2
(31) 1918-02-1	Picloram	0.5
(32) 122-34-9	Simazine	0.004
(33) 1746-01-6	2,3,7,8-TCDD (Dioxin)	3 × 10 ⁻⁸

[56 FR 3593, Jan. 30, 1991, as amended at 56 FR 30280, July 1, 1991; 57 FR 31846, July 17, 1992; 59 FR 34324, July 1, 1994]

§ 141.62 Maximum contaminant levels for inorganic contaminants.

(a) [Reserved]

(b) The maximum contaminant levels for inorganic contaminants specified in paragraphs (b) (2)–(6), (b)(10), and (b) (11)–(16) of this section apply to community water systems and non-transient, non-community water systems. The maximum contaminant level specified in paragraph (b)(1) of this section only applies to community water systems. The maximum contaminant levels specified in (b)(7), (b)(8), and (b)(9) of this section apply to community water systems; non-transient, non-community water systems; and transient non-community water systems.

Contaminant	MCL (mg/l)
(1) Fluoride	4.0
(2) Asbestos	7 Million Fibers/liter (longer than 10 µm).
(3) Barium	2
(4) Cadmium	0.005
(5) Chromium	0.1
(6) Mercury	0.002
(7) Nitrate	10 (as Nitrogen)
(8) Nitrite	1 (as Nitrogen)

Contaminant	MCL (mg/l)
(9) Total Nitrate and Nitrite	10 (as Nitrogen)
(10) Selenium	0.05
(11) Antimony	0.006
(12) Beryllium	0.004
(13) Cyanide (as free Cyanide)	0.2
(14) [Reserved]	
(15) Thallium	0.002
(16) Arsenic	0.010

(c) The Administrator, pursuant to section 1412 of the Act, hereby identifies the following as the best technology, treatment technique, or other means available for achieving compliance with the maximum contaminant levels for inorganic contaminants identified in paragraph (b) of this section, except fluoride:

BAT FOR INORGANIC COMPOUNDS LISTED IN SECTION 141.62(b)

Chemical Name	BAT(s)
Antimony	2,7
Arsenic ⁴	1, 2, 5, 6, 7, 9, 12 ⁵
Asbestos	2,3,8
Barium	5,6,7,9

Environmental Protection Agency

§ 141.63

BAT FOR INORGANIC COMPOUNDS LISTED IN SECTION 141.62(b)—Continued

Chemical Name	BAT(s)
Beryllium	1,2,5,6,7
Cadmium	2,5,6,7
Chromium	2,5,6 ² ,7
Cyanide	5,7,13
Mercury	2 ¹ ,4,6 ¹ ,7 ¹
Nickel	5,6,7
Nitrate	5,7,9
Nitrite	5,7
Selenium	1,2 ³ ,6,7,9
Thallium	1,5

¹ BAT only if influent Hg concentrations ≤10µg/l.
² BAT for Chromium III only.
³ BAT for Selenium IV only.
⁴ BATs for Arsenic V. Pre-oxidation may be required to convert Arsenic III to Arsenic V.
⁵ To obtain high removals, iron to arsenic ratio must be at least 20:1.

Key to BATS in Table

- 1 = Activated Alumina
- 2 = Coagulation/Filtration (not BAT for systems <500 service connections)
- 3 = Direct and Diatomite Filtration
- 4 = Granular Activated Carbon
- 5 = Ion Exchange
- 6 = Lime Softening (not BAT for systems <500 service connections)
- 7 = Reverse Osmosis
- 8 = Corrosion Control
- 9 = Electrodialysis
- 10 = Chlorine
- 11 = Ultraviolet
- 12 = Oxidation/Filtration
- 13 = Alkaline Chlorination (pH ≥8.5)

(d) The Administrator, pursuant to section 1412 of the Act, hereby identifies in the following table the affordable technology, treatment technique, or other means available to systems serving 10,000 persons or fewer for achieving compliance with the maximum contaminant level for arsenic:

SMALL SYSTEM COMPLIANCE TECHNOLOGIES (SSCTs)¹ FOR ARSENIC²

Small system compliance technology	Affordable for listed small system categories ³
Activated Alumina (centralized).	All size categories.
Activated Alumina (Point-of-Use) ⁴ .	All size categories.
Coagulation/Filtration ⁵	501–3,300, 3,301–10,000.
Coagulation-assisted Micro-filtration.	501–3,300, 3,301–10,000.
Electrodialysis reversal ⁶	501–3,300, 3,301–10,000.
Enhanced coagulation/filtration.	All size categories
Enhanced lime softening (pH>10.5).	All size categories.
Ion Exchange	All size categories.
Lime Softening ⁵	501–3,300, 3,301–10,000.
Oxidation/Filtration ⁷	All size categories.
Reverse Osmosis (centralized) ⁶ .	501–3,300, 3,301–10,000.

SMALL SYSTEM COMPLIANCE TECHNOLOGIES (SSCTs)¹ FOR ARSENIC²—Continued

Small system compliance technology	Affordable for listed small system categories ³
Reverse Osmosis (Point-of-Use) ⁴ .	All size categories.

¹ Section 1412(b)(4)(E)(ii) of SDWA specifies that SSCTs must be affordable and technically feasible for small systems.
² SSCTs for Arsenic V. Pre-oxidation may be required to convert Arsenic III to Arsenic V.
³ The Act (ibid.) specifies three categories of small systems: (i) those serving 25 or more, but fewer than 501, (ii) those serving more than 500, but fewer than 3,301, and (iii) those serving more than 3,300, but fewer than 10,001.
⁴ When POU or POE devices are used for compliance, programs to ensure proper long-term operation, maintenance, and monitoring must be provided by the water system to ensure adequate performance.
⁵ Unlikely to be installed solely for arsenic removal. May require pH adjustment to optimal range if high removals are needed.
⁶ Technologies reject a large volume of water—may not be appropriate for areas where water quantity may be an issue.
⁷ To obtain high removals, iron to arsenic ratio must be at least 20:1.

[56 FR 3594, Jan. 30, 1991, as amended at 56 FR 30280, July 1, 1991; 57 FR 31847, July 17, 1992; 59 FR 34325, July 1, 1994; 60 FR 33932, June 29, 1995; 66 FR 7063, Jan. 22, 2001; 68 FR 14506, Mar. 25, 2003; 69 FR 38855, June 29, 2004]

§ 141.63 Maximum contaminant levels (MCLs) for microbiological contaminants.

(a) Until March 31, 2016, the total coliform MCL is based on the presence or absence of total coliforms in a sample, rather than coliform density.

(1) For a system that collects at least 40 samples per month, if no more than 5.0 percent of the samples collected during a month are total coliform-positive, the system is in compliance with the MCL for total coliforms.

(2) For a system that collects fewer than 40 samples per month, if no more than one sample collected during a month is total coliform-positive, the system is in compliance with the MCL for total coliforms.

(b) Until March 31, 2016, any fecal coliform-positive repeat sample or *E. coli*-positive repeat sample, or any total coliform-positive repeat sample following a fecal coliform-positive or *E. coli*-positive routine sample, constitutes a violation of the MCL for total coliforms. For purposes of the public notification requirements in subpart Q of this part, this is a violation that may pose an acute risk to health.

(c) Beginning April 1, 2016, a system is in compliance with the MCL for *E.*