

under § 403.6 and 40 CFR chapter I, subchapter N is a Non-Significant Categorical Industrial User rather than a Significant Industrial User on a finding that the Industrial User never discharges more than 100 gallons per day (gpd) of total categorical wastewater (excluding sanitary, non-contact cooling and boiler blowdown wastewater, unless specifically included in the Pretreatment Standard) and the following conditions are met:

(i) The Industrial User, prior to the Control Authority's finding, has consistently complied with all applicable categorical Pretreatment Standards and Requirements;

(ii) The Industrial User annually submits the certification statement required in § 403.12(q) together with any additional information necessary to support the certification statement; and

(iii) The Industrial User never discharges any untreated concentrated wastewater.

(3) Upon a finding that an Industrial User meeting the criteria in paragraph (v)(1)(ii) of this section has no reasonable potential for adversely affecting the POTW's operation or for violating any Pretreatment Standards or requirement, the Control Authority may at any time, on its own initiative or in response to a petition received from an Industrial User or POTW, and in accordance with 40 CFR 403.8(f)(6), determine that such Industrial User is not a Significant Industrial User.

(w) The term *Submission* means:

(1) A request by a POTW for approval of a Pretreatment Program to the EPA or a Director;

(2) A request by a POTW to the EPA or a Director for authority to revise the discharge limits in categorical Pretreatment Standards to reflect POTW pollutant removals; or

(3) A request to the EPA by an NPDES State for approval of its State pretreatment program.

[46 FR 9439, Jan. 28, 1981, as amended at 49 FR 5132, Feb. 10, 1984; 49 FR 28059, July 10, 1984; 51 FR 20430, June 4, 1986; 51 FR 23760, July 1, 1986; 52 FR 1600, Jan. 14, 1987; 53 FR 40610, Oct. 17, 1988; 55 FR 30129, July 24, 1990; 70 FR 60191, Oct. 14, 2005]

§ 403.4 State or local law.

Nothing in this regulation is intended to affect any Pretreatment Requirements, including any standards or prohibitions, established by State or local law as long as the State or local requirements are not less stringent than any set forth in National Pretreatment Standards, or any other requirements or prohibitions established under the Act or this regulation. States with an NPDES permit program approved in accordance with section 402 (b) and (c) of the Act, or States requesting NPDES programs, are responsible for developing a State pretreatment program in accordance with § 403.10 of this regulation.

§ 403.5 National pretreatment standards: Prohibited discharges.

(a)(1) *General prohibitions.* A User may not introduce into a POTW any pollutant(s) which cause Pass Through or Interference. These general prohibitions and the specific prohibitions in paragraph (b) of this section apply to each User introducing pollutants into a POTW whether or not the User is subject to other National Pretreatment Standards or any national, State, or local Pretreatment Requirements.

(2) *Affirmative Defenses.* A User shall have an affirmative defense in any action brought against it alleging a violation of the general prohibitions established in paragraph (a)(1) of this section and the specific prohibitions in paragraphs (b)(3), (b)(4), (b)(5), (b)(6), and (b)(7) of this section where the User can demonstrate that:

(i) It did not know or have reason to know that its Discharge, alone or in conjunction with a discharge or discharges from other sources, would cause Pass Through or Interference; and

(ii)(A) A local limit designed to prevent Pass Through and/or Interference, as the case may be, was developed in accordance with paragraph (c) of this section for each pollutant in the User's Discharge that caused Pass Through or Interference, and the User was in compliance with each such local limit directly prior to and during the Pass Through or Interference; or

(B) If a local limit designed to prevent Pass Through and/or Interference,

as the case may be, has not been developed in accordance with paragraph (c) of this section for the pollutant(s) that caused the Pass Through or Interference, the User's Discharge directly prior to and during the Pass Through or Interference did not change substantially in nature or constituents from the User's prior discharge activity when the POTW was regularly in compliance with the POTW's NPDES permit requirements and, in the case of Interference, applicable requirements for sewage sludge use or disposal.

(b) *Specific prohibitions.* In addition, the following pollutants shall not be introduced into a POTW:

(1) Pollutants which create a fire or explosion hazard in the POTW, including, but not limited to, wastestreams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21;

(2) Pollutants which will cause corrosive structural damage to the POTW, but in no case Discharges with pH lower than 5.0, unless the works is specifically designed to accommodate such Discharges;

(3) Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW resulting in Interference;

(4) Any pollutant, including oxygen demanding pollutants (BOD, etc.) released in a Discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW.

(5) Heat in amounts which will inhibit biological activity in the POTW resulting in Interference, but in no case heat in such quantities that the temperature at the POTW Treatment Plant exceeds 40 °C (104 °F) unless the Approval Authority, upon request of the POTW, approves alternate temperature limits.

(6) Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;

(7) Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;

(8) Any trucked or hauled pollutants, except at discharge points designated by the POTW.

(c) *When specific limits must be developed by POTW.* (1) Each POTW developing a POTW Pretreatment Program pursuant to § 403.8 shall develop and enforce specific limits to implement the prohibitions listed in paragraphs (a)(1) and (b) of this section. Each POTW with an approved pretreatment program shall continue to develop these limits as necessary and effectively enforce such limits.

(2) All other POTW's shall, in cases where pollutants contributed by User(s) result in Interference or Pass-Through, and such violation is likely to recur, develop and enforce specific effluent limits for Industrial User(s), and all other users, as appropriate, which, together with appropriate changes in the POTW Treatment Plant's facilities or operation, are necessary to ensure renewed and continued compliance with the POTW's NPDES permit or sludge use or disposal practices.

(3) Specific effluent limits shall not be developed and enforced without individual notice to persons or groups who have requested such notice and an opportunity to respond.

(4) POTWs may develop Best Management Practices (BMPs) to implement paragraphs (c)(1) and (c)(2) of this section. Such BMPs shall be considered local limits and Pretreatment Standards for the purposes of this part and section 307(d) of the Act.

(d) *Local limits.* Where specific prohibitions or limits on pollutants or pollutant parameters are developed by a POTW in accordance with paragraph (c) above, such limits shall be deemed Pretreatment Standards for the purposes of section 307(d) of the Act.

(e) EPA enforcement actions under section 309(f) of the Clean Water Act.

If, within 30 days after notice of an Interference or Pass Through violation has been sent by EPA to the POTW, and to persons or groups who have requested such notice, the POTW fails to commence appropriate enforcement action to correct the violation, EPA may take appropriate enforcement action

under the authority provided in section 309(f) of the Clean Water Act.

[46 FR 9439, Jan. 28, 1981, as amended at 51 FR 20430, June 4, 1986; 52 FR 1600, Jan. 14, 1987; 55 FR 30129, July 24, 1990; 60 FR 33932, June 29, 1995; 70 FR 60192, Oct. 14, 2005]

§ 403.6 National pretreatment standards: Categorical standards.

National pretreatment standards specifying quantities or concentrations of pollutants or pollutant properties which may be discharged to a POTW by existing or new industrial users in specific industrial subcategories will be established as separate regulations under the appropriate subpart of 40 CFR chapter I, subchapter N. These standards, unless specifically noted otherwise, shall be in addition to all applicable pretreatment standards and requirements set forth in this part.

(a) *Category determination request*—(1) *Application deadline.* Within 60 days after the effective date of a Pretreatment Standard for a subcategory under which an Industrial User may be included, the Industrial User or POTW may request that the Water Management Division Director or Director, as appropriate, provide written certification on whether the Industrial User falls within that particular subcategory. If an existing Industrial User adds or changes a process or operation which may be included in a subcategory, the existing Industrial User must request this certification prior to commencing discharge from the added or changed processes or operation. A New Source must request this certification prior to commencing discharge. Where a request for certification is submitted by a POTW, the POTW shall notify any affected Industrial User of such submission. The Industrial User may provide written comments on the POTW submission to the Water Management Division Director or Director, as appropriate, within 30 days of notification.

(2) *Contents of application.* Each request shall contain a statement:

(i) Describing which subcategories might be applicable; and

(ii) Citing evidence and reasons why a particular subcategory is applicable and why others are not applicable. Any person signing the application state-

ment submitted pursuant to this section shall make the following certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

(3) *Deficient requests.* The Water Management Division Director or Director will only act on written requests for determinations that contain all of the information required. Persons who have made incomplete submissions will be notified by the Water Management Division Director or Director that their requests are deficient and, unless the time period is extended, will be given 30 days to correct the deficiency. If the deficiency is not corrected within 30 days or within an extended period allowed by the Water Management Division Director or the Director, the request for a determination shall be denied.

(4) *Final decision.* (i) When the Water Management Division Director or Director receives a submittal he or she will, after determining that it contains all of the information required by paragraph (2) of this section, consider the submission, any additional evidence that may have been requested, and any other available information relevant to the request. The Water Management Division Director or Director will then make a written determination of the applicable subcategory and state the reasons for the determination.

(ii) Where the request is submitted to the Director, the Director shall forward the determination described in this paragraph to the Water Management Division Director who may make a final determination. The Water Management Division Director may waive receipt of these determinations. If the Water Management Division Director does not modify the Director's decision within 60 days after receipt thereof, or