

## § 141.27

State may require more frequent monitoring than specified in paragraphs (a) and (b) of this section, or may require confirmation samples at its discretion. The results of the initial and confirmation samples will be averaged for use in compliance determinations.

(2) Each public water systems shall monitor at the time designated by the State during each compliance period.

(3) *Compliance:* Compliance with §141.66 (b) through (e) will be determined based on the analytical result(s) obtained at each sampling point. If one sampling point is in violation of an MCL, the system is in violation of the MCL.

(i) For systems monitoring more than once per year, compliance with the MCL is determined by a running annual average at each sampling point. If the average of any sampling point is greater than the MCL, then the system is out of compliance with the MCL.

(ii) For systems monitoring more than once per year, if any sample result will cause the running average to exceed the MCL at any sample point, the system is out of compliance with the MCL immediately.

(iii) Systems must include all samples taken and analyzed under the provisions of this section in determining compliance, even if that number is greater than the minimum required.

(iv) If a system does not collect all required samples when compliance is based on a running annual average of quarterly samples, compliance will be based on the running average of the samples collected.

(v) If a sample result is less than the detection limit, zero will be used to calculate the annual average, unless a gross alpha particle activity is being used in lieu of radium-226 and/or uranium. If the gross alpha particle activity result is less than detection,  $\frac{1}{2}$  the detection limit will be used to calculate the annual average.

(4) States have the discretion to delete results of obvious sampling or analytic errors.

(5) If the MCL for radioactivity set forth in §141.66 (b) through (e) is exceeded, the operator of a community water system must give notice to the State pursuant to §141.31 and to the

## 40 CFR Ch. I (7-1-22 Edition)

public as required by subpart Q of this part.

[65 FR 76745, Dec. 7, 2000, as amended at 69 FR 38855, June 29, 2004]

### § 141.27 Alternate analytical techniques.

(a) With the written permission of the State, concurred in by the Administrator of the U.S. EPA, an alternate analytical technique may be employed. An alternate technique shall be accepted only if it is substantially equivalent to the prescribed test in both precision and accuracy as it relates to the determination of compliance with any MCL. The use of the alternate analytical technique shall not decrease the frequency of monitoring required by this part.

[45 FR 57345, Aug. 27, 1980]

### § 141.28 Certified laboratories.

(a) For the purpose of determining compliance with §141.21 through 141.27, 141.30, 141.40, 141.74, 141.89 and 141.402, samples may be considered only if they have been analyzed by a laboratory certified by the State except that measurements of alkalinity, disinfectant residual, orthophosphate, pH, silica, temperature, and turbidity may be performed by any person acceptable to the State.

(b) Nothing in this part shall be construed to preclude the State or any duly designated representative of the State from taking samples or from using the results from such samples to determine compliance by a supplier of water with the applicable requirements of this part.

[45 FR 57345, Aug. 27, 1980; 47 FR 10999, Mar. 12, 1982, as amended at 59 FR 34323, July 1, 1994; 64 FR 67465, Dec. 1, 1999; 71 FR 65651, Nov. 8, 2006; 86 FR 4282, Jan. 15, 2021]

### § 141.29 Monitoring of consecutive public water systems.

When a public water system supplies water to one or more other public water systems, the State may modify the monitoring requirements imposed by this part to the extent that the interconnection of the systems justifies treating them as a single system for monitoring purposes. Any modified

**Environmental Protection Agency**

**Pt. 141, Subpt. C, App. A**

monitoring shall be conducted pursuant to a schedule specified by the State and concurred in by the Administrator of the U.S. Environmental Protection Agency.

**APPENDIX A TO SUBPART C OF PART 141—ALTERNATIVE TESTING METHODS APPROVED FOR ANALYSES UNDER THE SAFE DRINKING WATER ACT**

Only the editions stated in the following table are approved.

**ALTERNATIVE TESTING METHODS FOR CONTAMINANTS LISTED AT 40 CFR 141.21(f)(3)**

Organism	Methodology	SM 21st Edition <sup>1</sup>	SM 22nd Edition <sup>28</sup>	SM Online <sup>3</sup>	Other
Total Coliforms .....	Total Coliform Fermentation Technique.	9221 A, B .....	9221 A, B .....	9221 A,B-06.	
	Total Coliform Membrane Filter Technique.	9222 A, B, C.			
	Presence-Absence (P-A) Coliform Test.	9221 D.			
	ONPG-MUG Test	9223 .....	9223 B .....	9223 B-04.	
	Colitag™ Tecta EC/TC <sup>33</sup> ....	..... .....	..... .....	..... .....	..... .....

**ALTERNATIVE TESTING METHODS FOR CONTAMINANTS LISTED AT 40 CFR 141.21(f)(5)**

Organism	Methodology	SM 22nd Edition <sup>28</sup>	SM Online <sup>3</sup>
Fecal Coliforms .....	Fecal Coliform Procedure .....	9221 E .....	9221 E-06