

§ 141.52

Contaminant	MCLG (mg/l)
Antimony	0.006
Arsenic	zero ¹
Asbestos	7 Million fibers/liter (longer than 10 µm).
Barium	2
Beryllium004
Cadmium	0.005
Chromium	0.1
Copper	1.3
Cyanide (as free Cyanide)2
Fluoride	4.0
Lead	zero
Mercury	0.002
Nitrate	10 (as Nitrogen).
Nitrite	1 (as Nitrogen).
Total Nitrate + Nitrite	10 (as Nitrogen).
Selenium	0.05
Thallium0005

¹This value for arsenic is effective January 23, 2006. Until then, there is no MCLG.

[50 FR 47155, Nov. 14, 1985, as amended at 52 FR 20674, June 2, 1987; 56 FR 3593, Jan. 30, 1991; 56 FR 26548, June 7, 1991; 56 FR 30280, July 1, 1991; 57 FR 31846, July 17, 1992; 60 FR 33932, June 29, 1995; 66 FR 7063, Jan. 22, 2001]

§ 141.52 Maximum contaminant level goals for microbiological contaminants.

(a) MCLGs for the following contaminants are as indicated:

Contaminant	MCLG
(1) <i>Giardia lamblia</i>	zero
(2) Viruses	zero
(3) <i>Legionella</i>	zero
(4) Total coliforms (including fecal) coliforms and <i>Escherichia coli</i>	zero
(5) <i>Cryptosporidium</i>	zero
(6) <i>Escherichia coli</i> (<i>E. coli</i>)	zero

(b) The MCLG identified in paragraph (a)(4) of this section is applicable until March 31, 2016. The MCLG identified in paragraph (a)(6) of this section is applicable beginning April 1, 2016.

[78 FR 10347, Feb. 13, 2013]

§ 141.53 Maximum contaminant level goals for disinfection byproducts.

MCLGs for the following disinfection byproducts are as indicated:

Disinfection byproduct	MCLG (mg/L)
Bromodichloromethane	zero
Bromoform	zero
Bromate	zero
Chlorite	0.8
Chloroform	0.07
Dibromochloromethane	0.06
Dichloroacetic acid	zero
Monochloroacetic acid	0.07
Trichloroacetic acid	0.02

40 CFR Ch. I (7-1-24 Edition)

[63 FR 69465, Dec. 16, 1998, as amended at 65 FR 34405, May 30, 2000; 71 FR 478, Jan. 4, 2006]

§ 141.54 Maximum residual disinfectant level goals for disinfectants.

MRDLGs for disinfectants are as follows:

Disinfectant residual	MRDLG(mg/L)
Chlorine	4 (as Cl ₂).
Chloramines	4 (as Cl ₂).
Chlorine dioxide	0.8 (as ClO ₂)

[63 FR 69465, Dec. 16, 1998]

§ 141.55 Maximum contaminant level goals for radionuclides.

MCLGs for radionuclides are as indicated in the following table:

Contaminant	MCLG
1. Combined radium-226 and radium-228	Zero.
2. Gross alpha particle activity (excluding radon and uranium)	Zero.
3. Beta particle and photon radioactivity	Zero.
4. Uranium	Zero.

[65 FR 76748, Dec. 7, 2000]

Subpart G—National Primary Drinking Water Regulations: Maximum Contaminant Levels and Maximum Residual Disinfectant Levels

§ 141.60 Effective dates.

(a) The effective dates for § 141.61 are as follows:

(1) The effective date for paragraphs (a)(1) through (a)(8) of § 141.61 is January 9, 1989.

(2) The effective date for paragraphs (a)(9) through (a)(18) and (c)(1) through (c)(18) of § 141.61 is July 30, 1992.

(3) The effective date for paragraphs (a)(19) through (a)(21), (c)(19) through (c)(25), and (c)(27) through (c)(33) of § 141.61 is January 17, 1994. The effective date of § 141.61(c)(26) is August 17, 1992.

(4) The effective date for § 141.61(c)(2)(i) through (vii) is April 26, 2029.

(b) The effective dates for § 141.62 are as follows:

(1) The effective date of paragraph (b)(1) of § 141.62 is October 2, 1987.

(2) The effective date for paragraphs (b)(2) and (b)(4) through (b)(10) of § 141.62 is July 30, 1992.