

Further information with reference to this meeting can be obtained from Ms. Yvonne M. Sabine, Committee Management Officer, National Endowment for the Arts, Washington, D.C., 20506, or call 202/682-5433.

Dated: January 18, 1995.

Yvonne M. Sabine,

Director, Office of Council and Panel Operations, National Endowment for the Arts.

[FR Doc. 95-1705 Filed 1-23-95; 8:45 am]

BILLING CODE 7537-01-M

NATIONAL SCIENCE FOUNDATION

Special Emphasis Panel in Electrical and Communications Systems; Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463, as amended), the National Science Foundation announces the following meeting:

Name: Special Emphasis Panel in Electrical and Communication Systems.

Date and Time: February 3, 1995/8:30 a.m.-5:00 p.m.

Place: National Science Foundation, 4201 Wilson Boulevard, Room 380, Arlington, Virginia 22230.

Contact Person: Dr. Deborah Crawford, Program Director, Solid State and Microstructures, Division of Electrical and Communications Systems Room 675, National Science Foundation, 4201 Wilson Blvd., Arlington, VA 22230.

Telephone: (703) 306-1339.

Type of Meeting: Closed.

Purpose of Meeting: To provide advice and recommendations concerning proposals submitted to NSF for financial support.

Agenda: To review and evaluate applications of Research Equipment (REG) research proposal as part of the selection process for awards.

Reason for Closing: The proposals being reviewed include information of a proprietary or confidential nature, including technical information; financial data, such as salaries; and personal information concerning individuals associated with the proposals. These matters are exempt under 5 U.S.C. 552b(c) (4) and (6) of the Government in the Sunshine Act.

Dated: January 18, 1995.

M. Rebecca Winkler,

Committee Management Officer.

[FR Doc. 95-1692 Filed 1-23-95; 8:45 am]

BILLING CODE 7555-01-M

NUCLEAR REGULATORY COMMISSION

Draft Supplemental Environmental Statement

AGENCY: Nuclear Regulatory Commission.

ACTION: Extension of public comment period.

SUMMARY: On December 9, 1994, the Nuclear Regulatory Commission issued a notice of availability for the Draft Supplement (NUREG-0498, Supplement 1) to the Final Environmental Statement related to the operation of Watts Bar Nuclear Plant Units 1 and 2 (59 FR 63832). The Environmental Protection Agency also noticed the availability of the draft supplement on December 9, 1994 (59 FR 63791). Interested members of the public were requested to submit their comments by January 30, 1995. During a January 10, 1995, public meeting on the draft supplement, members of the public cited the extensive technical content of the document as the primary reason why additional time is needed to provide comments. After considering the public concerns, the Nuclear Regulatory Commission has decided to extend the comment period by an additional 15 days.

DATES: The comment period is extended to February 14, 1995. Interested parties are invited to submit comments.

ADDRESSES: Written comments may be submitted by mail to the Rules Review and Directives Branch, Division of Freedom of Information and Publications Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Written comments also may be delivered to Room 6D22, Two White Flint North, 1145 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays.

Single copies of the draft supplement report are available free, to the extent of supply, upon written request to the Superintendent of Documents, U.S. Government Printing Office, P.O. Box 37082, Washington, DC 20013-7082 or the Office of Administration, Distribution and Mail Service Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

An individual copy is available for inspection and/or copying for a fee in the NRC Public Document Room, 2120 L Street, NW., Washington, DC 20555.

FOR FURTHER INFORMATION CONTACT: Scott C. Flanders, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555, telephone (301) 504-1172

Dated at Rockville, Maryland, this 18th day of January 1994.

For the Nuclear Regulatory Commission.

Scott F. Newberry,

Director, License Renewal and Environmental Review Project Directorate, Associate Director for Advanced Reactors and License Renewal, Office of Nuclear Reactor Regulation.

[FR Doc. 95-1714 Filed 1-23-95; 8:45 am]

BILLING CODE 7590-01-M

Regulatory Guide; Issuance, Availability

The Nuclear Regulatory Commission has issued a revision to a guide in its Regulatory Guide Series. This series has been developed to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the Commission's regulations, techniques used by the staff in evaluating specific problems or postulated accidents, and data needed by the staff in its review of applications for permits and licenses.

Revision 1 of Regulatory Guide 1.160, "Monitoring the Effectiveness of Maintenance at Nuclear Power Plants," provides guidance on meeting the Commission's rules on maintenance and monitoring the effectiveness of maintenance in nuclear power plants. Although the concept of trigger values was included in the original guide as an option to be used as an alert to reveal emergency diesel generator performance problems that may need additional monitoring or corrective actions, it was clearly noted that conformance with such triggers was not a statistical demonstration of maintaining the emergency diesel generator reliability levels at levels selected for compliance with the station blackout rule (10 CFR 50.63). Since there has been continued misinterpretation of the triggers as related to statistical achievement of selected emergency diesel generator reliability, all language in this Revision 1 to Regulatory Guide 1.160 pertaining to emergency diesel generator performance and trigger values was deleted to avoid any misconceptions on their statistical significance. The Commission expects that in implementing the maintenance rule as applied to emergency diesel generators, each licensee will set performance goals that are consistent with the licensee's coping analysis performed to comply with the station blackout rule (10 CFR 50.63), unless there is a documented basis for the inconsistency.

No comments were received from the public regarding emergency diesel generator performance as related to the deletion of the trigger values. However, a number of comments were received requesting further clarification of