

[Docket No. 50-382]

Entergy Operations Inc.; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity For a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NFP-38, issued to Entergy Operations Inc. (the licensee), for operation of the Waterford Steam Electric Station, Unit 3, located in St. Charles Parish, Louisiana.

The proposed amendment would remove a footnote tied to MODE 1 of Technical Specification (TS) Limiting Condition for Operation 3.1.1.3, moderator temperature coefficient (MTC). The deleted footnote was only valid for Cycle 2 and its removal is purely administrative. A new footnote is added to surveillance 4.1.1.3.2.c that proposes a one time deviation not to perform the specified two-thirds end-of-cycle (EOC) MTC test for Cycle 7. TS 3.1.1.3 requires that the most negative MTC value for this cycle to be less negative than the Core Operating Limits Report (COLR) specified a value of -3.3×10^{-4} delta k/k°F. Waterford 3 has determined that the most negative MTC value for the current cycle is -2.88×10^{-4} delta k/k°F. The MTC for Waterford 3 Cycle 7 has been determined to be well within the TS limit including applicable uncertainties.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

Pursuant to 10 CFR 50.91(a)(6) for amendments to be granted under exigent circumstances, the NRC staff must determine that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

Waterford 3 is currently analyzed for a EOC limiting value of -3.3×10^{-4} delta k/k°F. Under the proposed change, compliance with this TS Limit is assured by supporting data and analysis. The analysis demonstrates that the predicted EOC 7 best estimate MTC value is -2.88×10^{-4} delta k/k°F. This is a conservative value because it includes a 26 EFPD extension beyond the actual end of full power reactivity. The margin to the TS limit is thus 0.42×10^{-4} delta k/k°F.

The probability and consequences of an accident previously evaluated will not be increased because this change does not modify any assumptions used in the input to the safety analyses. The current safety calculations will remain valid because the allowed range of MTC values will not change. Therefore, the proposed change will not involve any increase in the probability or consequences of any accident previously evaluated.

Plant operation and plant parameter TS limits will remain unchanged. There are no new changes in plant design nor are any new failure modes introduced. Therefore, the proposed change will not create the possibility of a new or different kind of accident from any accident previously evaluated.

Margin of safety will not be reduced because the range of allowed temperature coefficients will not be changed. The surveillance program consisting of beginning-of-cycle measurements was not affected. Explicit End-of-Cycle 7 MTC predictions have ensured that the MTC is and will remain within the range of specified values. Therefore, the proposed change will not involve any reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 15 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 15-day notice period. However, should circumstances change during the notice period, such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 15-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will

publish in the **Federal Register** a notice of issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Rules Review and Directives Branch, Division of Freedom of Information and Publications Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and should cite the publication date and page number of this **Federal Register** notice. Written comments may also be delivered to Room 6D22, Two White Flint North, 11455 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By May 11, 1995, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the University of New Orleans Library, Louisiana Collection, Lakefront, New Orleans, LA 70122. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the

following factors: (1) the nature of the petitioner's right under the Act to be made a party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If the amendment is issued before the expiration of the 30-day hearing period, the Commission will make a final determination on the issue of no

significant hazards consideration. If a hearing is requested, the final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Docketing and Services Branch, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. Where petitions are filed during the last 10 days of the notice period, it is requested that the petitioner promptly so inform the Commission by a toll-free telephone call to Western Union at 1-(800) 248-5100 (in Missouri 1-(800) 342-6700). The Western Union operator should be given Datagram Identification Number N1023 and the following message addressed to William D. Beckner: petitioner's name and telephone number, date petition was mailed, plant name, and publication date and page number of this **Federal Register** notice. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555, and to N. S. Reynolds, Esq., Winston & Strawn, 1400 L Street, NW., Washington DC 20005-3502, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated April 4, 1995, as supplemented by letter dated April 5, 1995, which are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room, located at the University of New Orleans

Library, Louisiana Collection, Lakefront, New Orleans, LA 70122.

Dated at Rockville, Maryland, this 6th day of April 1995.

Chandu P. Patel,

*Project Manager, Project Directorate IV-1,
Division of Reactor Projects—III/IV, Office of
Nuclear Reactor Regulation.*

[FR Doc. 95-8846 Filed 4-10-95; 8:45 am]

BILLING CODE 7590-01-M

[Docket No. 50-483]

Union Electric Company (Callaway Plant, Unit 1)

Exemption

I.

Union Electric Company (UE or the licensee) is the holder of Facility Operating License No. NPF-30, which authorizes operation of Callaway Plant, Unit 1 (the facility), at a rated power level not in excess of 3565 megawatts thermal. The facility is a pressurized water reactor located at the licensee's site in Callaway County, Missouri. The license provides among other things, that it is subject to all rules, regulations, and Orders of the U.S. Nuclear Regulatory Commission (the Commission or NRC) now or hereafter in effect.

II.

Section III.D.1.(a) of Appendix J to 10 CFR Part 50 requires the performance of three Type A containment integrated leakage rate tests (CILRTs), at approximately equal intervals during each 10-year service period. The third test of each set shall be conducted when the plant is shutdown for the 10-year plant inservice inspection.

III.

By letters dated December 9, 1994, and January 27, 1995, UE requested relief from the requirement to perform a set of three Type A tests at approximately equal intervals during each 10-year service period. The requested exemption would permit an interval extension for the third Type A test of approximately 18 months (from the currently scheduled outage, March 1995, until the next planned refueling outage, September 1996). The exemption request would also permit the third Type A test of the first 10-year service period not to correspond with the end of the current American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code) 10-year plant inservice inspection interval.

The licensee's request cites the special circumstances of 10 CFR 50.12,