

its Supercomputing Centers Program considering the changing nature of computing and information science and technology. Its scope will be limited to NSF's support for advanced computational science.

Agenda: Deliberation of the Draft Report.

Reason for Late Notice: Difficulty with scheduling meeting location.

Dated: May 30, 1995.

M. Rebecca Winkler,

Committee Management Officer.

[FR Doc. 95-13555 Filed 6-1-95; 8:45 am]

BILLING CODE 7555-01-M

Advisory Committee for Social, Behavioral and Economic Sciences; Subcommittee on Transformations to Quality Organizations; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463, as amended), the National Science Foundation announces the following meeting:

Name: Advisory Committee for Social, Behavioral and Economic Sciences; Subcommittee on Transformations to Quality Organizations (#1171)

Date & Time: June 21, 1995, 8:30 am-3:30 pm.

Place: Rm 320, National Science Foundation, 4201 Wilson Blvd., Arlington VA.

Type of Meeting: Open.

Contact Person: Dr. Marietta Baba, Program Director, Transformations to Quality Organizations Program, National Science Foundation, 4201 Wilson Boulevard, Room 910, Arlington, VA 22230, 703/306-1757, x7210.

Minutes: May be obtained from the contact person listed above.

Meeting Purpose: To provide advice, recommendations, and oversight concerning support for research, education, and human resources in the areas of the social, behavioral, and economic sciences. To identify preliminary plans to advance Transformations to Quality Organizations (TQO) effort.

Agenda

1. Welcome and Introductions
2. Opening Remarks
3. Importance of Research
4. Role of Subcommittee
5. Current Status of Program
6. Assessment of Year One
7. Work Plan for Year Two
8. Next Steps

Dated: May 30, 1995.

M. Rebecca Winkler,

Committee Management Officer.

[FR Doc. 95-13550 Filed 6-1-95; 8:45 am]

BILLING CODE 7555-01-M

NUCLEAR REGULATORY COMMISSION

Proposed Generic Letter; Relocation of the Pressure Temperature Limit Curves and Low Temperature Overpressure Protection System Limits

AGENCY: Nuclear Regulatory Commission.

ACTION: Notice of opportunity for public comment.

SUMMARY: The Nuclear Regulatory Commission (NRC) is proposing to issue a generic letter. This draft generic letter would allow licensees to voluntarily relocate the pressure temperature limit curves and low temperature overpressure protection system limits from the technical specifications to a licensee-controlled document. The NRC is seeking comment from interested parties regarding both the technical and regulatory aspects of the proposed generic letter presented under the Supplementary Information heading. This proposed generic letter and supporting documentation were sent to the Committee to Review Generic Requirements (CRGR). CRGR will review the proposed generic letter after resolution and incorporation of public comments. Relevant information, including model technical specifications and a model safety evaluation, that was sent to the CRGR is available in the Public Document Rooms under accession number 9505220128. The NRC will consider comments received from interested parties in the final evaluation of the proposed generic letter. The NRC's final evaluation will include a review of the technical position and, when appropriate, an analysis of the value/impact on licensees. Should this generic letter be issued by the NRC, it will become available for public inspection in the Public Document Rooms.

DATES: Comment period expires July 3, 1995. Comments submitted after this date will be considered if it is practical to do so, but assurance of consideration cannot be given except for comments received on or before this date.

ADDRESSES: Submit written comments to Chief, Rules Review and Directives Branch, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Written comments may also be delivered to 11545 Rockville Pike, Rockville, Maryland, from 7:30 am to 4:15 pm, Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, 2120 L Street NW. (Lower Level), Washington, DC.

FOR FURTHER INFORMATION CONTACT: Maggalean W. Weston, Technical Specifications Branch, Division of Project Support, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-001, Telephone (301) 415-3151.

SUPPLEMENTARY INFORMATION:

NRC Generic Letter 95-XX: Relocation of the Pressure Temperature Limit Curves and Low Temperature Overpressure Protection System Limits

Addressees

All holders of operating licenses or construction permits for nuclear power reactors.

Purpose

The U.S. Nuclear Regulatory Commission (NRC) is issuing this generic letter to advise licensees that they may request a license amendment to relocate the pressure temperature (P/T) limit curves and low temperature overpressure protection (LTOP) system limits from the technical specifications (TS) to a pressure temperature limits report (PTLR) or a similar document.

Description of Circumstances

During the development of the improved standard technical specifications (STS), a change was proposed to relocate the P/T curves and LTOP setpoint curves and values currently contained in the TS to a licensee-controlled document. As part of the improvements to the STS, the NRC staff agreed with the industry that the curves and setpoints may be relocated outside the TS where these limits could be maintained more efficiently and at a lower cost to the licensee, provided the parameters for constructing the curves and setpoints are derived using a methodology approved by the NRC.

Discussion

Technical specifications include limiting conditions for operation (LCOs) that establish P/T and LTOP system limits for the reactor coolant system. The limits are defined by figures and values that provide an acceptable range of operating temperatures and pressures for heatup, cooldown, low temperature overpressure, criticality, and inservice leak and hydrostatic testing conditions. These parameters are generally valid for a specified number of effective full-power years.

License amendments are generally required at the end of the effective period for P/T limit curves or when surveillance specimens are withdrawn