

acceptable limits. Accordingly, the Commission has concluded that the one-time extension does not result in a significant increase in the amounts of any effluents that may be released nor does it result in a significant increase in individual or cumulative occupational radiation exposure. Therefore, there are no significant radiological environmental impacts associated with the proposed exemption.

With regard to potential nonradiological impacts, the proposed exemption only involves Type A testing of the containment. It does not affect nonradiological plant effluents and has no other environmental impact. Accordingly, the Commission concludes that there are no significant nonradiological environmental impacts associated with the proposed exemption.

*Alternatives to the Proposed Action*

Since the Commission has concluded there is no measurable environmental impact associated with the proposed exemption, any alternatives with equal or greater environmental impact need not be evaluated. As an alternative to the proposed action, the staff considered denial of the proposed action. Denial of the application would result in no change in current environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

*Alternative Use of Resources*

This action does not involve the use of resources not previously considered in connection with the Nuclear Regulatory Commission's Final Environmental Statement dated December 1972, related to the operation of the Zion Nuclear Power Station, Unit 1.

*Agencies and Persons Consulted*

In accordance with its stated policy, on June 7, 1995, the NRC staff consulted with the Illinois State Official, Mr. Frank Niziolek; Head, Reactor Safety Section, Division of Engineering; Illinois Department of Nuclear Safety; regarding the environmental impact of the proposed action. The State official had no comments.

**Finding of No Significant Impact**

Based upon the environmental assessment, the Commission concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the Commission has determined not to prepare an environmental impact statement for the proposed exemption.

For further details with respect to this action, see the licensee's letter dated May 12, 1995, which is available for public inspection at the Commission's Public Document Room, The Gelman Building, 2120 L Street, NW., Washington, DC, and at the local public document room located at the Waukegan Public Library, 128 N. County Street, Waukegan, Illinois 60085.

Dated at Rockville, Maryland, this 26th day of June 1995.

For the Nuclear Regulatory Commission.  
**Clyde Y. Shiraki,**  
*Senior Project Manager, Project Directorate III-2, Division of Reactor Projects—III/IV, Office of Nuclear Reactor Regulation.*  
 [FR Doc. 95-16110 Filed 6-29-95; 8:45 am]  
**BILLING CODE 7590-01-M**

**Governor's Designees Receiving Advance Notification of Transportation of Nuclear Waste**

On January 6, 1982 (47 FR 596 and 47 FR 600), the Nuclear Regulatory Commission (NRC) published in the Federal Register, as final, certain amendments to 10 CFR parts 71 and 73 (effective July 6, 1982), which require advance notification to Governors or their designees concerning transportation of certain shipments of nuclear waste and spent fuel. The advance notification covered in part 73 is for spent nuclear reactor fuel shipments and the notification for part 71 is for large quantity shipments of radioactive waste (and of spent nuclear reactor fuel not covered under the final amendment to 10 CFR part 73).

The following list updates the names, addresses and telephone numbers of those individuals in each State who are responsible for receiving information on nuclear waste shipments. The list will be published annually in the Federal Register on or about June 30, to reflect any changes in information.

**INDIVIDUALS RECEIVING ADVANCE NOTIFICATION OF NUCLEAR WASTE SHIPMENTS**

State and Part 71	Part 73
Alabama: Col. Gene Mitchell, Director Alabama Department of Public Safety, P.O. Box 1511, Montgomery, AL 36102-1511, (334) 242-4378.	Same.
Alaska: Doug Dasher, Alaska Department of Environmental Conservation, Northern Regional Office, 610 University Avenue, Fairbanks, AK 99709-3643, (907) 451-2184.	Same.

**INDIVIDUALS RECEIVING ADVANCE NOTIFICATION OF NUCLEAR WASTE SHIPMENTS—Continued**

State and Part 71	Part 73
Arizona: Aubrey V. Godwin, Director, Arizona Radiation Regulatory Agency, 4814 South 40th Street, Phoenix, AZ 85040, (602) 255-4845, 24 hours: (602) 223-2212.	Same.
Arkansas: Greta J. Dicus, Director, Division of Radiation Control and Emergency Management Programs, Arkansas Department of Health, 4815 West Markham Street, Little Rock, AR 72205-3867, (501) 661-2301, 24 hours: (501) 661-2136 or 661-2000.	Same.
California: L. Denno, Chief, Enforcement Services Division, California Highway Patrol, 444 North Third Street, Suite 310, Sacramento, CA 95814, (916) 445-3253.	Same.
Colorado: Captain Allan M. Turner, Hazardous Materials Section, Colorado State Patrol, 700 Kipling Street, Suite 1000, Denver, CO 80215-5865, (303) 239-4546, 24 hours: (303) 239-4501.	Same.
Connecticut: Commissioner Sidney J. Holbrook, Department of Environmental Protection, 79 Elm Street, Hartford, CT 06106-5127, (203) 424-3001, 24 hours: (203) 566-3333.	Same.
Delaware: Karen L. Johnson, Secretary, Department of Public Safety, P.O. Box 818, Dover, DE 19903, (302) 739-4321, 24 hours: (302) 739-5851.	Same.
Florida: Harlan Keaton, Manager, Environmental Radiation Program, Office of Radiation Control, Department of Health and Rehabilitative Services, P.O. Box 680069, Orlando, FL 32868-0069, (407) 297-2095.	Same.
Georgia: Al Hatcher, Director, Transportation Division, Public Service Commission, 1007 Virginia Avenue, Suite 310, Hapeville, GA 30354, (404) 559-6600.	Same.
Hawaii: James K. Ikeda, Acting Deputy Director for Environmental Health, State Department of Health, P.O. Box 3378, Honolulu, HI 96801, (808) 548-4424.	Same.
Idaho: Captain David C. Rich, Department of Law Enforcement, Idaho State Police, 700 South Stratford Drive, P.O. Box 700, Meridian, ID 83680-0700, (208) 884-7206.	Same.
Illinois: Thomas W. Ortciger, Director, Illinois Department of Nuclear Safety, 1035 Outer Park Drive, 5th Floor, Springfield, IL 62704, (217) 785-9868, 24 Hours: (217) 785-9900.	Same.

## INDIVIDUALS RECEIVING ADVANCE NOTIFICATION OF NUCLEAR WASTE SHIPMENTS—Continued

State and Part 71	Part 73
Indiana: Lloyd R. Jennings, Superintendent, Indiana State Police, Indiana Government Center North, 100 North Senate Avenue, Indianapolis, IN 46204, (317) 232-8248.	Same.
Iowa: Ellen M. Gordon, Administrator, Emergency Management Division, Hoover State Office Building, Des Moines, IA 50319-0113, (515) 281-3231.	Same.
Kansas: Frank H. Moussa, M.S.A., Technological Hazards Administrator, Department of the Adjutant General, Division of Emergency Management, 2800 S.W. Topeka Boulevard, Topeka, KS 66611-1287, (913) 274-1409, 24 hours: (913) 296-3176.	Same.
Kentucky: Michael W. Easley, D.D.S., M.P.H., Director, Division of Environmental Health & Community Safety, Department of Health Services, 275 East Main Street, Frankfort, KY 40621, (502) 564-7398.	Same.
Louisiana: Lt. Russell R. Robinson, Louisiana State Police, 7901 Independence Boulevard, P.O. Box 66614 (#21) Baton Rouge, LA 70896, (504) 925-6113.	Same.
Maine: Chief of the State Police, Maine Dept. of Public Safety, 36 Hospital Street, Augusta, ME 04333, (207) 624-7074.	Same.
Maryland: Colonel James E. Harvey, Chief, Maryland State Police, 1201 Reisterstown Road, Pikesville, MD 21208, (410) 653-4218, 24 hours: (410) 653-4200.	Same.
Massachusetts: Robert M. Hallisey, Director, Radiation Control Program, Massachusetts Department of Public Health, State Laboratory Institute, 305 South Street, 7th Floor, Jamaica Plain, MA 02130, (617) 727-6214.	Same.
Michigan: Captain Allen L. Byam, Commanding Officer, Special Operations Division, Michigan Department of State Police, 714 S. Harrison Road, East Lansing, MI 48823, (517) 336-6263, 24 hours: (517) 336-6100.	Same.
Minnesota: John R. Kerr, Assistant Director, Planning Branch, Minnesota Division of Emergency Management, B5—State Capitol, 75 Constitution Avenue, St. Paul, MN 55515, (612) 296-0481, 24 hours: (612) 649-5451.	Same.
Mississippi: James E. Maher, Director, Emergency Management Agency, P.O. Box 4501, Fondren Station, Jackson, MS 39296-4501, (601) 352-9100.	Same.

## INDIVIDUALS RECEIVING ADVANCE NOTIFICATION OF NUCLEAR WASTE SHIPMENTS—Continued

State and Part 71	Part 73
Missouri: Jerry B. Uhlmann, Director, Emergency Management Agency, 2302 Militia Drive, P.O. Box 116, Jefferson City, MO 65102, (314) 526-9101, 24 hours: (314) 751-2748.	Same.
Montana: Adrian Howe, Chief, Occupational and Radiologic, Health Bureau, Environmental Sciences Div., Dept. of Health and Environmental Sciences, 1400 Broadway, P.O. Box 200901, Helena, MT 59620, (406) 444-3671, 24 hours: (406) 442-7491.	(1) Same.
Nebraska: Colonel Ron Tussing, Superintendent, Nebraska State Patrol, P.O. Box 94907, Lincoln, NE 68509-4907, (402) 479-4931, 24 hours: (402) 471-4545.	Same.
Nevada: Stanley R. Marshall, Supervisor, Radiological Health Section, Bureau of Health Protection Services, Nevada Division of Health, 505 East King Street, Carson City, NV 89710, (702) 687-5394, 24 hours: (702) 687-5300.	Same.
New Hampshire: Richard M. Flynn, Commissioner, New Hampshire Dept. of Safety, James H. Hayes Building, 10 Hazen Drive, Concord, NH 03305, (603) 271-3636 (24 hours).	Same.
New Jersey: Kent Tosch, Manager, Department of Environmental Protection and Energy, Bureau of Nuclear Engineering, CN 415, Trenton, NJ 08625-0415, (609) 987-2031.	Same.
New Mexico: Roland K. Lough, Chief, Emergency Management Bureau, Department of Public Safety, P.O. Box 1628, Santa Fe, NM 87504-1628, (505) 827-9223, 24 hours: (505) 294-7932.	Same.
New York: Anthony J. Germano, Director, State Emergency Management Office, Public Security Building #22, State Campus, Albany, NY 12226-5000, (518) 457-9996.	Same.
North Carolina: First Sergeant T.C. Stroud, Hazardous Materials Coordinator, North Carolina Highway Patrol Headquarters, 512 N. Salisbury St., P.O. Box 27687, Raleigh, NC 27611-7687, (919) 733-5282, After hours: (919) 733-3861.	Same.
North Dakota: Dana K. Mount, Director, Division of Environmental Engineering, North Dakota Department of Health, 1200 Missouri Avenue, Box 5520, Bismarck, ND 58506-5520, (701) 328-5188, After hours: (701) 328-2121.	Same.

## INDIVIDUALS RECEIVING ADVANCE NOTIFICATION OF NUCLEAR WASTE SHIPMENTS—Continued

State and Part 71	Part 73
Ohio: Maj. Gen. James R. Williams, Chief of Staff, Ohio Emergency Management Agency, 2855 W. Dublin-Granville Road, Columbus, OH 43235-2206, (614) 889-7150.	Same.
Oklahoma: Kenneth Vanhoy, Commissioner of Public Safety, Oklahoma Department of Public Safety, P.O. Box 11415, Oklahoma City, OK 73136-0145, (405) 425-2001, 24 hours: (405) 425-2424.	Same.
Oregon: David Stewart-Smith, Administrator, Facility Regulation Division, Oregon Department of Energy, 625 Marion Street, N.E., Salem, OR 97310, (503) 378-6469.	Same.
Pennsylvania: John Bahnweg, Director of Operations, Pennsylvania Emergency Management Agency, P.O. Box 3321, Harrisburg, PA 17105-3321, (717) 783-8150.	Same.
Rhode Island: William A. Maloney, Associate Administrator, Motor Carriers Section, Division of Public Utilities and Carriers, 100 Orange Street, Providence, RI 02903, (401) 277-3500, ext. 150.	Same.
South Carolina: Virgil R. Autry, Director, Division of Radioactive Waste Management, South Carolina Department of Health and Environmental Control, 2600 Bull Street, Columbia, SC 29201, (803) 896-4244, Emergency: (803) 253-6488.	Same.
South Dakota: Gary N. Whitney, Division Director, Emergency Management, 500 E. Capitol Avenue, Pierre, SD 57501-5060, (605) 773-3231.	Same.
Tennessee: John White, Assistant Deputy Director, Tennessee Emergency Management Agency, State Emergency Operations Center, 3041 Sidco Drive, Nashville, TN 37204, (615) 741-0001, After hours: (Inside TN) 1-800-262-3300, (Outside TN) 1-800-258-3300.	Same.
Texas: Richard A. Ratliff, Chief, Bureau of Radiation Control, Texas Department of Health, 1100 West 49th Street, Austin, TX 78756, (512) 834-6688.	2
Utah: William J. Sinclair, Director, Division of Radiation Control, 168 North 1950 West, P.O. Box 144850, Salt Lake City, UT 84114-4850, (801) 536-4250, After hours: (801) 536-4123.	Same.
Vermont: Patrick J. Garahan, Secretary, Vermont Transportation Agency, 133 State Street, Montpelier, VT 05633-5001, (802) 828-2657.	Same.

## INDIVIDUALS RECEIVING ADVANCE NOTIFICATION OF NUCLEAR WASTE SHIPMENTS—Continued

State and Part 71	Part 73
Virginia: L. Ralph Jones, Jr., Director, Technological Hazards Division, Department of Emergency Services, Commonwealth of Virginia, 310 Turner Road, Richmond, VA 23225, (804) 674-2400.	Same.
Washington: Commander Maurice C. King, Washington State Patrol, General Administration Building, P.O. Box 42613, Olympia, WA 98504-2613, (360) 586-2340.	Same.
West Virginia: Colonel Thomas L. Kirk, Superintendent, Division of Public Safety, West Virginia State Police, 725 Jefferson Road, South Charleston, WV 25309, (304) 746-2111.	Same.
Wisconsin: Leroy E. Conner, Jr., Administrator, Wisconsin Division of Emergency Government, P.O. Box 7865, Madison, WI 53707-7865, (608) 242-3232.	Same.
Wyoming: Captain L. S. Gerard, Motor Carrier Officer, Wyoming Highway Patrol, 5300 Bishop Boulevard, P.O. Box 1708, Cheyenne, WY 82003-1708, (307) 777-4317, 24 hours: (307) 777-4323.	Same.
District of Columbia: Norma J. Stewart, Program Manager, Pharmaceutical, Radiological, and Medical Devices Control Division, Department of Consumer and Regulatory Affairs, 614 H Street, NW, Washington, DC 20001, (202) 727-7218, After hours: (202) 727-6161.	Same.
Puerto Rico: Hector Russe Martinez, Chairman, Environmental Quality Board, P.O. Box 11488, San Juan, PR 00910, (809) 767-8056 or (809) 725-5140.	Same.
Guam: Fred M. Castro, Administrator, Environmental Protection Agency, P.O. Box 2999, Agana, Guam 96910, (671) 646-8863/64/65.	Same.
Virgin Islands: Roy L. Schneider, Governor, Governor's Office, 21-22 Kongens Gade, St. Thomas, Virgin Islands 00802, (809) 774-0001.	Same.
American Samoa: Pati Fai'ai, Government Ecologist, Environmental Protection Agency, Office of the Governor, Pago Pago, American Samoa 96799, (684) 633-2304.	Same.

## INDIVIDUALS RECEIVING ADVANCE NOTIFICATION OF NUCLEAR WASTE SHIPMENTS—Continued

State and Part 71	Part 73
Commonwealth of the Northern Mariana Islands: Nicolas M. Leon Guerrero, Director, Department of Natural Resources Commonwealth of Northern Mariana Islands Government, Capitol Hill, Saipan, MP 96950, (670) 322-9830 or (670) 322-9834.	Same.

<sup>1</sup> Jim Greene, Administrator, Disaster and Emergency Services, P.O. Box 4789, Helena, MT 59604 (406) 444-6911

<sup>2</sup> Col. James Wilson, Director, Texas Department of Public Safety, 5805 N. Lamar Blvd., Austin, TX 78752, (512) 465-2000.

Questions regarding this matter should be directed to Spiros Droggitis at (301) 415-2367.

Dated at Rockville, Maryland this 21st day of June 1995.

For the Nuclear Regulatory Commission.

**Richard L. Bangart,**

*Director, Office of State Programs.*

[FR Doc. 95-15676 Filed 6-29-95; 8:45 am]

BILLING CODE 7590-01-M

## [Docket Nos. 50-390 and 50-391]

**Tennessee Valley Authority; Availability of Safety Evaluation Report Supplement Related to the Operation of Watts Bar Nuclear Plant, Units 1 and 2**

The U.S. Nuclear Regulatory Commission has published the Safety Evaluation Report, Supplement 15 (NUREG-0847, Supp. 15) related to the operation of Watts Bar Nuclear Plant, Units 1 and 2, Docket Nos. 50-390 and 50-391.

Copies of the report have been placed in the NRC's Public Document Room, the Gelman Building, 2120 L Street NW., Washington, DC 20555, and in the Local Public Document Room, Chattanooga-Hamilton Library, 1001 Broad Street, Chattanooga, Tennessee 37402, for review by interested persons. Copies of the report may be purchased from the Superintendent of Documents, U.S. Government Printing Office, Post Office Box 37082, Washington, DC 20013-7082. GPO deposit account holders may charge orders by calling 202-512-2249 or 2171. Copies are also available from the National Technical Information Service, 5285 Port Royal Road, Springfield, Virginia 22161.

Dated at Rockville, Maryland this 22nd day of June, 1995.

For The Nuclear Regulatory Commission.

**Peter S. Tam,**

*Senior Project Manager, Project Directorate II-3, Division of Reactor Projects—II/II, Office of Nuclear Regulatory Commission.*

[FR Doc. 95-16111 Filed 6-29-95; 8:45 am]

BILLING CODE 7590-01-M

## [Docket Nos. 50-295 and 50-304]

**Commonwealth Edison Company; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing**

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of amendments to Facility Operating License No. CPR-39, and Facility Operating License No. DPR-48 issued to Commonwealth Edison Company (ComEd, the licensee), for operation of the Zion Nuclear Power Station, Unit 1 and Unit 2, respectively, located in Lake County, Illinois.

The proposed amendment would add a provision to the Technical Specifications (TSs) to allow the hot restart sequence loading test of the emergency diesel generators (EDGs) to be performed independent of the 24-hour endurance test. The TSs currently incorporate by referencing Regulatory Guide 1.108, the requirement that the tests be performed in a certain sequence, the 24-hour endurance test first, followed immediately by the hot restart sequence loading test. The proposed change consists of a footnote added to Specification 4.15.1.B.3 which states that the hot restart sequence loading test need not be performed immediately following the 24-hour endurance test, but shall be performed within 5 minutes of shutting down the EDG after it has operated for a minimum of 2 hours between 3600 and 4000 KW. In addition, statements are added to the Bases in Section 4.15 to note this change to the required testing.

10 CFR 50.91(a)(6) specifies that the Commission may, where exigent circumstances exist, allow less than 30 days for public comment. Exigent circumstances have been found to exist for this proposed amendment. The licensee identified the emergency diesel generator testing as an issue of noncompliance with the TSs on June 12, 1995, during a review of another license amendment request. Changes to the EDG test procedure made during preparations for the dual unit outage (DUO) of fall 1993 allowed the hot restart sequence loading test to be performed independently of the 24-hour endurance run. These tests were