

actual annual heat input for units 1 and 2 shall not be greater than the annual heat input limits of 723,608 MMBtu and 731,528 MMBtu, respectively. The other units designated in this plan are Jack Watson units 4 and 5, Lansing Smith units 1 and 2, Victor J. Daniel units 1 and 2, and Crist units 4, 5, and 6. The designated representative is Frederick D. Kuester.

Victor J. Daniel in Florida: Units 1 and 2 will each comply with a NO_x averaging plan for 1996–1999. For each year under the plan, the actual annual average emission rate for NO_x for each of these units shall not exceed the alternative contemporaneous annual emission limitation of 0.34 lbs/MMBtu, and the actual annual heat input for units 1 and 2 shall not be less than the annual heat input limits of 21,244,417 MMBtu and 29,987,051 MMBtu, respectively. The other units designated in this plan are Jack Watson units 4 and 5, Lansing Smith units 1 and 2, Scholz units 1 and 2, and Crist units 4, 5, and 6. The designated representative is Frederick D. Kuester.

Arkwright in Georgia: One NO_x compliance plan for 1996–1999 in which units 1 and 2 will comply with the standard emission limitation of 0.45 lbs/MMBtu, and units 3 and 4 will comply with the standard emission limitation of 0.50 lbs/MMBtu. The designated representative is C.M. Hobson.

Harlee Branch in Georgia: One NO_x compliance plan for 1996–1999 in which unit 3 will comply with the standard emission limitation of 0.50 lbs/MMBtu. The designated representative is C.M. Hobson.

McIntosh in Georgia: One NO_x compliance plan for 1996–1999 in which unit 1 will comply with the standard emission limitation of 0.50 lbs/MMBtu. The designated representative is L.O. Keller.

Mitchell in Georgia: One NO_x compliance plan for 1996–1999 in which unit 3 will comply with the standard emission limitation of 0.45 lbs/MMBtu. The designated representative is C.M. Hobson.

Port Wentworth in Georgia: One NO_x compliance plan for 1996–1999 in which units 1, 2, and 3 will each comply with the standard emission limitation of 0.45 lbs/MMBtu. The designated representative is L.O. Keller.

Scherer in Georgia: One NO_x compliance plan for 1996–1999 in which unit 3 will comply with the standard emission limitation of 0.45 lbs/MMBtu. The designated representative is R.H. Haubein.

Dated: November 3, 1995.

Brian J. McLean,

Director, Acid Rain Division, Office of Atmospheric Programs, Office of Air and Radiation.

[FR Doc. 95–28040 Filed 11–9–95; 8:45 am]

BILLING CODE 6560–50–P

[FRL–5330–7]

Acid Rain Program: Notice of Written Exemptions

AGENCY: Environmental Protection Agency (EPA).

ACTION: Notice of written exemptions.

SUMMARY: The Environmental Protection Agency is issuing, as a direct final action, written exemptions from the Acid Rain permitting and monitoring requirements to 7 utility units at 2 plants in accordance with the Acid Rain Program regulations (40 CFR part 72). Because the Agency does not anticipate receiving adverse comments, the exemptions are being issued as a direct final action.

DATES: Each of the exemptions issued in this direct final action will be final on December 26, 1995, unless significant, adverse comments are received by December 13, 1995. If significant, adverse comments are timely received on any exemption in this direct final action, that exemption will be withdrawn through a notice in the Federal Register.

ADDRESSES: *Administrative Records.* The administrative record for the exemptions, except information protected as confidential, may be viewed during normal operating hours at EPA Region 5, 77 West Jackson Blvd., Chicago, IL 60604.

FOR FURTHER INFORMATION CONTACT: For plants in Minnesota, Franklin Echevarria, (312) 886–9653, for plants in Wisconsin, Beth Valenziano, (312) 886–2703.

SUPPLEMENTARY INFORMATION: All public comment received on any exemption in this direct final action on which significant, adverse comments are timely received will be addressed in a subsequent issuance or denial of exemption based on the relevant draft exemption in the notice of draft written exemptions that is published elsewhere in today's Federal Register and that is identical to this direct final action.

Under the Acid Rain Program regulations (40 CFR 72.7), utilities may petition EPA for an exemption from permitting and monitoring requirements for any new utility unit that serves one or more generators with total nameplate capacity of 25 MW or less and burns

only fuels with a sulfur content of 0.05 percent or less by weight. On the earlier of the date a unit exempted under 40 CFR 72.7 burns any fuel with a sulfur content in excess of 0.05 percent by weight or 24 months prior to the date the exempted unit first serves one or more generators with total nameplate capacity in excess of 25 MW, the unit shall no longer be exempted under 40 CFR 72.7 and shall be subject to all permitting and monitoring requirements of the Acid Rain Program.

EPA is issuing written exemptions to the following new units, effective from January 1, 1996 through December 31, 2000:

IEA Georgia Pacific units 1, 2, 3, 4, and 5 in Minnesota. The designated representative is William C. Douglas.

Oneida Casino units 1 and 2 in Wisconsin. The designated representative is Gary T. Van Helvoirt.

Dated: November 3, 1995.

Brian J. McLean,

Director, Acid Rain Division, Office of Atmospheric Programs, Office of Air and Radiation.

[FR Doc. 95–28041 Filed 11–9–95; 8:45 am]

BILLING CODE 6560–50–P

[FRL–5331–5]

Common Sense Initiative Council, Iron and Steel Sector Subcommittee Meeting

AGENCY: Environmental Protection Agency (EPA).

ACTION: Notice of open meeting of the Public Advisory Common Sense Initiative Council, Iron and Steel Sector Subcommittee.

SUMMARY: Pursuant to the Federal Advisory Committee Act, Public Law 92–463, notice is given that, pending resolution of EPA's FY 1996 appropriation, the Iron and Steel Sector Subcommittee of the Common Sense Initiative Council will meet on Thursday, December 7, 1995 in Washington, D.C. The Subcommittee is currently overseeing approved projects and exploring issues related to the iron and steel industry. Limited time will be provided for members of the public to make oral comments at the meeting.

OPEN MEETING NOTICE: Notice is hereby given that the Environmental Protection Agency, pending resolution of its FY 1996 appropriation, is convening an open meeting of the Iron and Steel Sector Subcommittee on Thursday, December 7, 1995. The meeting will begin at 8:00 a.m. est and run until 4:00 p.m. est, and will be held at the Doubletree Hotel Park Terrace, 1515