

includes the control number assigned to each schedule, and briefly describes the records proposed for disposal. The records schedule contains additional information about the records and their disposition. Further information about the disposition process will be furnished to each requester.

Schedules Pending

1. Department of the Army (N1-335-96-1). Routine administrative records of the 50th Anniversary of World War II Commemoration Committee.
2. Department of Energy (N1-434-96-5). Administrative, housekeeping, production, shipping, and stockpile support records for the nuclear weapons program. Historically significant policy direction, program management, weapon effects testing, and nuclear surety files are retained as permanent. Records relating to accidental exposure or other epidemiological concerns will be retained for 75 years.
3. Department of Justice, Federal Bureau of Investigation (N1-065-95-01). Administrative field files relating to applicant matters.
4. Department of Justice, Federal Bureau of Investigation (N1-065-95-02). Administrative field files relating to training matters.
5. Department of Justice, Immigration and Naturalization Service (N1-085-96-4). Consenting Alien Program records.
6. Department of State, Bureau of Public Affairs (N1-059-95-27). Routine, facilitative, and duplicative records of the office of the assistant secretary.
7. Department of Transportation, Federal Aviation Administration (N1-237-96-6). Administrator's Consumer Hotline files.
8. Department of the Treasury, Internal Revenue Service (N1-058-95-3). Tracking reports and work papers relating to the operations of the Taxpayer Ombudsman's Problem Resolution Program.
9. National Archives and Records Administration (N2-260-96-1). Duplicated motion picture film relating to the administration of the Ryukyu Islands, accumulated by the U.S. Civil Administration Ryukyu Islands.
10. Social Security Administration (N1-047-96-2). Records of the office of the Inspector General.
11. Social Security Administration (N1-047-96-3). Records of the Office of the General Counsel.

Dated: April 25, 1996.

James W. Moore,
Assistant Archivist for Records
Administration.

[FR Doc. 96-10938 Filed 5-1-96; 8:45 am]

BILLING CODE 7515-01-M

NATIONAL SCIENCE FOUNDATION

Special Emphasis Panel in Materials Research; Notice of Meetings

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463 as amended), the National Science Foundation announces the following meetings:

Name: Special Emphasis Panel in Materials Research (DMR) #1203.

Dates, and Times: May 12, 1996, 6 p.m.-9 p.m.; May 13-17, 1996, 8 a.m.-9 p.m.; May 19, 6 p.m.-9 p.m.; May 20-24, 1996, 8 a.m.-9 p.m.

Place: National Science Foundation; 4201 Wilson Blvd., Arlington, VA; Rooms 360, 375, 390, & 430.

Type of Meetings: Closed.

Contact Person: Dr. W. Lance Haworth, Dr. Carmen Huber, or Dr. Ulrich Strom, Program Directors, Materials Research Science and Engineering Centers, Division of Materials Research, Room 1065, National Science Foundation, Arlington, VA 22230. Telephone (703) 306-1810.

Purpose of Meetings: To provide advice and recommendations concerning proposals submitted to NSF for financial support.

Agenda: Review and evaluate proposals as part of the selection process to determine finalists considered for Materials Research Science and Engineering Center awards.

Reason for Closing: The proposals being reviewed include information of a proprietary or confidential nature, including technical information, financial data such as salaries, and personal information concerning individuals associated with the proposals. These matters are exempt under 5 U.S.C. 552b.(c) (4) and (6) of the Government in the Sunshine Act.

Reason for Late Notice: Times and dates could not be finalized until approval by Dr. William C. Harris, Assistant Director, Directorate for Mathematical and Physical Sciences. This approval was contingent upon Program Director recommendations based upon the MRSEC Special Emphasis Panel which met April 15-17, 1996.

Dated: April 29, 1996.

M. Rebecca Winkler,

Committee Management Officer.

[FR Doc. 96-10944 Filed 5-1-96; 8:45 am]

BILLING CODE 7555-01-M

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-282, 50-306]

Receipt of Addendum to Petition for Director's Decision Under 10 CFR 2.206

In the matter of Northern States Power Company; Prairie Island Nuclear Generating Plant.

Notice is hereby given that by letter dated March 13, 1996, the Nuclear Information and Resource Service and

the Prairie Island Coalition request that the U.S. Nuclear Regulatory Commission (NRC) take immediate action with regard to steam generator tube inspections at the Prairie Island Nuclear Generating Plant. The letter was a second addendum to an earlier Petition dated June 5, 1995. A first addendum was received from the Petitioners in a letter dated February 19, 1996.

The Petitioners request that the NRC require Northern States Power Company to place Prairie Island Nuclear Generating Plant Units 1 and 2 in mid-cycle outages to inspect the full length of the steam generator tubes using the Zetec Plus Point Probe and any state-of-the-art eddy current test capable of finding circumferentially oriented cracking. If these inspections are not performed, the Petitioners request that the NRC hold an informal public hearing in or near Red Wing, Minnesota, to inform the public why such inspections are not needed.

As the basis for this request, the Petitioners state that the NRC and nuclear utilities operating pressurized-water reactor facilities in the U.S. have known for years that the bobbin coil eddy current inspection probe is not effective at finding circumferentially oriented cracking. Circumferential and axial cracks have been found in the tubesheet region of steam generators; inspections with advanced technology probes that are effective in detecting circumferential cracks, such as the Plus Point Probe, are performed in the tubesheet region. The Petitioners state that since axially oriented cracks have been identified in steam generator free-span regions, circumferentially oriented cracks may also be present there. Thus a full-length tube inspection using state-of-the-art eddy current probe technology would be prudent.

This addendum to the Petition is being treated pursuant to 10 CFR 2.206 of the Commission's regulations and has been referred to the Director of the Office of Nuclear Reactor Regulation. As provided by 10 CFR 2.206, appropriate action will be taken on the Petition within a reasonable time. By letter dated April 22, 1996, the Director denied the request for immediate action to require that Prairie Island Units 1 and 2 be placed in mid-cycle outages to inspect the full length of the steam generator tubes.

Copies of the addenda to the Petition and the Director's letter are available for inspection at the Commission's Public Document Room at 2120 L Street, NW., Washington, DC, and at the Local Public Document Room, Minneapolis Public Library, Technology and Science