

For further information and a detailed description of the permits and permit modifications, see the information provided in the notice of permits and permit modifications elsewhere in today's **Federal Register**.

Dated: April 10, 1997.

**Brian J. McLean,**

*Director, Acid Rain Division, Office of Atmospheric Programs, Office of Air and Radiation.*

[FR Doc. 97-9865 Filed 4-15-97; 8:45 am]

BILLING CODE 6560-50-P

## ENVIRONMENTAL PROTECTION AGENCY

[FRL-5812-5]

### Acid Rain Program: Permit and Permit Modifications

**AGENCY:** Environmental Protection Agency (EPA).

**ACTION:** Notice of permits and permit modifications.

**SUMMARY:** The U.S. Environmental Protection Agency (EPA) is issuing, as a direct final action, Phase I Acid Rain permits and permit modifications including nitrogen oxides (NO<sub>x</sub>) compliance plans in accordance with the Acid Rain Program regulations (40 CFR parts 72 and 76). Because the Agency does not anticipate receiving adverse comments, the exemptions are being issued as a direct final action.

**DATES:** The permits and permit modifications issued in this direct final action will be final on May 26, 1997 or 40 days after publication of a similar notice in a local publication, whichever is later, unless significant, adverse comments are received by May 16, 1997 or 30 days after publication of a similar notice in a local publication, whichever is later. If significant, adverse comments are timely received on any permit or permit modification in this direct final action, that permit or permit modification will be withdrawn through a notice in the **Federal Register**.

**ADDRESSES:** *Administrative Records.* The administrative record for the permits, except information protected as confidential, may be viewed during normal operating hours at the following locations: for plants in New York, EPA Region 2, 290 Broadway, New York, NY, 10007-1866; for plants in Alabama, Florida, Georgia, Kentucky, North Carolina, South Carolina and Tennessee, EPA Region 4, 100 Alabama St., NW, Atlanta, GA, 30303; for plants in Illinois, Indiana, Michigan, Minnesota, Ohio, and Wisconsin, EPA Region 5, 77 West Jackson Blvd., Chicago, IL, 60604;

for plants in Colorado, Montana, North Dakota, Utah and Wyoming, EPA Region 8, 999 18th St., Denver, CO, 80202.

**Comments.** Send comments, requests for public hearings, and requests to receive notice of future actions to: for plants in New York, EPA Region 2, Division of Environmental Planning & Protection, Attn: Gerry DeGaetano (address above); for plants in Alabama, Florida, Georgia, Kentucky, North Carolina, South Carolina and Tennessee, EPA Region 4, Air, Pesticides and Toxics Management Division, Attn: Scott Davis (address above); for plants in Illinois, Indiana, and Ohio, EPA Region 5, Air and Radiation Division, Attn: Cecilia Mijares (address above); for plants in Michigan, Minnesota, and Wisconsin, EPA Region 5, Air and Radiation Division, Attn: Beth Valenziano (address above); for plants in Colorado, Montana, North Dakota, Utah and Wyoming, EPA Region 8, Air and Toxics Division, Attn: Mike Owens (address above). Submit comments in duplicate and identify the permit to which the comments apply, the commenter's name, address, and telephone number, and the commenter's interest in the matter and affiliation, if any, to the owners and operators of all units in the plan. All timely comments will be considered, except those pertaining to standard provisions under 40 CFR 72.9 or issues not relevant to the permit or the permit modification.

**Hearings.** To request a public hearing, state the issues proposed to be raised in the hearing. EPA may schedule a hearing if EPA finds that it will contribute to the decision-making process by clarifying significant issues affecting a NO<sub>x</sub> compliance plan.

**FOR FURTHER INFORMATION CONTACT:** For plants in New York, call Gerry DeGaetano, 212-637-4020; for plants in Alabama, Florida, Georgia, Kentucky, North Carolina, South Carolina and Tennessee, call Scott Davis, 404-562-9127; for plants in Illinois, Indiana, and Ohio, call Cecilia Mijares, 312-886-0968; for plants in Michigan, Minnesota, and Wisconsin, call Beth Valenziano, 312-886-2703; for plants in Colorado, Montana, North Dakota, Utah and Wyoming, call Mike Owens, 303-312-6440.

**SUPPLEMENTARY INFORMATION:** Title IV of the Clean Air Act directs EPA to establish a program to reduce the adverse effects of acidic deposition by promulgating rules and issuing permits to emission sources subject to the program. In today's action, EPA is issuing permits and permit modifications that include approval of early election plans for NO<sub>x</sub>. The units

that are included in the early election plans will be required to meet an actual annual average emissions rate for NO<sub>x</sub> of either 0.45 lbs/MMBtu for tangentially-fired boilers or 0.50 lbs/MMBtu for dry bottom wall-fired boilers beginning on January 1, 1997 through December 31, 2007, after which they will be required to meet the applicable emissions limitation under 40 CFR 76.7(a) of 0.40 lbs/MMBtu for tangentially-fired boilers or 0.46 lbs/MMBtu for dry bottom wall-fired boilers. The following is a list of units included in the permits or permit modifications and the limits that they are required to meet:

S A Carlson units 9, 10, 11, and 12 in New York: 0.50 lbs/MMBtu. The designated representative is R. James Gronquist.

Kintigh unit 1 in New York: 0.50 lbs/MMBtu. The designated representative is James Rettberg.

Charles R Lowman units 2 and 3 in Alabama: 0.50 lbs/MMBtu. The designated representative is John Howard.

C D McIntosh unit 3 in Florida: 0.50 lbs/MMBtu. The designated representative is Ronald Tomlin.

Crystal River units 2, 4, and 5 in Florida: 0.45 lbs/MMBtu for unit 2; 0.50 lbs/MMBtu for units 4 and 5. The designated representative is W. Jeffrey Pardue.

Deerhaven unit B2 in Florida: 0.50 lbs/MMBtu. The designated representative is John Hancock, Jr.

St. Johns River Power Park units 1 and 2 in Florida: 0.50 lbs/MMBtu. The designated representative is Brian Wirz.

Scherer unit 4 in Georgia: 0.45 lbs/MMBtu. The designated representative is R. Haubein, Jr.

D B Wilson unit W1 in Kentucky: 0.50 lbs/MMBtu. The designated representative is Gregory Black.

Cane Run units 4, 5, and 6 in Kentucky: 0.50 lbs/MMBtu for units 4 and 5; 0.45 lbs/MMBtu for unit 6. The designated representative is Chris Herman.

Mill Creek units 1, 2, 3, and 4 in Kentucky: 0.45 lbs/MMBtu for units 1 and 2; 0.50 lbs/MMBtu for units 3 and 4. The designated representative is Chris Herman.

Trimble County unit 1 in Kentucky: 0.45 lbs/MMBtu. The designated representative is Chris Herman.

Buck units 5, 6, 7, 8, and 9 in North Carolina: 0.45 lbs/MMBtu. The designated representative is T. McMeekin.

Cliffside units 1, 2, 3, 4, and 5 in North Carolina: 0.45 lbs/MMBtu. The

- designated representative is T. McMeekin.
- Dan River units 1, 2, and 3 in North Carolina: 0.45 lbs/MMBtu. The designated representative is T. McMeekin.
- G G Allen units 1, 2, 3, 4, and 5 in North Carolina: 0.45 lbs/MMBtu. The designated representative is T. McMeekin.
- Lee units 1, 2, and 3 in North Carolina: 0.45 lbs/MMBtu for unit 1; 0.50 lbs/MMBtu for units 2 and 3. The designated representative is Ronnie Coats.
- Marshall units 1, 2, 3, and 4 in North Carolina: 0.45 lbs/MMBtu. The designated representative is T. McMeekin.
- Riverbend units 7, 8, 9, and 10 in North Carolina: 0.45 lbs/MMBtu. The designated representative is T. McMeekin.
- Cross units 1 and 2 in South Carolina: 0.50 lbs/MMBtu for unit 1; 0.45 lbs/MMBtu for unit 2. The designated representative is Maxie Chaplin.
- Winyah units 2, 3, and 4 in South Carolina: 0.50 lbs/MMBtu. The designated representative is Maxie Chaplin.
- John Sevier units 1, 2, 3, and 4 in Tennessee: 0.45 lbs/MMBtu. The designated representative is Joseph Dickey.
- Dallman unit 33 in Illinois: 0.45 lbs/MMBtu. The designated representative is William Murray.
- Crawford units 7 and 8 in Illinois: 0.45 lbs/MMBtu. The designated representative is Emerson Lacey.
- Fisk unit 19 in Illinois: 0.45 lbs/MMBtu. The designated representative is Emerson Lacey.
- Waukegan units 7 & 8 in Illinois: 0.45 lbs/MMBtu. The designated representative is Emerson Lacey.
- Will County units 3 and 4 in Illinois: 0.45 lbs/MMBtu. The designated representative is Emerson Lacey.
- State Line unit 3 in Indiana: 0.45 lbs/MMBtu. The designated representative is Emerson Lacey.
- Merom units 1SG1 and 2SG1 in Indiana: 0.50 lbs/MMBtu. The designated representative is J. Steven Smith.
- R M Schahfer units U15, U17, and U18 in Indiana: 0.50 lbs/MMBtu for unit U15; 0.45 lbs/MMBtu for units U17 and U18. The designated representative is Patrick Mulchay.
- A B Brown units 1 and 2 in Indiana: 0.50 lbs/MMBtu. The designated representative is J. Gordon Hurst.
- J B Sims unit 3 in Michigan: 0.50 lbs/MMBtu. The designated representative is Phil Trumpfheller.
- B C Cobb units 4 and 5 in Michigan: 0.45 lbs/MMBtu. The designated representative is Robert Nicholson.
- J R Whiting units 1 and 3 in Michigan: 0.50 lbs/MMBtu. The designated representative is Robert Nicholson.
- Presque Isle units 7, 8, and 9 in Michigan: 0.50 lbs/MMBtu. The designated representative is Terry Coughlin.
- Clay Boswell unit 3 in Minnesota: 0.45 lbs/MMBtu. The designated representative is Warren Candy.
- Hoot Lake unit 2 in Minnesota: 0.45 lbs/MMBtu. The designated representative is Ward Uggerud.
- W H Zimmer unit 1 in Ohio: 0.50 lbs/MMBtu. The designated representative is David Hoffman.
- Blount Street units 8 and 9 in Wisconsin: 0.50 lbs/MMBtu. The designated representative is Steven Schultz.
- Columbia units 1 and 2 in Wisconsin: 0.45 lbs/MMBtu. The designated representative is Daniel Doyle.
- Edgewater unit 5 in Wisconsin: 0.50 lbs/MMBtu. The designated representative is Daniel Doyle.
- Ray D Nixon unit 1 in Colorado: 0.50 lbs/MMBtu. The designated representative is James Zalmanek.
- Rawhide unit 101 in Colorado: 0.45 lbs/MMBtu. The designated representative is Lloyd Greiner.
- Cherokee units 3 and 4 in Colorado: 0.50 lbs/MMBtu for unit 3; 0.45 lbs/MMBtu for unit 4. The designated representative is Ralph Sargent.
- Comanche units 1 and 2 in Colorado: 0.45 lbs/MMBtu for unit 1; 0.50 lbs/MMBtu for unit 2. The designated representative is Ralph Sargent.
- Pawnee unit 1 in Colorado: 0.50 lbs/MMBtu. The designated representative is Ralph Sargent.
- Valmont unit 5 in Colorado: 0.45 lbs/MMBtu. The designated representative is Ralph Sargent.
- Craig units C1, C2, and C3 in Colorado: 0.50 lbs/MMBtu. The designated representative is Jerry Walker.
- Colstrip units 1, 2, 3, and 4 in Montana: 0.45 lbs/MMBtu. The designated representative is Carlton Grimm.
- Lewis & Clark unit B1 in Montana: 0.45 lbs/MMBtu. The designated representative is Bruce Imsdahl.
- Antelope Valley units B1 and B2 in North Dakota: 0.45 lbs/MMBtu. The designated representative is Richard Fockler.
- Leland Olds unit 1 North Dakota: 0.50 lbs/MMBtu. The designated representative is Richard Fockler.
- Stanton unit 10 in North Dakota: 0.50 lbs/MMBtu. The designated representative is Gordon Westerlind.
- Bonanza unit 1-1 in Utah: 0.50 lbs/MMBtu. The designated representative is F. Ward Elgin.
- Intermountain units 1SGA and 2SGA in Utah: 0.50 lbs/MMBtu. The designated representative is Dennis Whitney.
- Carbon units 1 and 2 in Utah: 0.45 lbs/MMBtu. The designated representative is William Brauer.
- Hunter units 1 and 2 in Utah: 0.45 lbs/MMBtu. The designated representative is William Brauer.
- Huntington unit 1 in Utah: 0.45 lbs/MMBtu. The designated representative is William Brauer.
- Laramie River units 1, 2, and 3 in Wyoming: 0.50 lbs/MMBtu. The designated representative is Richard Fockler.
- Dave Johnston units BW41 and BW42 in Wyoming: 0.50 lbs/MMBtu. The designated representative is William Brauer.
- Jim Bridger unit BW74 in Wyoming: 0.45 lbs/MMBtu. The designated representative is William Brauer.

Dated: April 10, 1997.

**Brian J. McLean,**

*Director, Acid Rain Division, Office of Atmospheric Programs, Office of Air and Radiation.*

[FR Doc. 97-9866 Filed 4-12-97; 8:45 am]

BILLING CODE 6560-50-P

**ENVIRONMENTAL PROTECTION AGENCY**

[OPP-30381A; FRL-5599-9]

**FMC Corporation; Approval of a Pesticide Product Registration**

**AGENCY:** Environmental Protection Agency (EPA).

**ACTION:** Notice.

**SUMMARY:** This notice announces Agency approval of applications submitted by FMC Corporation, to conditionally register the pesticide products Sulfentrazone Technical, Authority 4F, Authority 75DF, Authority BL, and Authority Broadleaf containing new active ingredients not included in any previously registered products pursuant to the provisions of section 3(c)(7)(C) of the Federal Insecticide, Fungicide, and Rodenticide Act (FIFRA), as amended.

**FOR FURTHER INFORMATION CONTACT:** By mail: Joanne Miller, Product Manager (PM) 23, Registration Division (7505C), Office of Pesticide Programs, 401 M St., SW., Washington, DC 20460. Office location and telephone number: Rm. 237, CM #2, Environmental Protection Agency, 1921 Jefferson Davis Hwy, Arlington, VA 22202, 703-305-6224; e-mail: miller.joanne@epamail.epa.gov.

**SUPPLEMENTARY INFORMATION:**