

be accomplished when a source range neutron detector is inoperable with the plant shutdown. The proposed wording change will clarify the times and order in which these actions are to be performed.

Date of issuance: September 29, 1997

Effective date: September 29, 1997, to be implemented within 30 days from the date of issuance.

Amendment No.: 111

Facility Operating License No. NPF-42: The amendment revised the Technical Specifications.

Date of initial notice in Federal Register: August 27, 1997 (62 FR 45467) The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 29, 1997. No significant hazards consideration comments received: No.

Local Public Document Room

locations: Emporia State University, William Allen White Library, 1200 Commercial Street, Emporia, Kansas 66801 and Washburn University School of Law Library, Topeka, Kansas 66621

Wolf Creek Nuclear Operating Corporation, Docket No. 50-482, Wolf Creek Generating Station, Coffey County, Kansas

Date of amendment request:

September 6, 1997

Brief description of amendment: This amendment allows the testing of certain contacts in the emergency diesel generator load sequencer to be done with the unit at power (Mode 1) and provides an additional 24 hours to the time allowed by TS 4.0.3 to complete the testing.

Date of issuance: October 7, 1997

Effective date: October 7, 1997

Amendment No.: 112

Facility Operating License No. NPF-42. The amendment revised the Technical Specifications. Public comments requested as to proposed no significant hazards consideration: Yes (62 FR 49261 dated September 19, 1997). The notice provided an opportunity to submit comments on the Commission's proposed no significant hazards consideration determination. No comments have been received. The notice also provided for an opportunity to request a hearing by October 20, 1997, but indicated that if the Commission makes a final no significant hazards consideration determination any such hearing would take place after issuance of the amendment. The Commission's related evaluation of the amendment, finding of exigent circumstances, and final determination of no significant hazards consideration are contained in a Safety Evaluation dated October 7, 1997.

Attorney for licensee: Jay Silberg, Esq., Shaw, Pittman, Potts and Trowbridge, 2300 N Street, N.W., Washington, D.C. 20037

Local Public Document Room

locations: Emporia State University, William Allen White Library, 1200 Commercial Street, Emporia, Kansas 66801 and Washburn University School of Law Library, Topeka, Kansas 66621

Dated at Rockville, Maryland, this 15th day of October 1997.

For the Nuclear Regulatory Commission
Elinor G. Adensam,

Acting Director Division of Reactor Projects - III/IV, Office of Nuclear Reactor Regulation [Doc. 97-27877 Filed 10-21-97; 8:45 am]

BILLING CODE 7590-01-F

NUCLEAR REGULATORY COMMISSION

[NUREG-1569]

Draft Standard Review Plan For In Situ Uranium Extraction License Applications

AGENCY: Nuclear Regulatory Commission.

ACTION: Notice of availability; opportunity for comment.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is soliciting comments on a Draft Standard Review Plan for *in Situ* Uranium Extraction License Applications (NUREG-1569) from interested parties. A NRC source and byproduct material license is required under the provisions of Title 10 of the Code of Federal Regulations, Part 40 (10 CFR Part 40), Domestic Licensing of Source Material, to recover uranium by *in situ* leach uranium extraction mining techniques (*in situ* leaching). An applicant for a new operating license, or for the renewal or amendment of an existing license, is required to provide detailed information on the facilities, equipment, and procedures to be used, and if appropriate, an environmental report that discusses the effect of proposed operations on public health and safety and on the environment. This information is used by Nuclear Regulatory Commission staff to determine whether the proposed activities will be protective of public health and safety and be environmentally acceptable. The purpose of this standard review plan is to provide NRC staff with specific guidance on the review of this information and will be used to ensure a consistent quality and uniformity of staff reviews. Each section in the review plan provides guidance on what is to be

reviewed, the basis for the review, how the staff review is to be accomplished, what the staff will find acceptable in a demonstration of compliance with the regulations, and the conclusions that are sought regarding the applicable sections in 10 CFR. The review plan is also intended to improve the understanding of the staff review process by interested members of the public and the uranium recovery industry. The draft was developed using input from (1) staff review precedents; (2) staff inspection experiences; (3) public meetings with industry; and (4) experience from the State of Texas, which is an agreement state for uranium recovery and has 15 licensed *in situ* leach operations.

Opportunity to Comment: Interested parties are invited to comment on the review plan. Interested parties are also asked to comment on the level and extent that staff could rely on technical reviews performed by non-agreement states in areas where the NRC and the State have concurrent regulatory authority. These areas include land application, nonradiological soil cleanup, upper control limit, and groundwater restoration reviews. A final review plan will be prepared after the NRC staff has evaluated public comments received on the draft review plan.

DATES: Written comments must be received prior to December 8, 1997.

ADDRESSES: Comments on the draft review plan should be sent to the Chief, Rules and Directives, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

AVAILABILITY: A copy of the Draft Standard Review Plan (NUREG-1569) may be obtained by writing to the Printing and Graphics Branch, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555-0001.

Dated at Rockville, Maryland, this 14th day of October 1997.

For the Nuclear Regulatory Commission.

Joseph J. Holonich,

Chief, Uranium Recovery Projects Branch, Division of Waste Management, Office of Nuclear Material, Safety and Safeguards.

[FR Doc. 97-28002 Filed 10-21-97; 8:45 am]

BILLING CODE 7590-01-P

SECURITIES AND EXCHANGE COMMISSION

Applications, Hearings, Determinations, Etc. Tivoli Industries, Inc.

October 16, 1997.

Issuer Delisting; Notice of Application to Withdraw from Listing and