

k. *Description of Project:* The licensee requests Commission authorization to permit the Authority to increase its water withdrawal from Lake Rabun reservoir from 806,000 gpd currently to 2,000,000 gpd. Existing pumps and water treatment facilities at the site are able to accommodate the increased water withdrawal; consequently, the proposed action would not involve any new construction activity.

1. *This notice also consists of the following standard paragraph:* B, C1, and D2.

B. *Comments, Protests, or Motions to Intervene*—Anyone may submit comments, a protest, or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 3385.210, .211, .214. In determining the appropriate action to take, the Commission will consider all protests or other comments filed, but only those who file a motion to intervene in accordance with the Commission's Rules may become a party to the proceeding. Any comments, protests, or motions to intervene must be received on or before the specified comment date for the particular application.

C1. *Filing and Service of Responsive Documents*—Any filings must bear in all capital letters the title "COMMENTS", "RECOMMENDATIONS FOR TERMS AND CONDITIONS", "PROTEST", OR "MOTION TO INTERVENE", as applicable, and the Project Number of the particular application to which the filing refers. Any of the above-named documents must be filed by providing the original and the number of copies provided by the Commission's regulations to: The Secretary, Federal Energy Regulatory Commission, 888 First Street, N.E., Washington, D.C. 20426. A copy of any motion to intervene must also be served upon each representative of the Applicant specified in the particular application.

D2. *Agency Comments*—Federal, state, and local agencies are invited to file comments on the described application. A copy of the application may be obtained by agencies directly from the Applicant. If an agency does not file comments within the time specified for filing comments, it will be presumed to have no comments. One copy of an agency's comments must also be sent to the Applicant's representatives.

Linwood A. Watson, Jr.,
Acting Secretary.

[FR Doc. 98-3944 Filed 2-17-98; 8:45 am]

BILLING CODE 6717-01-M

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Notice of Conduit Exemption

February 11, 1998.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection:

a. *Type of Application:* Conduit Exemption.

b. *Project No:* 11468-001.

c. *Date filed:* January 28, 1998.

d. *Applicant:* North Side Canal Company.

e. *Name of Project:* Crossroads Conduit Project.

f. *Location:* On the North Side canal system in Jerome County, Idaho (T. 7S. R. 16E., Sections 23, 24, and 25).

g. *Filed Pursuant to:* Federal Power Act, 16 U.S.C. §§ 791(a)-825(r).

h. *Applicant Contact:*

Randolph J. Hill, Ida-West Energy Company, P.O. Box 7867, Boise, ID 83707, (208) 395-8930

or

John Rosholt, Rosholt, Robertson & Tucker, P.O. Box 1906, Twin Falls, ID 83301, (208) 734-0700.

i. *FERC Contact:* Héctor M. Pérez at (202) 219-2843.

j. *Description of Project:* The proposed project would consist of: (1) A 900-foot-long, 150-foot-wide forebay with a normal water surface elevation of 3,773.5 feet formed by two dikes with a maximum height above existing ground surface of 9 feet; (2) a primary overflow bypass channel with a top elevation of 3,774 feet and a secondary overflow bypass channel with a top elevation of 3,774.75 feet, both at the forebay; (3) a reinforced concrete intake structure; (4) a 10-foot-diameter, 1,750-foot-long steel penstock; and (5) a reinforced concrete powerhouse with a 3,200-kilowatt turbine-generator unit.

k. Under Section 4.32(b)(7) of the Commission's regulations (18 CFR), if any resource agency, Indian Tribe, or person believes that the applicant should conduct an additional scientific study to form an adequate factual basis for a complete analysis of the application on its merits, they must file a request for the study with the Commission, not later than 60 days after the application is filed, and must serve a copy of the request on the applicant.

Linwood A. Watson, Jr.,
Acting Secretary.

[FR Doc. 98-3946 Filed 2-17-98; 8:45 am]

BILLING CODE 6717-01-M

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Notice of Application Acceptance and Notice Requesting Interventions and Protests

February 11, 1998.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection:

a. *Type of Application:* Original License for a Major Water Power Project—5 Megawatts or Less.

b. *Project No.:* 11480.

c. *Date filed:* November 25, 1997.

d. *Applicant:* Haida Corporation.

e. *Name of Project:* Reynolds Creek Hydroelectric Project.

f. *Location:* On Reynolds Creek, Prince of Wales Island, Alaska.

g. *Filed Pursuant to:* Federal Power Act and Public Utility Regulatory Policies Act.

h. *Applicant Contact:* Michael V. Stimac, HDR Engineering, Inc., 500-108th Avenue NE, Suite 1200, Bellevue, Washington 98004-5538, (425) 453-1523.

i. *FERC Contact:* Carl J. Keller, (202) 219-2831.

j. *Deadline for filing interventions and protests:* April 15, 1998.

k. *Status of Environmental Analysis:* This application is not ready for environmental analysis at this time; therefore, the Commission is not now requesting comments, recommendations, terms and conditions, or prescriptions—see attached paragraph D7.

l. *Brief Description of Project:* The proposed modified run-of-river hydroelectric project would consist of: (1) A 20-foot-long, concrete weir, diversion dam and intake at the outlet of Rich's Pond; (2) a 3,200-foot-long, 42-inch diameter, steel penstock, (3) a metal powerhouse initially containing a 1,500 kilowatt (kW) horizontal impulse turbine/generator for Phase I; Phase II would add a second 3,500 kW turbine/generator, (4) about 500 feet of new access road, and (5) a 10.9-mile-long, 34.5 kilovolt overhead transmission line.

m. *This notice also consists of the following standard paragraphs:* A2, A-9, B1, and D7.

n. *Available Locations of Application:* A copy of the application is available for inspection and reproduction at the Commission's Public Reference Room, Room 2A, 888 First Street, N.E., Washington, D.C. 20426 or by calling (202) 208-1659. A copy is also available