

[reference temperature nil ductility temperature] (using Regulatory Guide 1.99 "Radiation Embrittlement of Reactor Vessel Materials," Revision 2), and (3) a limiting material toughness curve based on bounding dynamic crack initiation and crack arrest data.

In addition, NSP explained that plant operators must operate the plant between the minimum pressure required to preserve reactor coolant pump seals and a maximum pressure that does not challenge the power-operated relief valve setpoint. Without the application of ASME Code Case N-514, Prairie Island would have an operating window that is too narrow to permit reasonable system makeup and pressure control. NSP continued by stating that further reduction of the OPPS pressure setpoint below 500 psig would increase the probability that the reactor coolant pump's no. 1 seal will fail as a result of OPPS operation, and that such a seal failure could produce a breach in the reactor coolant system boundary that could not be isolated. Therefore, inadvertent OPPS actuation could lead to a small break loss-of-coolant accident and the unnecessary release of reactor coolant inside containment.

IV

For the foregoing reasons, the NRC staff has concluded that the licensee's proposed use of the alternate methodology in determining the acceptable setpoint for OPPS events will not present an undue risk to public health and safety and is consistent with the common defense and security. The NRC staff has determined that there are special circumstances present, as specified in 10 CFR 50.12(a)(2)(ii), in that the application of 10 CFR 50.60 is not necessary in order to achieve the underlying purpose of this regulation.

The NRC staff agreed with NSP's determination that an exemption would be required to approve the use of Code Case N-514. The NRC staff examined NSP's rationale to support the exemption request and concluded that the use of Code Case N-514 would also meet the underlying intent of the regulations. Based upon a consideration of the conservatism that are explicitly defined in the Appendix G methodology (as listed in Section III above), the staff concluded that permitting the OPPS setpoint to be established such that the vessel pressure would not exceed 110 percent of the limit defined by the P-T limit curves would provide an adequate margin of safety against brittle failure of the reactor vessel. This is also consistent with the determination that the staff has reached for other licensees under

similar conditions based on the same considerations. Therefore, requesting the exemption under the special circumstances of 10 CFR 50.12(a)(2)(ii) was found to be appropriate. The staff also agrees that limiting the potential for inadvertent OPPS actuation (and limiting the potential for reactor coolant pump seal damage) may improve plant safety.

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12(a), an exemption is authorized by law, will not endanger life or property or common defense and security, and is otherwise in the public interest. Therefore, the Commission hereby grants an exemption from the requirements of 10 CFR 50.60 and Appendix G to allow NSP to apply the methods in ASME Code Case N-514 for the determination of the Prairie Island Nuclear Generating Plant Units 1 and 2 pressure setpoints.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (63 FR 23477).

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 30th day of April 1998.

For the Nuclear Regulatory Commission.
Samuel J. Collins,
Director, Office of Nuclear Reactor Regulation.

[FR Doc. 98-12183 Filed 5-6-98; 8:45 am]
BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-259; License No. DPR-33]

Tennessee Valley Authority; Receipt of Petition for Director's Decision Under 10 CFR 2.206

Notice is hereby given that by petition dated April 5, 1998, the Union of Concerned Scientists, (or Petitioner), has requested that the U.S. Nuclear Regulatory Commission (NRC) take action with regard to Browns Ferry Nuclear Plant, Unit No. 1. Petitioner requests (1) that the operating license for Browns Ferry Unit 1 be revoked and (2) that the NRC require the Tennessee Valley Authority (TVA) to submit either a decommissioning plan or a lay-up plan for Browns Ferry Unit 1. Petitioner further requests a hearing on this petition to present new information on Browns Ferry Unit 1 that would include a discussion of the licensing basis reconstitution that would be required to support restart, and certain financial

aspects that might be a consideration for the TVA's decision for retaining the Browns Ferry Unit 1 operating license.

As the basis for this request, the Petitioner asserts that revocation of the operating license and requiring relicensing if TVA later decides to restart Unit 1 is a better, safer process than is the current Inspection Manual Chapter 0350 restart process. Further, the petition asserts that requiring a decommissioning plan would provide assurance that the irradiated fuel is stored safely and that Units 2 and 3 are sufficiently independent of Unit 1 for safe operation.

The petition is being treated pursuant to 10 CFR 2.206 of the Commission's regulations and has been referred to the Director of the Office of Nuclear Reactor Regulation. As provided by Section 2.206, appropriate action will be taken on this petition within a reasonable time.

By letter dated April 29, 1998, the Director acknowledged receipt of the petition and denied Petitioner's request for a public hearing to present new information.

A copy of the petition is available for inspection at the Commission's Public Document Room at 2120 L Street, NW., Washington, D.C. 20555.

Dated at Rockville, Maryland, this 29th day of April 1998.

For the Nuclear Regulatory Commission.
Samuel J. Collins,
Director, Office of Nuclear Reactor Regulation.

[FR Doc. 98-12178 Filed 5-6-98; 8:45 am]
BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-390]

Tennessee Valley Authority; Notice of Consideration of Issuance of Amendment To Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-90, issued to the Tennessee Valley Authority (TVA or the licensee) for operation of the Watts Bar Nuclear Plant (WBN), Unit 1 located in Rhea County, Tennessee.

WBN currently has two containment hydrogen igniters that are inoperable due to an apparent fault in the common circuit supplying these igniters. This condition renders Train A of the WBN