

Library, 663 Franklin Avenue,
Aliquippa, PA 15001.

Dated at Rockville, Maryland, this 24th day
of November, 1998.

For the Nuclear Regulatory Commission.

Donald S. Brinkman,

*Senior Project Manager, Project Directorate
I-2, Division of Reactor Projects—I/II, Office
of Nuclear Reactor Regulation.*

[FR Doc. 98-31932 Filed 11-30-98; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-302]

Florida Power Corporation; Notice of Withdrawal of Application for Amendment to Facility Operating License

The U.S. Nuclear Regulatory
Commission (the Commission) has
granted a request by the Florida Power
Corporation (FPC) to withdraw its
October 31, 1997, application for an
amendment to Facility Operating
License No. DPR 72, issued to FPC for
operation of the Crystal River Nuclear
Generating Unit 3 (CR3) located in
Citrus County, Florida. Notice of
consideration of issuance of this
amendment was published in the
Federal Register on November 12, 1997
(62 FR 60735).

The proposed amendment would
have revised the CR3 Technical
Specifications (TS) relating to decay
heat removal requirements in Mode 4.
The proposed modification would have
revised the TS and associated Bases to
require in Mode 4, one operable
emergency feedwater (EFW) train and

associated equipment, including the
EFW tank, emergency feedwater
initiation and control actuation
instrumentation for EFW, post accident
monitoring instrumentation, and the
turbine bypass valves. Additionally, the
TS and associated Bases would have
been revised to require in Mode 4, a
low-pressure injection (LPI) train,
dedicated to the borated water storage
tank, and to reflect that the available
loops for decay heat removal do not
include this dedicated LPI train.
Editorial changes would also have been
made to clarify the description of Mode
4 accidents requiring emergency core
cooling system injection, and to revise
the title of TS limiting condition for
operation 3.7.5.

FPC's letter of November 18, 1998,
informed the staff that the request was
being withdrawn because the NRC staff
had indicated that the subject of reactor
decay heat removal requirements during
Mode 4 operation would be treated as a
generic industry issue. In this letter,
FPC committed to continue to maintain
administrative controls for the
additional equipment and capability to
remove decay heat identified in the
October 31, 1997, request during Mode
4 operation of CR-3.

For further details with respect to this
action, see the application for
amendment dated October 31, 1997, and
FPC's withdrawal letter dated November
18, 1998, which are available for public
inspection at the Commission's Public
Document Room, the Gelman Building,
2120 L Street, NW., Washington, DC and
at the local public document room
located at the Coastal Region Library,
8619 W. Crystal Street, Crystal River,
Florida.

NRC EXPORT LICENSE APPLICATION

Name of applicant, date of application, date re- ceived, application No.	Description of material		End use	Country
	Material type	Total qty		
Transnuclear, Inc., October 30, 1998, November 2, 1998, XSNM03060.	High-enriched Uranium (93.3%).	130.65 kg	Production of medical isotopes.	Canada.

For the Nuclear Regulatory Commission.

Dated this 24th day of November 1998 at
Rockville, Maryland.

Ronald D. Hauber,

*Director, Division of Nonproliferation,
Exports and Multilateral Relations, Office of
International Programs.*

[FR Doc. 98-31929 Filed 11-30-98; 8:45 am]

BILLING CODE 7590-01-M

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-338 and 50-339]

Virginia Electric and Power Company; Notice of Withdrawal of Application For Amendment To Facility Operating License

The U.S. Nuclear Regulatory
Commission (the Commission) has
granted the request of Virginia Electric
and Power Company (the licensee) to
withdraw its March 21, 1996,

Dated at Rockville, Maryland, this 24th day
of November, 1998.

For the Nuclear Regulatory Commission.

Leonard A. Wiens,

*Senior Project Manager, Project Directorate
II-3, Division of Reactor Projects—I/II, Office
of Nuclear Reactor Regulation.*

[FR Doc. 98-31936 Filed 11-30-98; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Application for a License To Export Special Nuclear Material

Pursuant to 10 CFR 110.70(b) "Public
notice of receipt of an application",
please take notice that the Nuclear
Regulatory Commission has received the
following application for an export
license. Copies of the application are on
file in the Nuclear Regulatory
Commission's Public Document Room
located at 2120 L Street, N.W.,
Washington, D.C.

A request for a hearing or petition for
leave to intervene may be filed within
30 days after publication of this notice
in the **Federal Register**. Any request for
hearing or petition for leave to intervene
shall be served by the requestor or
petitioner upon the applicant, the Office
of the General Counsel, U.S. Nuclear
Regulatory Commission, Washington,
D.C. 20555; the Secretary, U.S. Nuclear
Regulatory Commission, Washington,
D.C. 20555; and the Executive Secretary,
U.S. Department of State, Washington,
D.C. 20520.

The information concerning the
application follows.

application for proposed amendments to
Facility Operating License Nos. NPF-4
and NPF-7 for the North Anna Power
Station, Unit Nos. 1 and 2, located in
Louisa County, Virginia.

The proposed amendments would
have clarified the requirements for
testing charcoal adsorbent in the Waste
Gas Charcoal Filter System, the Control
Room Emergency Habitability System,
and the Safeguards Area Ventilation
System.

The Commission had previously
issued a Notice of Consideration of