

Hall, Environmental Coordinator, at (202) 219-2853.

Linwood A. Watson, Jr.,

Acting Secretary.

[FR Doc. 99-16724 Filed 6-20-99; 8:45 am]

BILLING CODE 6717-01-M

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Notice of Amendment of License and Soliciting Comments, Motions To Intervene, and Protests

June 25, 1999.

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection:

a. *Type of Application:* Amendment of Exhibit S.

b. *Project No.:* 2426-144.

c. *Date Filed:* March 25, 1999.

d. *Applicant:* California Department of Water Resources.

e. *Name of Project:* California Aqueduct Project.

f. *Location:* The project is located in San Bernardino and Los Angeles Counties, California. The project does not utilize federal or tribal lands.

g. *Filed Pursuant to:* 18 CFR 4.200.

h. *Applicant Contact:* Dale Martfeld, Department of Water Resources, 1418 Ninth St., P.O. Box 942838, Sacramento, CA 94236-001, (916) 653-5951.

i. *FERC Contact:* Robert Fletcher, robert.fletcher@ferc.fed.us, (202) 219-1206.

j. *Deadline for filing comments, motions to intervene and protests:* 30 days from the issuance date of this notice. Please include the project number (2426-144) on any comments or motions filed. All documents (original and eight copies) should be filed with: David P. Boergers, Secretary, Federal Energy Regulatory Commission, 888 First St. NE, Washington, DC 20426.

k. *Description of Application:* The original Exhibit S annual trout stocking requirements for Silverwood, Pyramid, and Castaic Lakes were 300,000; 200,000; and 250,000 trout, respectively. In cooperation with the California Department of Fish and Game, it was determined that these stocking rates were unattainable. As a result, the licensee proposes to amend the above annual stocking rates to 20,000 pounds of catchable trout at Silverwood Lake, 20,000 pounds of catchable trout at Pyramid Lake, and 4,000 pounds of catchable trout at Piru Creek.

l. *Location of the application:* A copy of the application is available for

inspection and reproduction at the Commission's Public Reference Room, located at 888 First Street, NE, Room 2A, Washington, DC 20426 or by calling (202) 208-1371. This filing may be viewed on <http://www.ferc.fed.us/online/rims.htm> (call (202) 208-2222 for assistance). A copy is also available for inspection and reproduction at the address listed in item h above.

m. Individual desiring to be included on the Commission's mailing list should so indicate by writing to the Secretary of the Commission.

Protests or Motions to Intervene—Anyone may submit a protest or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210, 385.211, and 385.214. In determining the appropriate action to take, the Commission will consider all protests filed, but only those who file a motion to intervene in accordance with the Commission's Rules may become a party to the proceeding. Any protests or motions to intervene must be received on or before the specified deadline date for the particular application.

Filing and Service of Responsive Documents—Any filings must bear in all capital letters the title "COMMENTS", "RECOMMENDATIONS FOR TERMS AND CONDITIONS", "PROTEST", OR "MOTION TO INTERVENE", as applicable, and the Project Number of the particular application to which the filing refers. Any of the above-named documents must be filed by providing the original and the number of copies provided by the Commission's regulations to: The Secretary, Federal Energy Regulatory Commission, 888 First Street, NE, Washington, DC 20426. A copy of any motion to intervene must also be served upon each representative of the Applicant specified in the particular application.

Agency Comments—Federal, state, and local agencies are invited to file comments on the described application. A copy of the application may be obtained by agencies directly from the Applicant. If an agency does not file comments within the time specified for filing comments, it will be presumed to have no comments. One copy of an agency's comments must also be sent to the Applicant's representatives.

Linwood A. Watson, Jr.,

Acting Secretary.

[FR Doc. 99-16722 Filed 6-30-99; 8:45 am]

BILLING CODE 6717-01-M

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Notice of PP&L, Inc. Request To Use Alternative Procedures in Preparing a License Application

June 25, 1999.

Take notice that the following request to use alternative procedures to prepare a license application has been filed with the Commission:

a. *Type of Application:* Request to use alternative procedures to prepare a license application.

b. *Project No.:* 487.

c. *Date filed:* May 4, 1999.

d. *Applicant:* PP&L, Inc.

e. *Name of Project:* Wallenpaupack.

f. *Location:* On the Wallenpaupack Creek and Lackawaxen River, near the Borough of Hawley and the City of Seranton, in Wayne and Pike Counties, Pennsylvania. The project would not utilize federal lands.

g. *Filed Pursuant to:* Federal Power Act, 16 USC §§ 791(a)-825(r).

h. *Applicant Contact:* Gary Petrewski, PP&L, Inc., Two North Ninth Street (GENN5), Allentown, PA 18101-1179, 610-774-4759.

i. *FERC Contact:* Any questions on this notice should be addressed to Patrick Murphy, E-mail address, patrick.murphy@ferc.fed.us, or telephone 202-219-2659.

j. *Deadline for comments:* 30 days from the date of this notice.

All documents (original and eight copies) should be filed with: David P. Boergers, Secretary, Federal Energy Regulatory Commission, 888 First Street, NE, Washington, DC 20426.

The Commission's Rules of Practice and Procedure require all intervenors filing documents with the Commission to serve a copy of that document on each person whose name appears on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. *Description of the Project:* The project consists of an 870-foot-long, 67-foot-high concrete dam with a center spillway equipped with two 67.5-foot-long by 14-foot-high steel roller gates; a 13-mile-long, 5,700-acre reservoir at a full pool elevation of 1,190 feet msl; an 18,000-foot-long 14-foot-diameter pipeline connecting the dam with the powerhouse; a powerhouse containing two generating units with a total