

Corrections

Federal Register

Vol. 65, No. 206

Tuesday, October 24, 2000

This section of the FEDERAL REGISTER contains editorial corrections of previously published Presidential, Rule, Proposed Rule, and Notice documents. These corrections are prepared by the Office of the Federal Register. Agency prepared corrections are issued as signed documents and appear in the appropriate document categories elsewhere in the issue.

Wednesday, August 9, 2000, make the following correction:

§431.271 [Corrected]

On page 48837 and 48838, in §431.271, Tables 1 and 2 should read as follows:

DEPARTMENT OF ENERGY

Office of Energy Efficiency and Renewable Energy

10 CFR Part 431

[Docket No. EE-RM/TP-99-460]

RIN 1904-AA97

Energy Efficiency Program for Certain Commercial and Industrial Equipment: Test Procedures and Efficiency Standards for Commercial Air Conditioners and Heat Pumps

Correction

In proposed rule document 00-19723 beginning on page 48828 in the issue of

TABLE 1.—MINIMUM COOLING EFFICIENCY LEVELS

Product	Category	Cooling capacity	Subcategory	Efficiency Level ¹
Small Commercial Packaged Air Conditioning and Heating Equipment.	Air Cooled, 3 Phase ..	<65,000 Btu/h	Split System	SEER = 10.0
			Single Package	SEER = 9.7
	Air Cooled	≥65,000 Btu/h and <135,000 Btu/h.	All	EER = 8.9
Large Commercial Packaged Air Conditioning and Heating Equipment.	Water Cooled Evaporatively Cooled, and Water-Source.	<65,000 Btu/h	All	EER = 9.3
		≥65,000 Btu/h and <135,000 Btu/h.	All	EER = 10.5
Large Commercial Packaged Air Conditioning and Heating Equipment.	Air Cooled	≥135,000 Btu/h and <240,000 Btu/h.	All	EER = 8.5
	Water-Cooled, and Evaporatively Cooled.	≥135,000 Btu/h and <240,000 Btu/h.	All	EER = 9.6
Packaged Terminal Air Conditioners and Heat Pumps.	All	<7,000 Btu/h	All	EER = 8.88
		≥7,000 Btu/h and ≤15,000 Btu/h.		EER = 10.0 – (0.16 × capacity [in thousands of Btu/h at 95° outdoor dry-bulb temperature])
		>15,000 Btu/h		EER = 7.6

¹ All EER values must be rated at 95°F outdoor dry-bulb temperature for air-cooled products and evaporatively-cooled products and at 85°F entering water temperature for water-source and water-cooled products.

TABLE 2.—MINIMUM HEATING EFFICIENCY LEVELS

Product	Category	Cooling capacity	Subcategory	Efficiency Level ²
Small Commercial Packaged Air Conditioning and Heating Equipment.	Air Cooled, 3 Phase ..	<65,000 Btu/h	Split System Single Package	HSPF = 6.8 HSPF = 6.6
	Water-Source	<135,000 Btu/h	Split System and Single Package.	COP = 3.8
	Air Cooled	≥65,000 Btu/h and <135,000 Btu/h.	All	COP = 3.0
Large Commercial Packaged Air Conditioning and Heating Equipment.	Air Cooled	≥135,000 Btu/h and <240,000 Btu/h.	Split System and Single Package.	COP = 2.9
	Packaged Terminal Heat Pumps.	All	All	COP = 1.3+(0.16 × the applicable minimum cooling EER prescribed in Table 1—Minimum Cooling Efficiency Levels)

² All COP values must be rated at 47°F outdoor dry-bulb temperature for air-cooled products and evaporatively-cooled products and at 70°F entering water temperature for water-source products.

[FR Doc. C0-19723 Filed 10-23-00; 8:45 am]
BILLING CODE 1505-01-D

ENVIRONMENTAL PROTECTION AGENCY

40 CFR Part 52

[NC-087-9939; FRL-6881-1]

Approval and Promulgation of State Plans—North Carolina: Approval of Revisions to the North Carolina State Implementation Plan; Technical Correction

Correction

In rule document 00-25599 beginning on page 60101 in the issue of Tuesday, October 10, 2000, make the following corrections:

§52.1770 [Corrected]

1. On page 60102, in §52.1770 (c), in the table, in the section “Subchapter 2D—Air Pollution Control Requirements”, in the first line, the column for “State effective date” should read “1/15/98” and the column for “EPA approval date” should read “11/10/99”.

2. On page 60103, in the same section of the table, in the last line, in the column for “State effective date”, “Annual Emissions Reporting” should read “1/15/98”. The column for “EPA approval date” should read “11/10/99” and the column for “Comments” should read “*”.

[FR Doc. C0-25599 Filed 10-23-00; 8:45 am]

BILLING CODE 1505-01-D

DEPARTMENT OF THE INTERIOR

Bureau of Land Management

[NM-930-1430-ET; NMNM 52408, NMNM 52409, NMNM 52410]

Public Land Order No. 7462; Revocation of Three Secretarial Orders Dated May 1, 1929, April 27, 1939, and May 24, 1939; New Mexico

Correction

In notice document 00-25579 beginning on page 59463, in the issue of Thursday, October 5, 2000, make the following correction:

On page 59463, in the third column, in the seventh line from the bottom, “Sec. 3, SE ¼ NW ½” should read “Sec. 3, SE ¼ NW ¼”.

[FR Doc. C0-25579 Filed 10-23-00; 8:45 am]

BILLING CODE 1505-01-D