

Signed at Washington, DC, this 19th day of December, 2001.

Jesús Salinas,

Acting Chief, Division of Management Systems, Bureau of Labor Statistics.

[FR Doc. 02-668 Filed 1-10-02; 8:45 am]

BILLING CODE 4510-24-P

NATIONAL SCIENCE FOUNDATION

Alan T. Waterman Award Committee; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463, as amended), the National Science Foundation announces the following meeting:

Name: Alan T. Waterman Award Committee (1172).

Date/Time: Wednesday, March 6, 2000, 9 a.m.-3 p.m., room 340.

Place: National Science Foundation, 4201 Wilson Blvd., Arlington, VA.

Type of Meeting: Closed.

Contact Person: Mrs. Susan E.

Fannoney, Executive Secretary, Room 1220, National Science Foundation, 4201 Wilson Blvd, Arlington, VA 22230. Telephone: 703/292-8096.

Purpose of Meeting: To provide advice and recommendations in the selection of the Alan T. Waterman Award recipient.

Agenda: To review and evaluate nominations as part of the selection process for awards.

Reasons for Closing: The nominations being reviewed include information of a personal nature where disclosure would constitute unwarranted invasions of personal privacy. These matters are exempt under (4) and (6) of 5 U.S.C. 552b(c) of the Government in the Sunshine Act.

Dated: January 8, 2002.

Susanne Bolton,

Committee Management Officer.

[FR Doc. 02-758 Filed 1-10-02; 8:45 am]

BILLING CODE 7555-01-M

NATIONAL SCIENCE FOUNDATION

Special Emphasis Panel in Research, Evaluation and Communication; Notice of Meeting

In accordance with the Federal Advisory Committee Act (Pub. L. 92-463), as amended, the National Science Foundation announces the following meeting:

Name: Special Emphasis Panel on Research, Evaluation and Communication (1210).

Dates/Time: January 29, 2002 (8:00 a.m.-5:00 p.m.), January 30, 2002 (8:00 a.m. to 5:00 p.m.).

Place: National Science Foundation, 4201 Wilson Boulevard, Arlington, VA.

Type of Meeting: Open.

Contact Person: Kenneth Whang, Program Director, Division of Research, Evaluation and Communication (REC), Room 855, National Science Foundation, 4201 Wilson Boulevard, Arlington, VA 22230, Telephone: 703/292-8650.

Purpose of Meeting: To discuss trends and implications of brain research and education.

Agenda (Tentative):

January 29, 2002

2:15 pm

Overview and welcome

Introductions

2:30 pm

The ROLE portfolio: brain and cognitive components

3:00 pm

Discussion

3:30 pm

The ROLE program: guidelines, review, and management

4:00 pm

Discussion

4:30 pm

The ROLE community: outreach and development

5:00 pm

Discussion

5:30 pm

Break

6:00 pm

Dinner

January 30, 2002

8:30 pm

Synthesis and outstanding issues

Discussion a

10:00 am

Complete panel write-ups of recommendations

12:00 pm

Adjourn

Dated: January 8, 2002.

Susanne Bolton,

Committee Management Officer.

[FR Doc. 02-774 Filed 1-10-02; 8:45 am]

BILLING CODE 7555-01-M

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-254 and 50-265]

Exelon Generation Company, LLC and MidAmerican Energy Company; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DAR-29 and DAR-30 issued to Exelon Generation Company, LLC, and MidAmerican Energy Company (the licensee) for operation of the Quad

Cities Nuclear Power Station, Units 1 and 2, located in Rock Island County, Illinois.

The proposed amendment would revise technical specification section 3.3.1.1, "Reactor Protection System Instrumentation," to modify the description for Reactor Protection System (RPS) Function 7.a, "Scram Discharge Volume Water Level—High." This change supports a planned upgrade to the scram discharge volume level instrumentation from Fluid Components International thermal switches to Magnetrol float switches. These float switches are more reliable than the existing thermal switches, which are highly sensitive to a steam environment, since they respond to actual water level increases within the scram discharge volume. These types of Magnetrol float switches are used successfully in various applications at Quad Cities.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in Title 10 of the Code of Federal Regulations (10 CFR), Section 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

Does the Proposed Change Involve a Significant Increase in the Probability or Consequences of an Accident Previously Evaluated?

During the upcoming refueling outages at Quad Cities Nuclear Power Station (QCNPS), a design change will be implemented that upgrades the existing Scram Discharge Water Level—High instrumentation from thermal switches to float switches. Float switches are a proven technology that provide a more reliable measurement than existing equipment. Float switches are used in various applications at QCNPS, including the Emergency Core Cooling Systems instrumentation for Suppression Pool Water Level High function.

TS requirements that govern operability or routine testing of plant instruments are not