

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated July 9, 2002.

*No significant hazards consideration comments received:* No.

*Entergy Gulf States, Inc., and Entergy Operations, Inc., Docket No. 50-458, River Bend Station, Unit 1, West Feliciana Parish, Louisiana*

*Date of amendment request:* February 6, 2002, as supplemented by letter dated June 7, 2002.

*Brief description of amendment:* The amendment relocates the requirements for Main Steam Isolation Valve isolations on certain area temperatures from Technical Specification Section 3.3.6.1, "Primary Containment and Drywell Isolation Instrumentation," to the Technical Requirements Manual.

*Date of issuance:* July 11, 2002.

*Effective date:* As of the date of issuance and shall be implemented 60 days from the date of issuance.

*Amendment No.:* 124.

*Facility Operating License No. NPF-47:* The amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* March 19, 2002 (67 FR 12601). The June 7, 2002, supplemental letter provided clarifying information that did not change the scope of the original **Federal Register** notice or the original no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 11, 2002.

*No significant hazards consideration comments received:* No.

*Entergy Nuclear Operations, Inc., Docket No. 50-333, James A. FitzPatrick Nuclear Power Plant, Oswego County, New York*

*Date of application for amendment:* March 31, 1999, as supplemented by letters dated June 1, July 14, and October 14, 1999, February 11, April 4 and 13, June 30, July 31, September 12 and 13, and October 23, 2000, May 31, October 18, 2001, and February 6, March 27, April 26, and June 11 and 12, 2002 (two letters).

*Brief description of amendment:* The amendment provides for the full conversion of the Current Technical Specifications to the Improved Technical Specifications.

*Date of issuance:* July 3, 2002.

*Effective date:* As of the date of issuance to be implemented within 120 days.

*Amendment No.:* 274.

*Facility Operating License No. DPR-59:* Amendment revised the Technical Specifications.

*Date of initial notice in Federal Register:* November 8, 1999, (64 FR 60584), December 13, 1999, (64 FR 69574) and November 28, 2001 (66 FR 59595). The letters subsequent to the November 28, 2001, **Federal Register** notice did not change the technical content of the **Federal Register** notices, and did not change the scope of the proposed action. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 3, 2002.

*No significant hazards consideration comments received:* No.

*Nuclear Management Company, LLC, Docket No. 50-305, Kewaunee Nuclear Power Plant (KNPP), Kewaunee County, Wisconsin*

*Date of application for amendment:* April 17, 2002.

*Brief description of amendment:* The amendment revises the KNPP Technical Specification (TS) 6.3, "Plant Staff Qualifications," to change the title of the Superintendent Plant Radiation Protection to the Radiation Protection Manager. In addition, the licensee informed the Nuclear Regulatory Commission staff of its intention to reformat TS 6.3 using MicroSoft Word format.

*Date of issuance:* June 28, 2002.

*Effective date:* As of the date of issuance and shall be implemented within 30 days.

*Amendment No.:* 161.

*Facility Operating License No. DPR-43:* Amendment revised the TSs.

*Date of initial notice in Federal Register:* May 28, 2002 (67 FR 36932). The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated June 28, 2002.

*No significant hazards consideration comments received:* No.

*Tennessee Valley Authority, Docket No. 50-390, Watts Bar Nuclear Plant, Unit 1, Rhea County, Tennessee*

*Date of application for amendment:* August 7, 2001, as supplemented December 14, 2001 and April 1, 2002.

*Brief description of amendment:* Revised the Technical Specifications (TSs) to add a new condition and associated actions to Limiting Condition for Operation 3.8.1, "AC Sources Operating," to allow one diesel generator to be out of service for 14 days.

*Date of issuance:* July 1, 2002.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment No.:* 39.

*Facility Operating License No. NPF-90:* Amendment revised the TSs.

*Date of initial notice in Federal Register:* September 19, 2001 (66 FR 48292). The supplemental letters provided clarifying information that was within the scope of the initial notice and did not change the initial proposed no significant hazards consideration determination. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated July 1, 2002.

*No significant hazards consideration comments received:* No.

Dated at Rockville, Maryland, this 12th of July, 2002.

For the Nuclear Regulatory Commission.

**John A. Zwolinski,**

*Director, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 02-18242 Filed 7-22-02; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

### Biweekly Notice; Correction

The July 9, 2002, **Federal Register** contained a "Biweekly Notice; Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing." This notice corrects the notice published on July 9, 2002, (67 FR 45560). The last paragraph on page 45560 reads as follows: "By July 25, 2002, the licensee may file a request for a hearing with \* \* \*". It should read, "By August 8, 2002, the licensee may file a request for a hearing with \* \* \*" to correct the hearing date to 30 days.

Dated at Rockville, Maryland, this 17th day of July 2002.

For the Nuclear Regulatory Commission.

**John A. Zwolinski,**

*Director, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 02-18522 Filed 7-22-02; 8:45 am]

**BILLING CODE 7590-01-P**

## SECURITIES AND EXCHANGE COMMISSION

### Submission for OMB Review; Comment Request

Upon Written Request, Copies Available From: Securities and Exchange Commission, Office of Filings and Information Services, 450 Fifth Street, NW., Washington, DC 20549.

Extension:

Rule 17f-5, SEC File No. 270-259,