

Environmental Quality, regarding the environmental impact of the proposed action. On August 15, 2002, the staff consulted with the Vermont State official, William Sherman of the Department of Public Service, regarding the environmental impact of the proposed action. The State officials had no comments.

#### Finding of No Significant Impact

On the basis of the environmental assessment, the NRC concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the NRC has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated July 20, 2001, as supplemented by letter dated June 13, 2002. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209 or 301-415-4737, or by e-mail to [pdrr@nrc.gov](mailto:pdrr@nrc.gov).

Dated at Rockville, Maryland, this 28th day of August, 2002.

For the Nuclear Regulatory Commission.

#### Robert A. Gramm,

Chief, Section 1, Project Directorate IV, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.

[FR Doc. 02-22491 Filed 9-3-02; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

### Sunshine Act Meeting Notice

**AGENCY HOLDING THE MEETING:** Nuclear Regulatory Commission.

**DATE:** Weeks of September 2, 9, 16, 23, 30, October 7, 2002.

**PLACE:** Commissioners' Conference Room, 11555 Rockville Pike, Rockville, Maryland.

**STATUS:** Public and Closed.

**MATTERS TO BE CONSIDERED:**

#### Week of September 2, 2002

Wednesday, September 4, 2002

10:25 a.m.

Affirmation Session (Public Meeting) (Tentative)

- a. Final Rule: 10 CFR part 63: Specification of a Probability for Unlikely Features, Events, and Processes
- b. Duke Cogema Stone & Webster (Savannah River Mixed Oxide Fuel Fabrication Facility); Board's Certified Question Regarding Procedure

#### Week of September 9, 2002—Tentative

There are no meetings scheduled for the Week of September 9, 2002.

#### Week of September 16, 2002—Tentative

There are no meetings scheduled for the Week of September 16, 2002.

#### Week of September 23, 2002—Tentative

There are no meetings scheduled for the Week of September 23, 2002.

#### Week of September 30, 2002—Tentative

Tuesday, October 1, 2002

9:25 a.m.

Affirmation Session (Public Meeting) (If needed)

9:30 a.m.

Briefing on Decommissioning Activities and Status (Public Meeting) (Contact: John Buckley, 301-415-6607)

This meeting will be webcast live at the Web address—<http://www.nrc.gov>.

Wednesday, October 2, 2002

10:00 a.m.

Briefing on Strategic Workforce Planning and Human Capital Initiatives (Closed—Ex. 2)

#### Week of October 7, 2002—Tentative

There are no meetings scheduled for the Week of October 7, 2002.

\* The schedule for Commission meetings is subject to change on short notice. To verify the status of meetings call (recording)—(301) 415-1292. Contact person for more information: R. Michelle Schroll (301) 415-1662.

The NRC Commission Meeting Schedule can be found on the internet at: <http://www.nrc.gov/what-we-do/policy-making/schedule.html>.

This notice is distributed by mail to several hundred subscribers; if you no longer wish to receive it, or would like to be added to the distribution, please contact the Office of the Secretary, Washington, DC 20555 (301-415-1969). In addition, distribution of this meeting notice over the Internet system is available. If you are interested in receiving this Commission meeting schedule electronically, please send an electronic message to [dkw@nrc.gov](mailto:dkw@nrc.gov).

Dated: August 29, 2002.

#### R. Michelle Schroll,

Acting Technical Coordinator, Office of the Secretary.

[FR Doc. 02-22594 Filed 8-30-02; 11:32 am]

BILLING CODE 7590-01-M

## NUCLEAR REGULATORY COMMISSION

[Docket No. 50-423]

### Dominion Nuclear Connecticut, Inc.; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-49 issued to Dominion Nuclear Connecticut, Inc. (the licensee) for operation of the Millstone Power Station, Unit No. 3 (MP3), located in New London County, Connecticut.

The proposed amendment would revise Technical Specification (TS) Surveillance Requirement (SR) 4.0.3 to extend the delay period, before entering a Limiting Condition for Operation, following a missed surveillance. The delay period would be extended from the current limit of “. . . up to 24 hours” to “. . . up to 24 hours or up to the limit of the specified surveillance interval, whichever is greater.” In addition, the following requirement would be added to SR 4.0.3: “A risk evaluation shall be performed for any surveillance delayed greater than 24 hours and the risk impact shall be managed.”

The NRC staff issued a notice of opportunity for comment in the **Federal Register** on June 14, 2001 (66 FR 32400), on possible amendments concerning missed surveillances, including a model safety evaluation and model no significant hazards consideration (NSHC) determination, using the consolidated line item improvement process (CLIIP). The NRC staff subsequently issued a notice of availability of the models for referencing in license amendment applications in the **Federal Register** on September 28, 2001 (66 FR 49714). The licensee affirmed the applicability of the model NSHC determination for amendments concerning missed surveillances in its application dated July 19, 2002.

The proposed amendment would also make administrative changes to SRs 4.0.1 and 4.0.3 to be consistent with NUREG-1431, Revision 2, “Westinghouse Standard Technical Specifications.” These changes are necessary to make the current MP3 TSs compatible with the proposed CLIIP changes for missed surveillances. The licensee provided its analysis of the issue of NSHC for these proposed changes in its application.