

Dated: September 30, 2002.

Michael J. Kurtz,

*Assistant Archivist for Record Services—
Washington, DC.*

[FR Doc. 02-25242 Filed 10-3-02; 8:45 am]

BILLING CODE 7515-01-P

NATIONAL ARCHIVES AND RECORDS ADMINISTRATION

Information Quality Guidelines

AGENCY: National Archives and Records Administration (NARA).

ACTION: Notice of availability of final information quality guidelines.

SUMMARY: NARA is giving notice of availability of its Information Quality Guidelines (guidelines). The guidelines contain NARA's standards of quality, utility, objectivity, and integrity for information that is disseminated to the public, and the administrative procedures for preparing, reviewing, and correcting information products. The guidelines also describe the mechanisms for the public to request correction of information, and to request reconsideration of a NARA decision to deny a request for correction.

The guidelines are available electronically at http://www.archives.gov/about_us/information_quality/guidelines.html. For a paper copy of the guidelines, contact the person listed in **FOR FURTHER INFORMATION CONTACT**.

EFFECTIVE DATE: The guidelines were effective October 1, 2002.

FOR FURTHER INFORMATION CONTACT: Lisa Weber at 301-837-3112.

Dated: October 1, 2002.

Nancy Allard,

Federal Register Liaison.

[FR Doc. 02-25393 Filed 10-3-02; 8:45 am]

BILLING CODE 7515-01-P

NATIONAL COUNCIL ON DISABILITY

International Watch Advisory Committee Meeting (Conference Call)

AGENCY: National Council on Disability (NCD).

DATES: 12 noon, EST, November 21, 2002.

ADDRESSES: National Council on Disability, 1331 F Street, NW., Suite 850, Washington, DC.

Status: All parts of this meeting will be open to the public. Those interested in participating in the conference call should contact the appropriate staff member listed below. Due to limited resources, only a few telephone lines will be available for the conference call.

Agenda: Roll call, announcements, overview of accomplishments, planning for FY 2003, reports, new business, adjournment.

FOR FURTHER INFORMATION CONTACT: Joan Durocher, Attorney Advisor and Designated Federal Official, National Council on Disability, 1331 F Street NW, Suite 850, Washington, DC 20004; 202-272-2004 (voice), 202-272-2074 (TTY), 202-272-2022 (fax), jdurocher@ncd.gov (e-mail).

International Watch Advisory Committee Mission: The purpose of NCD's International Watch is to share information on international disability issues and to advise NCD on developing policy proposals that will advocate for a foreign policy that is consistent with the values and goals of the Americans with Disabilities Act.

Dated: October 1, 2002.

Ethel D. Briggs,

Executive Director.

[FR Doc. 02-25253 Filed 10-3-02; 8:45 am]

BILLING CODE 6820-MA-P

NUCLEAR REGULATORY COMMISSION

[Docket Nos. 50-254 and 50-265]

Exelon Generation Company, LLC; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License Nos. DPR-29 and DPR-30 issued to Exelon Generation Company, LLC (Exelon, the licensee), for operation of the Quad Cities Nuclear Power Station, Units 1 and 2, located in Rock Island County, IL.

The proposed amendment would revise the Updated Safety Analysis Report (UFSAR) to allow lifting heavier loads with the reactor building crane during the Unit 1 refueling outage beginning in November 2002.

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in Title 10 of the Code of Federal Regulations (10

CFR), Section 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. The proposed changes do not involve a significant increase in the probability or consequences of an accident previously evaluated.

The proposed changes will allow use of the reactor building crane at Quad Cities Nuclear Power Station (QCNPS) during power operations to lift heavy loads up to 125 tons for removal and re-installation activities for the reactor cavity shield blocks during the Unit 1 refueling outage (*i.e.*, Q1R17). The reactor building crane has additional margin for a total lifted load of 125 tons with single failure-proof features if a Design Basis Earthquake (DBE) is not assumed. Exelon has qualitatively demonstrated that the probability of a DBE occurring during the limited duration (estimated to be 24 hours) of the request is very small. The probability of load drop accidents previously evaluated is not increased since the capacity of the reactor building crane equals or exceeds the weight of the reactor cavity shield blocks.

Therefore, the proposed changes do not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. The proposed changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.

The proposed changes allow use of the QCNPS reactor building crane for a limited duration to lift heavy loads up to a total of 125 tons during removal and reinstallation activities for the reactor cavity shield blocks. The reactor building crane has additional margin for a lifted load of 125 tons with single failure-proof features if a DBE is not assumed. The probability of a DBE during the limited duration of the request is very small. Therefore, the single failure-proof features ensure that the proposed changes provide an equivalent level of safety and will not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. The proposed changes do not involve a significant reduction in a margin of safety.

The reactor building crane is rated for lifting loads up to 125 tons. The NRC has approved qualification of the QCNPS reactor building crane as single failure-proof for loads of up to 110 tons. The proposed change allows use of the crane for a limited duration to lift loads up to 125 tons. Existing safety margins are enhanced when lifting loads up to 125 tons if a DBE is not assumed, and Exelon has demonstrated that the probability