

Date of issuance: November 10, 2003.
Effective date: November 10, 2003,
and shall be implemented within 60
days from the date of issuance.

Amendment No.: 223.

*Renewed Facility Operating License
No. DPR-40:* The amendment revised the
Technical Specifications.

*Date of initial notice in Federal
Register:* March 18, 2003 (68 FR
12955).

The October 14, 2003, supplemental
letter provided additional information
that clarified the application, did not
expand the scope of the application as
originally noticed, and did not change
the staff's original proposed no
significant hazards consideration
determination.

The Commission's related evaluation
of the amendment is contained in a
Safety Evaluation dated November 10,
2003.

No significant hazards consideration
comments received: No.

*PPL Susquehanna, LLC, Docket Nos.
50-387 and 50-388, Susquehanna
Steam Electric Station, Units 1 and 2,
Luzerne County, Pennsylvania.*

Date of application for amendments:
May 6, 2003, as supplemented by letters
dated August 12 and September 18,
2003.

Brief description of amendments:
These amendments deleted Technical
Specification (TS) 3.3.1.3, "Oscillation
Power Range Monitor (OPRM)
Instrumentation," and revised TS 3.4.1,
"Recirculation Loops Operating," to
formally extend the currently
implemented requirements, which
define appropriately conservative
restrictions to plant operation and
operator response to thermal hydraulic
instability events. In addition, the
amendments revise TS 3.4.1 to refer to
the power flow map in the core
operating limits report and include a
reference in TS 5.6.5.

Date of issuance: October 29, 2003.

Effective date: As of the date of
issuance and shall be implemented
within 30 days.

Amendment Nos.: 215 and 190.

*Facility Operating License Nos. NPF-
14 and NPF-22:* The amendments
revised the Technical Specifications.

*Date of initial notice in Federal
Register:* June 24, 2003 (68 FR 37582).

The supplemental letters dated
August 12 and September 18, 2003,
provided clarifying information that did
not change the scope of the amendment
as described in the initial notice of the
proposed action published in the
Federal Register notice (68 FR 37582,
June 24, 2003), or the U.S. Nuclear
Regulatory Commission staff's proposed

no significant hazards consideration
determination.

The Commission's related evaluation
of the amendments is contained in a
Safety Evaluation dated October 29,
2003.

No significant hazards consideration
comments received: No.

*Tennessee Valley Authority, Docket
Nos. 50-259, 50-260, and 50-296,
Browns Ferry Nuclear Plant, Units 1, 2,
and 3, Limestone County, Alabama.*

Date of application for amendments:
July 25, 2003.

Description of amendment request:
The amendments revised Technical
Specification 3.1.8, "Scram Discharge
Volume (SDV) Vent and Drain Valves,"
to allow a vent or drain line with one
inoperable valve to be isolated instead
of requiring the valve to be restored to
operable status within 7 days.

Date of issuance: November 3, 2003.

Effective date: Date of issuance, to be
implemented within 60 days.

Amendment Nos.: 248, 285, and 243.

*Facility Operating License Nos. DPR-
33, DPR-52, and DPR-68.* Amendments
revised the Technical Specifications.

*Date of initial notice in Federal
Register:* September 18, 2003 (68 FR
54753).

The Commission's related evaluation
of the amendment is contained in a
Safety Evaluation.

No significant hazards consideration
comments received: No.

Dated at Rockville, Maryland, this 17th day
of November, 2003.

For the Nuclear Regulatory Commission.

Eric Leeds,

*Deputy Director, Division of Licensing Project
Management, Office of Nuclear Reactor
Regulation.*

[FR Doc. 03-29107 Filed 11-24-03; 8:45 am]

BILLING CODE 7590-01-P

OFFICE OF PERSONNEL MANAGEMENT

Federal Employees' Group Life Insurance Program: New Option B Premiums

AGENCY: Office of Personnel
Management.

ACTION: Notice.

SUMMARY: The Office of Personnel
Management (OPM) is announcing new
Federal Employees' Group Life
Insurance (FEGLI) premiums for the
upper age bands of Option B. The
premiums will be maintained on the
FEGLI Web site at <http://www.opm.gov/insure/life>.

EFFECTIVE DATE: January 1, 2004.

FOR FURTHER INFORMATION CONTACT:
Karen Leibach, (202) 606-0004.

SUPPLEMENTARY INFORMATION: On
December 30, 2002, OPM published a
Federal Register notice (67 FR 79659)
announcing premium changes for FEGLI
and new age bands for Options B and C.
The premiums for the new Option B age
bands are being phased in over a 3-year
period. The first set of premiums for
these age bands was effective the first
pay period beginning on or after January
1, 2003.

This notice announces the second
phase of the Option B premium
changes. These premiums are effective
the first pay period beginning on or after
January 1, 2004.

OPTION B PREMIUM PER \$1,000 OF INSURANCE

Age band	Biweekly	Monthly
70-74	\$1.03	\$2.232
75-79	1.43	3.098
80 and over	1.83	3.965

The premiums for compensationers,
who are paid every 4 weeks, are 2 times
the biweekly premium amounts.

Premiums for other FEGLI coverages,
including premiums for other Option B
age bands, are not changing.

U.S. Office of Personnel Management.

Kay Coles James,
Director.

[FR Doc. 03-29438 Filed 11-24-03; 8:45 am]

BILLING CODE 6325-50-P

SECURITIES AND EXCHANGE COMMISSION

[Release No. 34-48800; File No. SR-Amex-
2002-116]

Self-Regulatory Organizations; Notice of Filing of a Proposed Rule Change and Amendment Nos. 1, 2, 3, and 4 Thereby by the American Stock Exchange LLC Relating to Specialist Stabilization Requirements for Derivative Products

November 17, 2003.

Pursuant to Section 19(b)(1) of the
Securities Exchange Act of 1934
("Act")¹ and Rule 19b-4 thereunder,²
notice is hereby given that on December
27, 2002, the American Stock Exchange
LLC ("Amex" or "Exchange") filed with
the Securities and Exchange
Commission ("Commission") the
proposed rule change as described in

¹ 15 U.S.C. 78s(b)(1).

² 17 CFR 240.19b-4.