

# Corrections

Federal Register

Vol. 71, No. 122

Monday, June 26, 2006

This section of the FEDERAL REGISTER contains editorial corrections of previously published Presidential, Rule, Proposed Rule, and Notice documents. These corrections are prepared by the Office of the Federal Register. Agency prepared corrections are issued as signed documents and appear in the appropriate document categories elsewhere in the issue.

## ENVIRONMENTAL PROTECTION AGENCY

40 CFR Parts 60, 63, 85, 90, 1048, 1065, and 1068

[EPA-HQ-OAR-2005-0030, FRL-8176-1]

RIN 2060-AM81 and 2060-AN62

### Standards of Performance for Stationary Spark Ignition Internal Combustion Engines and National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines

#### Correction

In proposed rule document 06-4919 beginning on page 33804 in the issue of

Monday, June 12, 2006, make the following corrections:

1. On page 33808, in Table 1, in the table heading, in the first line, ">19" should read "≤19".

2. On page 33809, in Table 3, in the second column, in the third entry, "HP≤500" should read "HP≥500".

3. On the same page, in the same table, in the same column, in the fifth entry, "HP≥500" should read "HP<500".

4. On pages 33810 and 33811, Table 4 is being reprinted in its entirety to read as follows:

TABLE 4.—EMISSION STANDARDS FOR STATIONARY RICE ≤500 HP LOCATED AT MAJOR SOURCES OF HAP EMISSIONS AND STATIONARY RICE LOCATED AT AREA SOURCES OF HAP EMISSIONS

Engine type and fuel	Maximum engine power	Manufacture date <sup>a</sup>	Emission standards
Existing All Fuels and All Types	All Sizes		No Emission Reduction.
New/Reconstructed SI	≤25 HP	January 1, 2008 ...	Meet 40 CFR part 60 subpart JJJJ.
New/Reconstructed SI Gasoline and Rich Burn LPG.	25<HP<500	January 1, 2008 ...	Meet 40 CFR part 60 subpart JJJJ.
New/Reconstructed Non-Emergency SI Natural Gas.	HP≥500	July 1, 2007	
	25<HP<500 <sup>a</sup>	January 1, 2008 ...	1.0 g/HP-hr NMHC.
and			
New/Reconstructed Non-Emergency SI Lean Burn LPG <sup>b</sup> .		January 1, 2011 ...	0.7 g/HP-hr NMHC.
New/Reconstructed Non-Emergency SI Natural Gas.	HP≥500	July 1, 2007	1.0 g/HP-hr NMHC
and			
New/Reconstructed Non-Emergency SI Lean Burn LPG.		July 1, 2010	0.7 g/HP-hr NMHC.
New/Reconstructed Non-Emergency SI 4SLB at Major Sources (except landfill and digester gas) <sup>b</sup> .	250<HP ≤500	January 1, 2008 ...	93% CO Reduction or 14 ppmvd formaldehyde.
CI All Fuels	All Sizes	2007+ Model Year	Meet 40 CFR part 60 subpart IIII.
Landfill/Digester Gas	HP<500	January 1, 2008 ...	1.0 g/HP-hr NMHC.
	HP≥500	July 1, 2007	1.0 g/HP-hr NMHC.
Emergency SI	All Sizes	January 1, 2009 ...	1.0 g/HP-hr NMHC.

<sup>a</sup> Stationary SI natural gas and lean burn LPG engines between 19 and 37 KW (25 and 50 HP) may comply with the requirements of Table 2 of this preamble, instead of this table, as applicable.

<sup>b</sup> New and reconstructed non-emergency 4SLB engines at major sources with a site rating between 250 and 500 HP are not required to meet the 1.0 and 0.7 g/HP-hr NMHC emission standards.

**Table 3 to Subpart ZZZZ of Part 63  
[Corrected]**

5. On page 33844, in Table 3 to Subpart ZZZZ of Part 63, in the table

heading, in the second line, ">500 HP" should read "≤500 HP".

6. On page 33845, in the same table, in the table heading, in the second line, ">500 HP" should read "≤500 HP".

[FR Doc. C6-4919 Filed 6-23-06; 8:45 am]

**BILLING CODE 1505-01-D**