

doc-comment/omb/index.html. The document will be available on the NRC home page site for 60 days after the signature date of this notice.

Comments and questions should be directed to the OMB reviewer listed below by October 2, 2006. Comments received after this date will be considered if it is practical to do so, but assurance of consideration cannot be given to comments received after this date. John A. Asalone, Office of Information and Regulatory Affairs (3150-0090), NEOB-10202, Office of Management and Budget, Washington, DC 20503.

Comments can also be e-mailed to John_A._Asalone@omb.eop.gov or submitted by telephone at (202) 395-4650.

The NRC Clearance Officer is Brenda Jo. Shelton, 301-415-7233.

Dated at Rockville, Maryland, this 25th day of August, 2006.

For the Nuclear Regulatory Commission.

Beth C. St. Mary,

Acting NRC Clearance Officer, Office of Information Services.

[FR Doc. E6-14515 Filed 8-31-06; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

The Ohio State University Notice of Acceptance for Docketing of the Application and Notice of Opportunity for Hearing Regarding Renewal of The Ohio State University Research Reactor Facility License No. R-75 for an Additional 20-year Period; Extension of Comment Period

AGENCY: United States Nuclear Regulatory Commission.

ACTION: Extension of comment period.

SUMMARY: On August 2, 2006 (71 FR 43818), the U.S. Nuclear Regulatory Commission (NRC) published for public comment a Notice of Acceptance for Docketing of the Application and Notice of Opportunity for Hearing Regarding Renewal of the Ohio State University Research Reactor. An additional 30 days has been added to this **Federal Register** Notice. The date for an applicant to file a request for hearing and a petition for leave to intervene has been extended to October 2, 2006.

DATES: The comment period has been extended and now expires on October 2, 2006.

ADDRESSES: Mail Written comments to: the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-

0001. *Attn:* Rulemaking and Adjudications Staff.

Hand delivered comments should also be addressed to: the Office of the Secretary, Sixteenth Floor, One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, *Attn:* Rulemaking and Adjudications Staff. This should be delivered between 7:30am and 4:15pm Federal Workdays.

Certain Documents relating to this renewal may be examined at the NRC Public Document Room, 11555 Rockville Pike, Room O1F21, Rockville, Maryland, 20852. For more information, contact the Public Document Room Reference Staff at 1-800-397-4209, or at 301-415-4737, or by e-mail at PDR@NRC.GOV.

FOR FURTHER INFORMATION CONTACT:

Daniel Hughes, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, telephone 301-415-1631, e-mail DEH3@NRC.GOV.

Dated at Rockville, Maryland, this 23rd day of August 2006.

For the Nuclear Regulatory Commission.

Brian E. Thomas,

Branch Chief, Research and Test Reactors Branch, Division of Policy and Rulemaking, Office of Nuclear Reactor Regulation.

[FR Doc. E6-14512 Filed 8-31-06; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-271]

Vermont Yankee Nuclear Power Station; Notice of Withdrawal of Application for Amendment to Facility Operating License

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Entergy Nuclear Operations, Inc. (the licensee) to withdraw its December 15, 2004, application for proposed amendment to Facility Operating License No. DPR-28 for the Vermont Yankee Nuclear Power Station, located in Windham County.

The proposed amendment would have revised the Technical Specifications pertaining to control rod operability, scram time and control rod accumulator technical specification surveillance testing requirements. The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the **Federal Register** on January 18, 2005 (70 FR 2889). However, by letter dated August 10, 2006, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for

amendment dated December 15, 2004, as supplemented on December 12, 2005, and July 6, 2006, and the licensee's letter dated August 10, 2006, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by e-mail to pdr@nrc.gov.

Dated at Rockville, Maryland, this 28th day of August 2006.

For the Nuclear Regulatory Commission.

James Shea,

Project Manager, Plant Licensing Branch I-1, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. E6-14525 Filed 8-31-06; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-482]

Wolf Creek Nuclear Operating Corporation; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. NPF-42, issued to Wolf Creek Nuclear Operating Corporation (the licensee), for operation of the Wolf Creek Generating Station, located in Coffey County, Kansas.

The proposed amendment would revise Technical Specification (TS) 3.7.2, "Main Steam Isolation Valves (MSIVs)," and TS 3.7.3, "Main Feedwater Isolation Valves (MFIVs)," to add the associated actuator trains to (1) the limiting condition for operation (LCO), (2) the conditions, required actions, and completion times for the LCO, and (3) the surveillance requirements. Each MSIV and MFIV has