

*South Carolina Electric & Gas Company, South Carolina Public Service Authority, Docket No. 50-395, Virgil C. Summer Nuclear Station, Unit No. 1, Fairfield County, South Carolina*

*Date of application for amendment:* November 15, 2005, as supplemented May 31, August 31, and September 29, 2006.

*Brief description of amendment:* The amendment revises the Virgil C. Summer Nuclear Station Technical Specifications (TS) 3/4.3 for the reactor trip instrumentation and the engineered safety feature actuation system instrumentation to implement the allowed outage time and bypass test time changes approved in WCAP-14333-P-A, Revision 1, "Probabilistic Risk Analysis of the RPS and ESFAS Test Times and Completion Times," and makes several additional changes to TS outside of the scope of WCAP-14333.

*Date of issuance:* October 24, 2006.

*Effective date:* As of the date of issuance and shall be implemented within 60 days.

*Amendment No. 177.*

*Renewed Facility Operating License No. NPF-12:* Amendment revises the Technical Specifications.

*Date of initial notice in Federal Register:* December 20, 2005 (70 FR 75496).

The supplemental letters provided clarifying information that was within the scope of the initial notice and did not change the initial proposed no significant hazards consideration. The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated October 24, 2006.

No significant hazards consideration comments received: No.

*Tennessee Valley Authority, Docket No. 50-259 Browns Ferry Nuclear Plant, Unit 1, Limestone County, Alabama*

*Date of application for amendment:* November 10, 2003 (TS-430), as supplemented by letter dated November 8, 2004.

*Brief description of amendment:* The amendment incorporates the necessary Technical Specification (TS) changes for the planned replacement of the power range monitoring portion of the existing Neutron Monitoring System with a digital upgrade. These changes expand the current allowable operating domain to the Maximum Extended Load Line Limit region of the power/flow chart.

*Date of issuance:* September 27, 2006.

*Effective date:* Date of issuance, to be implemented within 30 days.

*Amendment No.:* 262.

*Facility Operating License No. DPR-33:* Amendment revised the TSs.

*Date of initial notice in Federal Register:* February 3, 2004 (69 FR 5208). The November 8, 2004, supplement, contained clarifying information and did not change the NRC staff's initial proposed finding of no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated September 27, 2006.

No significant hazards consideration comments received: No.

*Tennessee Valley Authority, Docket Nos. 50-327 and 50-328, Sequoyah Nuclear Plant, Units 1 and 2, Hamilton County, Tennessee*

*Date of application for amendments:* February 6, 2006.

*Brief description of amendments:* The amendments modify Technical Specification (TS) requirements for inoperable snubbers by adding Limiting Condition for Operation 3.0.7. This operating license improvement was made available by the Nuclear Regulatory Commission (NRC) on May 4, 2005 (70 FR 23252) as part of the consolidated line item improvement process and is consistent with NRC approved Technical Specification Task Force (TSTF) standard TS change TSTF-372, Revision 4.

*Date of issuance:* October 4, 2006.

*Effective date:* As of the date of issuance and shall be implemented within 45 days.

*Amendment Nos. 312/301.*

*Facility Operating License Nos. DPR-77 and DPR-79:* Amendments revised the technical specifications.

*Date of initial notice in Federal Register:* March 28, 2006 (71 FR 15487).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated October 4, 2006.

No significant hazards consideration comments received: No.

Dated at Rockville, Maryland, this 30th day of October 2006.

For the Nuclear Regulatory Commission.

**Catherine Haney,**

*Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.*

[FR Doc. E6-18595 Filed 11-6-06; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

### Notice of Availability of Model License Amendment Request and Safety Evaluation on Technical Specification Improvement Regarding Revision to the Completion Time in STS 3.6.6A, "Containment Spray and Cooling Systems" for Combustion Engineering Pressurized Water Reactors Using the Consolidated Line Item Improvement Process

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Notice of availability.

**SUMMARY:** Notice is hereby given that the staff of the U.S. Nuclear Regulatory Commission (NRC) has prepared a model license amendment request (LAR), model safety evaluation (SE), and model proposed no significant hazards consideration (NSHC) determination related to changes to the completion times (CT) in Standard Technical Specification (STS) 3.6.6A, "Containment Spray and Cooling Systems," contained in NUREG-1432 (Standard Technical Specifications for Combustion Engineering Plants, Rev. 3.0). The proposed changes would revise STS 3.6.6A by extending the CT for one containment spray system (CSS) train inoperable from 72 hours to seven days, and add a Condition, Required Actions and associated CT when one CSS train and one containment cooling system (CCS) train are inoperable. These changes are based on analyses provided in a joint applications report submitted by the Combustion Engineering Owner's Group (CEOG). The CEOG participants in the Technical Specifications Task Force (TSTF) proposed these changes to the STS in Change Traveler No. TSTF-409, Revision 2.

The purpose of these models is to permit the NRC to efficiently process amendments to incorporate these changes into plant-specific STS for Combustion Engineering pressurized water reactors (PWRs). Since TSTF-409 involves a risk-informed approach to extending the CT for one CSS inoperable, the NRC staff must verify that licensees who apply for this TS change have a valid, up-to-date probabilistic risk assessment (PRA) model that employs PRA principles to ensure that public health and safety are maintained when the CSS CT of 7 days is implemented. Therefore, the model LAR contains several conditions requiring licensees to make specific validations of their plant PRA quality and methods. The intent of using the CLIP to adopt TSTF-409 is to eliminate

the need for additional technical review and requests for additional information (RAIs) on plant-specific amendments. Licensees of nuclear power reactors to which the models apply can request amendments conforming to the models. In such a request, a licensee should confirm the applicability of the model SE and NSHC determination to its plant, and provide the expected supplemental information requested in the model LAR.

**DATES:** The NRC staff issued a Federal Register Notice (71 FR 18380, April 11, 2006) which provided for public comment a model SE, model LAR, and NSHC determination related to changes to the CT for one CSS train inoperable in STS 3.6.6A. The NRC staff herein provides a revised model SE, revised model LAR, and NSHC determination. The NRC staff can most efficiently consider applications based upon the model LAR, which references the Model SE, if the application is submitted within one year of this **Federal Register** Notice.

**FOR FURTHER INFORMATION CONTACT:** Tim Kobetz, Mail Stop: O-12H2, Division of Inspection Program Management, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, telephone 301-415-1932.

#### **SUPPLEMENTARY INFORMATION:**

##### **Background**

Regulatory Issue Summary 2000-06, "Consolidated Line Item Improvement Process [CLIIP] for Adopting Standard Technical Specifications Changes for Power Reactors," was issued on March 20, 2000. The CLIIP is intended to improve the efficiency and transparency of NRC licensing processes. This is accomplished by processing proposed changes to the STS in a manner that supports subsequent license amendment applications. The CLIIP includes an opportunity for the public to comment on proposed changes to the STS following a preliminary assessment by the NRC staff and finding that the change will likely be offered for adoption by licensees. The CLIIP includes NRC staff evaluation of any comments received for a proposed change to the STS. In several instances, the staff's evaluation did result in changes to the model LAR and/or model SE. Those licensees opting to apply for the subject changes to TSs are responsible for reviewing the staff's evaluation, referencing the applicable technical justifications, and providing any necessary plant-specific information. The model LAR shows licensees the expected level of detail

that needs to be included in order to adopt TSTF-409, Rev. 2, as well as guidelines for staff review. The NRC has established an internal review plan that designates the appropriate staff and approximate timelines to review plant-specific LARs that reference TSTF-409, Rev. 2. Each amendment application made in response to the notice of availability will be processed and noticed in accordance with applicable NRC rules and procedures.

This notice involves an increase in the allowed CT to restore an inoperable CSS train on Combustion Engineering PWRs. By letter dated November 10, 2003, the CEOG proposed this change for incorporation into the STS as TSTF-409, Revision 2. This change is based on the NRC staff-approved analyses contained in CE NPSD-1045-A, "Joint Applications Report: Modification to the Containment Spray System, and Low Pressure Safety Injection System Technical Specifications," dated March 2000, as approved by the NRC in a SE dated December 21, 1999, accessible electronically from the Agencywide Documents Access and Management System's (ADAMS) Public Electronic Reading Room on the Internet (ADAMS Accession No. ML993620241) at the NRC Web site <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC Public Document Room Reference staff by telephone at 1-800-397-4209, 301-415-4737, or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

This notice, along with TSTF-409, Rev. 2, will be posted on the NRC Web site at <http://www.nrc.gov/reactors/operating/licensing/techspecs/changes-issued-for-adoption.html>.

##### **Applicability**

This proposed change to revise the Technical Specification (TS) CT for one inoperable CSS train is applicable to Combustion engineering PWRs.

To efficiently process the incoming license amendment applications, the NRC staff requests that each licensee applying for the changes addressed by TSTF-409, Revision 2, use the CLIIP to submit a LAR that adheres to the following model. Any deviations from the model LAR should be explained in the licensee's submittal. When applying, licensees should ensure they address the eight conditions and one regulatory commitment listed in the model LAR and model SE.

The CLIIP does not prevent licensees from requesting an alternative approach, proposing changes without providing the information described in the eight

model LAR conditions, or making the requested commitment. Variations from the approach recommended in this notice may, however, require additional review by the NRC staff and may increase the time and resources needed for the review. Significant variations from the approach, or inclusion of additional changes in the LAR, will result in staff rejection of the submittal under the CLIIP. Instead, licensees desiring significant variations and/or additional changes should either submit a LAR that does not claim to adopt TSTF-409, or specifically state in their LAR that they are adopting TSTF-409 without using the CLIIP.

##### **Public Notices**

In a notice in the **Federal Register** dated April 11, 2006 (71 FR 18380), the staff requested comment on the use of the CLIIP to process requests to revise the CE PWR TS regarding Containment Spray System completion time extensions as discussed in TSTF-409. In response to this notice, the staff received one set of comments (developed by the PWR Owners Group, and submitted by the Nuclear Energy Institute in a letter dated May 10, 2006 (ADAMS Accession No. ML061570029)). Specific comments on the model LAR and model SE were offered. These comments, along with the NRC staff's responses, are summarized and discussed below.

1. *Comment:* Based on discussions with the author regarding the intent of the "Model SE," [i.e., to allow acceptance review without RAIs while satisfying the CLIIP] it is recommended that additional explanatory information be included. \* \* \* At the very minimum, a clear preamble to the FRN should be provided that places the scope of the FRN in perspective.

*Response:* The following preamble has been inserted after the first sentence of the second paragraph of the FRN.

"Since TSTF-409 involves a risk-informed approach to extending the CT for one CSS inoperable, the NRC staff must verify that licensees who apply for this TS change have a valid, up to date probabilistic risk assessment (PRA) model that employs PRA principles to ensure that public health and safety are maintained when the CSS CT of 7 days is implemented. Therefore, the model LAR contains several conditions requiring licensees to make specific validations of their plant PRA quality and methods. The intent of using the CLIIP to adopt TSTF-409 is to eliminate the need for additional technical review and requests for additional information (RAIs) on plant-specific amendments."

2. *Comment:* [The FRN] should equally note that existing strategies for

approval are valid and may also be used.

*Response:* The second to last paragraph of the FRN discusses how a licensee should proceed if it desires to deviate from the approach outlined in the CLIIP. The NRC's position is that, if a licensee is going to submit a LAR that adopts TSTF-409 using the CLIIP, then the plant-specific LAR should provide all the information requested in the model LAR. Any variations/deviations should be explained, and may require additional review by the staff (including issuance of RAIs). Significant variations from the CLIIP methodology should be submitted as normal license amendment requests. The staff has changed the last sentence of second to last paragraph of the FRN to read:

"Instead, licensees desiring significant variations and/or additional changes should either submit a LAR that does not claim to adopt TSTF-409, or specifically state in their LAR that they are adopting TSTF-409 without using the CLIIP."

This will correctly define the scope of the review for the staff when processing an incoming LAR that does not conform to the CLIIP.

3. *Comment:* The essence of the proposed CSS TS change focuses on a single CSS train. Thus, the mention of ACTION G (regarding two CSS trains out-of-service) seems unnecessary.

*Response:* The staff agrees with this comment. Mention of ACTION G has been removed from Section 4.1 of the model LAR, and Section 3.1 of the model SE.

4. *Comment:* The last paragraph of section 4.2.1 item 1 notes that "If a zero maintenance PRA model is used \* \* \* in performing these calculations, then the licensee must commit to performing no other maintenance during the extended CSS CT \* \* \*". This restriction has no technical merit. The risk of maintenance is generated as incremental risks from the baseline. The initial submittal noted that for plants with emergency grade fan coolers (most of the applicants), the actual risk increases as a result of removing a CSS out of service is very low. Furthermore, CSS have very little (if any) overlap with other systems. Because the risk important function of CSSs is to maintain the containment pressure within acceptable limits (and control sump temperature to ensure adequate NPSH for ECCS equipment—a function left out of FRN Section 3), those functions can be accommodated by the redundant CS train or the fan coolers. Furthermore, by using RG 1.177 to support low risk, the risk impact of removal of the CSS for the duration of

the 7 day AOT is small. Because plants perform maintenance on a frequent basis, not allowing repair or maintenance on another system (which is likely to be of greater risk importance than the CSS) is unnecessary and likely to have worse risk.

Another unusual aspect of the restriction implies that the incremental risk calculated using zero maintenance conditions is significantly different from that calculated using annualized plant-wide system out-of-service values. While the baseline PRA for zero maintenance is less than the baseline PRA value for nominal maintenance, its impact on incremental risk will be small.

*Response:* The staff accepts NEI's comment in that it creates a regulatory condition that is overly restrictive to plants using a zero maintenance PRA model. The staff has inserted alternate wording (from RG 1.177 Section 2.3.4. #2) to the last sentence of condition 1 in Section 4.2.1 of the model LAR as follows:

If the licensee utilizes a "zero maintenance" PRA model for the assessment, they should state they are using a "zero maintenance" model in the evaluation, and provide a discussion as to the ability of that model to produce comparable results to the "average maintenance" assessment.

5. *Comment:* It is understood that documented quantitative external event information for the plants may be limited. However, reference to plant individual plant examination (IPE) and individual plant examination for external events (IPEEE) and the requirements to explain the evolution of the PRA since 1988 as identified in Section in item 4.2.1 part 2.b is unnecessary. Item 2.c requires that the peer review results be discussed along with the overall disposition of relevant facts and observations (F&Os) and item e (which includes an overall determination of the adequacy of the plant specific PRA with respect to this application). These assessment[s] are current and of more importance to the application. Where external events rely on IPEEE vintage information, a discussion/statement of the risk significance of the spray system in mitigating external events should be performed.

*Response:* The staff agrees that peer reviews of plant-specific PRA are important. However, it is equally important to have an understanding of PRA updates and upgrades since the IPE, IPEEE, and peer reviews were conducted, especially if plant improvements and/or commitments are cited and credited in the analyses as being implemented. Licensees who have

given this information in prior submittals may incorporate the information by reference.

6. *Comment:* Section 4.2.1 item 3 requirements on consideration of fire and external events and the associated EXPECTATIONS are too restrictive and do not correspond to safety benefits. The CSS has limited risk overlap with fires or external initiating events. Challenges to power induced by tornadoes, high winds or seismic events have limited importance to the spray system and [are] more appropriate with AOTs associated with AC-power related components. It was our understanding that the intent of this restriction was to assure the regulator that the overall combined plant risk remains below a CDF of  $10^{-4}$  per year (per requirements of RG 1.174). The intent of this section should be clarified. This requirement should be reduced to providing information regarding the reasons underlying low risk associated with this system.

*Response:* The staff acknowledges that, for many plants, the impact of the CT extension on external event risk will be minimal. If this is the case, the licensee needs to confirm this in its submittal and explain why there is limited overlap.

7. *Comment:* Section 4.2.1 item 3 ACCEPTANCE CRITERIA requires "combining internal events, internal flooding, external events and shutdown PRA results." The requirements for the combination of events should be modified to have the utility provide a technical basis for demonstrating the plant CDF to be less than  $10^{-4}$  per year or has no plant specific vulnerabilities (per SECY-88-20). Requirements for a fully quantified external events (including fire) PRA and shutdown PRA [are] beyond the state of the art. Few plants have all the above. The Fire PRA standard is just undergoing peer review and no shutdown PRA standard has been written. Methods for combining these PRA results [are] also not defined (particularly merging shutdown and "at power" PRA results). Instead, it should be noted that the utility may use existing external event evaluations including IPEEE results and qualitative external event assessments, where appropriate, to provide confidence that the overall plant CDF is not within RG 1.174 risk region 1.

*Response:* The staff is requesting that licensees provide  $\Delta$ CDF and  $\Delta$ LERF calculations for those external events for which the licensee has a PRA. For external events for which the licensee does not have a PRA, the licensee will need to confirm there are no vulnerabilities that would indicate that

the total CDF is  $>10^{-4}$  or the total LERF is  $>10^{-5}$  yr. this stipulation allows the staff to ensure that plans whose  $\Delta$ CDF or  $\Delta$ LERF calculation puts them in Region II of either Figure 3 or Figure 4 of RG 1.174 are still within the RG 1.174 Section 2.2.4 acceptance guidelines for total plant risk (CDF and LERF).

With regard to NEI's comments on a fully-quantified external events (including fire) PRA and shutdown PRA being beyond state-of-the-art, the staff believes the wording in the EXPECTATIONS for Section 4.2.1 condition 3 was misinterpreted. The wording has been revised to read "(quantitatively and/or qualitatively, as appropriate)." However, the staff notes that while fire and shutdown PRA standards have not yet been endorsed, there are available methods to quantify fire and shutdown PRA. Therefore, the staff does not believe such evaluations are beyond the state of the art. Rather, they are areas where some evaluation is still ongoing.

8. *Comment:* EXPECTATIONS supporting 4.2.1 item 4. The TS is structured to have a revised CT. Once the new CT is adopted the old CT will disappear as a regulatory item. Thus, there is no entry into an extended CSS CT. It is simply an entry into the CT. There are no significant external event interactions and the outage is limited to a single spray train. Therefore, The Tier 2 requirement should be limited to one CSS out of service, which is already governed in the TS with a cautionary note that Maintenance rule or tier 3 guidance to not simultaneously disable both the emergency grade fan coolers and the sprays.

*Response:* The staff agrees that "extended CT" should not be used in the model LAR. Appropriate changes will be made here and in other sections of the FRN where appropriate.

The staff believes that a tier 2 justification by the licensee is warranted with regard to removing one CSS train from service due to scheduled "preventive" maintenance for the 7-day period. If there are no risk-significant configurations or risk-significant external event conditions identified in the tier 2 evaluation, then the licensee should include a statement that there are no risk-significant configurations or external event conditions that would preclude them from using the 7-day CT.

9. *Comment:* End of [Section 4.2.1 item 7]. Note that the RGs provide guidelines. Risk values are not rigid thresholds. Thus small deviations to the guidance can be and are somewhat fuzzy to allow for the mathematical uncertainties inherent in these studies.

*Response:* The staff agrees that RG 1.174 and 1.177 guidelines are not rigid standards, and has revised condition 7 to delete the second paragraph of the EXPECTATIONS section. Note that Condition 5 of the model LAR requires licensees to confirm that their CRMP or associated (a)(4) program meets all aspects of Section 2.3.7.2 or RG 1.177.

Dated at Rockville, Maryland; this 19th day of October 2006.

For the Nuclear Regulatory Commission.

**Timothy J. Kobetz,**

*Branch Chief, Technical Specifications Branch, Division of Inspection and Regional Support, Office of Nuclear Reactor Regulation.*

FOR INCLUSION ON THE TECHNICAL SPECIFICATION WEB PAGE THE FOLLOWING EXAMPLE OF A LICENSE AMENDMENT REQUEST (LAR) WAS PREPARED BY THE NRC STAFF TO FACILITATE THE ADOPTION OF TECHNICAL SPECIFICATIONS TASK FORCE (TSTF) TRAVELER TSTF-409, REVISION 2 "CONTAINMENT SPRAY SYSTEM COMPLETION TIME EXTENSION (CE NPSD-1045-A)." THE MODEL PROVIDES THE EXPECTED LEVEL OF DETAIL AND CONTENT FOR A LAR TO ADOPT TSTF-409, REVISION 2. LICENSEES REMAIN RESPONSIBLE FOR ENSURING THAT THEIR PLANT-SPECIFIC LAR FULFILLS THEIR ADMINISTRATIVE REQUIREMENTS AS WELL AS NRC REGULATIONS.

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

SUBJECT: [PLANT NAME]

APPLICATION FOR TECHNICAL SPECIFICATION IMPROVEMENT TO EXTEND THE COMPLETION TIME FOR CONTAINMENT SPRAY SYSTEM INOPERABILITY IN ACCORDANCE WITH TSTF-409, REVISION 2

Dear Sir or Madam:

In accordance with the provisions of Section 50.90 of Title 10 of the Code of Federal Regulations (10 CFR 50.90), [LICENSEE] is submitting a request for an amendment to the technical specifications (TS) for [PLANT NAME, UNIT NOS.].

The proposed changes would revise TS 3.6.6A, "Containment Spray and Cooling Systems," by extending from 72 hours to seven days the completion time (CT) to restore an inoperable containment spray system (CSS) train. In addition, a Condition would be added to the TS to allow one CSS train and one containment cooling system

(CCS) train to be inoperable for a period of 72 hours.

The changes are consistent with NRC-approved Industry Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-409, Revision 2, "Containment Spray System Completion Time Extension (CE NPSD-1045-A)."

Enclosure 1 provides a description and assessment of the proposed changes and confirmation of applicability. Enclosure 2 provides the existing TS pages marked-up to show the proposed changes. Enclosure 3 provides the existing TS Bases marked-up to reflect the proposed changes (for information only). Final TS Bases will be provided in a future update to the Updated Final Safety Analysis Report (UFSAR) in accordance with the Bases Control Program. Attachments 1 through 8 provide the discussions of [LICENSEE'S] evaluations and supporting information with regard to the conditions stipulated in Section 4.2.1 of Enclosure 1.

[LICENSEE] requests approval of the proposed license amendment by [DATE], with the amendment being implemented [BY DATE OR WITHIN X DAYS]. in accordance with 10 CFR 50.91, a copy of this application, with enclosures, is being provided to the designated [STATE] Official.

I declare under penalty of perjury under the laws of the United States of America that I am authorized by [LICENSEE] to make this request and that the foregoing is true and correct. [Note that request may be notarized in lieu of using this oath or affirmation statement]. If you should have any questions regarding this submittal, please contact [ ].

Sincerely,  
Name, Title

Enclosures:

1. Description and Assessment of Proposed Changes
2. Proposed Technical Specification Changes
3. Proposed Technical Specification Bases Changes (if applicable)

Attachments:

1. Licensee's supporting information for condition 1
2. Licensee's supporting information for condition 2
3. Licensee's supporting information for condition 3
4. Licensee's supporting information for condition 4
5. Licensee's supporting information for condition 5
6. Licensee's supporting information

- for condition 6
- 7. Licensee's supporting information for condition 7
- 8. Licensee's supporting information for condition 8

cc:

NRR Project Manager  
Regional Office  
Resident Inspector  
State Contact  
ITSB Branch Chief

### 1.0 Description

The letter is a request to amend Operating License(s) [LICENSE NUMBER(S)] for [PLANT/UNIT NAME(S)].

The proposed changes would revise Technical Specification (TS) 3.6.6A, "Containment Spray and Cooling Systems," by extending from 72 hours to seven days the completion time (CT) to restore an inoperable containment spray system (CSS) train to operable status, and would add a Condition describing the required action and CT when one CSS train and one containment cooling system (CCS) train are inoperable.

The changes are consistent with NRC approved Industry Owner's Group Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler TSTF-409, Revision 2 (Rev. 2), "Containment Spray System Completion Time Extension (CE NPSD-1045-A)." TSTF-409, Rev. 2 was approved by the NRC on [DATE].

### 2.0 Proposed Change

Specifically, the proposed revision extends the CT (or allowed outage time) that one CSS train is permitted to remain inoperable from 72 hours to seven days based on Reference 1, as accepted by, and subject to the limitations specified in, Reference 2. TSTF-409, Rev. 2 states that the longer CT will enhance overall plant safety by avoiding potential unscheduled plant shutdowns and allowing greater availability of safety significant components during shutdown. In addition, TSTF-409, Rev. 2 states that this extension provides for increased flexibility in scheduling and performing maintenance and surveillance activities in order to enhance plant safety and operational flexibility during lower modes of operation.

The revision also adds a Condition to allow one CSS train and one CCS train to be inoperable for up to 72 hours. Since Reference 1 did not evaluate the concurrent inoperabilities of one CSS train and one CCS train, the CT for this Condition was limited to 72 hours.

[LICENSEE] also proposes to make changes to the supporting TS Bases in accordance with TSTF-409, Rev. 2. Changes to the Bases include supporting information justifying the addition of the Condition for one CSS train and one CCS train inoperable. The Bases changes also include a reviewer's note that requires [LICENSEE] to adopt Reference 1 and meet the requirements of References 1 and 2 prior to utilizing the 7-day CT for one inoperable CSS. Finally, a reference to Reference 1 is added to the Bases. Markups of the TS Bases are provided in enclosure 3. Changes to the Bases will be implemented in accordance with [LICENSEE's] bases control program.

In summary, [LICENSEE] proposes to extend the CT for one inoperable CSS train from 72 hours to 7 days based on Reference 1, and add a Condition to allow one CSS train and one CCS train to be inoperable for up to 72 hours.

### 3.0 Background

The function of the containment heat removal systems under accident conditions is to remove heat from the containment atmosphere, thus maintaining the containment pressure and temperature at acceptably low levels. The systems also serve to limit offsite radiation levels by reducing the pressure differential between the containment atmosphere and the external environment, thereby decreasing the driving force for fission product leakage across the containment. The two containment heat removal systems are the CCS and the CSS. The CCS fan coolers are designed to operate during both normal plant operations and under loss-of-coolant accident [LOCA] or main steam line break [MSLB] conditions. The CSS is designed to operate during accident conditions only.

The heat removal capacity of the CCS and CSS is sufficient to keep the containment temperature and pressure below design conditions for any size break, up to and including a double-ended break of the largest reactor coolant pipe. The systems are also designed to mitigate the consequences of any size break, up to and including a double-ended break of a main stream line. The CCS and CSS continue to reduce containment pressure and temperature and maintain them at acceptable levels post-accident.

The CCS and CSS at [PLANT NAME] each consist of [Substitute plant-specific configuration if it differs from the following description] two redundant loops and are designed such that a single failure does not degrade their ability to provide the required heat

removal capability. Two of four containment fan coolers and one CSS loop are powered from one safety-related bus. The other two containment fan coolers and CSS loop are powered from another independent safety-related bus. The loss of one bus does not affect the ability of the containment heat removal systems to maintain containment temperature and pressure below the design values in a post-accident mode.

The [PLANT NAME] CSS consists of [Substitute plant-specific configuration if it differs from the following description] two independent and redundant loops each containing a spray pump, shutdown heat exchanger, piping, valves, spray headers, and spray nozzles. It has two modes of operation, which are:

1. The injection mode, during which the system sprays borated water from the refueling water tank (RWT) into the containment, and

2. The recirculation mode, which is automatically initiated by the recirculation actuation signal (RAS) after low level is reached in the RWT. During this mode of operation, the safety injection system (SIS) sump provides suction for the spray pumps.

Containment spray is automatically initiated by the containment spray actuation signal coincident with the safety injection actuation signal and high containment pressure signal. If required, the operator can manually activate the system from the main control room.

Each CSS pump, together with a CCS loop, provides the flow necessary to remove the heat generated inside the containment following a LOCA or MSLB. Upon system activation, the pumps are started and the borated water flows into the containment spray headers. When low level is reached in the RWT, sufficient water has been transferred to the containment to allow for the recirculation mode of operation. Spray pump suction is automatically realigned to the SIS sump upon a RAS.

During the recirculation mode, the spray water is cooled by the shutdown heat exchangers prior to discharge into the containment. The shutdown heat exchangers are cooled by the component cooling water system. Post-LOCA pH control is provided by [Substitute plant-specific configuration if it differs from the following description] trisodium phosphate dodecahydrate, which is stored in stainless steel baskets located in the containment near the SIS sump intake.

The longer CT for an inoperable CSS train will enhance overall plant safety by avoiding potential unscheduled plant

shutdowns and allowing greater availability of safety significant components during shutdown. In addition, this extension provides for increased flexibility in scheduling and performing maintenance and surveillance activities in order to enhance plant safety and operational flexibility during lower modes of operation.

#### 4.0 Technical analysis

[LICENSEE] has reviewed References 1 and 2, as well as TSTF-409, Rev. 2, and the model SE published on [DATE] ([ FR ]) as part of the CLIP Notice of Availability. [LICENSEE] has applied the methodology in Reference 1 to develop the proposed TS changes. [LICENSEE] has also concluded that the justifications presented in TSTF-409, Rev. 2 and the model SE prepared by the NRC staff are applicable to [PLANT NAME], and justify this amendment for the incorporation of changes to the [PLANT NAME] TS.

In determining the suitability and safety impact of its adoption of TSTF-409, Rev. 2, [LICENSEE] analyzed the effect of increasing the CT for one CSS train to remain out of service using both traditional engineering considerations and probabilistic risk assessment (PRA) methods.

##### 4.1 Traditional (Deterministic) Engineering Analysis

The functions and operation of the CSS and CCS were described in Section 3.0 of this application. Based on a review of the design-basis requirements for the CSS, [LICENSEE] concluded that the loss of one CSS train is well within the design-basis analyses. This conclusion is based on the fact that each CSS pump, together with a CCS loop, provides the flow necessary to remove the heat generated inside the containment following a LOCA or MSLB. Therefore, the combination of one CSS pump and one CCS loop can carry out the design functions of maintaining the containment pressure and temperature at acceptably low levels following a design-basis accident (DBA), and limiting offsite radiation levels by reducing the pressure differential between the containment atmosphere and the external environment, thereby decreasing the driving force for fission product leakage across the containment.

The plant status with one CSS train and one CCS train inoperable is covered by TS 3.6.6A, ACTION [D], which states:

“[With] one containment spray and one containment cooling train inoperable, restore containment spray train to OPERABLE status

within 72 hours, or restore containment cooling train to OPERABLE status within 72 hours.”

ACTION [D] ensures that the iodine removal capabilities of the CSS are available, along with 100 percent of the heat removal needs after an accident. The supporting analyses performed in Reference 1 did not evaluate the concurrent inoperabilities of one CSS train and one CCS train, therefore, the current CT of 72 hours is retained in Condition [D]. The 72 hour Completion Time was developed taking into account the redundant heat removal capabilities afforded by combinations of the CSS and CCS, the iodine removal function of the CSS, and the low probability of a DBA occurring during this period.

##### 4.2 Probabilistic Risk Assessment Evaluation

[LICENSEE] evaluated the proposed CT extension for the CSS using Reference 3 and Reference 4. This is the same methodology that the NRC staff used in Reference 2. The Key Principles of A Risk-Informed Integrated Decisionmaking Process listed in Reference 3 are as follows:

- Principle I: The proposed change meets the current regulations.
- Principle II: The proposed change is consistent with the defense-in-depth philosophy.
- Principle III: The proposed change maintains sufficient safety margin.
- Principle IV: When the proposed change results in an increase in core damage frequency or risk, the increase should be small and consistent with the Commission's Safety Goal Policy Statement.
- Principle V: The impact of the proposed change should be monitored using performance measurement strategies.

In Reference 2, the NRC staff found, and [LICENSEE] agrees, that in risk-informed TS CT applications, Principle I is met, since regulations do not require specific CTs, but, rather, require “remedial actions” when an LCO cannot be met. Additionally, in its analysis of Principle III, the NRC staff found, and [LICENSEE] agrees, that the proposed CT extension maintains sufficient safety margins. For [PLANT NAME], the loss of one CSS train is well within the plant's design basis.

In Reference 2, the NRC staff determined that the intent of Principles II, IV, and V would be met by a three-tiered approach to evaluate the plant-specific risk impact associated with the proposed TS changes, consistent with the requirements of Reference 4. The first tier evaluates the plant-specific

PRA model and the impact of the proposed CT extension on plant operational risk. The second tier addresses the need to preclude potentially high risk configurations by identifying the need for any additional constraints or compensatory actions that, if implemented, would avoid or reduce the probability of a risk-significant configuration during the time when one CSS train is out of service. The third tier evaluates [LICENSEE'S] proposed Configuration Risk Management Program (CRMP) to ensure that the applicable plant configuration will be appropriately assessed from a risk perspective before entering into or during the proposed CT.

In addition, the NRC staff determined in Reference 2, that the risk analysis methodology and approach used by the CEOG to estimate the risk impact of increasing the CT were reasonable. For most plants that participated in the joint application report, the NRC staff found that the risk impact was shown to be consistent with the acceptance guidelines for change in core damage frequency ( $\Delta$ CDF), change in large early release frequency ( $\Delta$ LERF), incremental conditional core damage probability (ICCDP), and incremental conditional large early release probability (ICLERP) specified in References 3 and 4 and Chapters 19.0 and 16.1 of Reference 5. However, not all Combustion Engineering (CE) plants participated in the joint application report, and the estimated risk impacts for some plans exceeded the Reference 3 and/or Reference 4 acceptance guidelines, which would require additional justifications and/or compensatory measures to be provided for these plants to be determined to have acceptable risk impacts.

In addition, the NRC staff found that the Tier 2 and Tier 3 evaluations, as described in Reference 4, could not be approved generically since they were not complete, which would require that each individual plant-specific license amendment seeking adoption of TSTF-409, Rev. 2 would need to include an assessment with respect to the Tier 2 and Tier 3 principles of Reference 4.

##### 4.2.1 Conditions and Supporting Information

The following conditions are provided to support adoption of TSTF-409, Rev. 2 by [PLANT NAME]. Responses to the conditions are contained in Attachments 1 through 8 to this application: [NOTE: Licensees who cannot meet the Expectation and Acceptance Criteria listed in these conditions, or choose not to submit the associated information, should not

submit an application to adopt TSTF-409, Rev. 2 under the CLIIP.]

1. As shown in Attachment 1, the plant-specific Tier 1 information associated with extending the CSS CT meets the acceptance guidelines of References 3 and 4 associated with  $\Delta$ CDF,  $\Delta$ LERF, ICCDP, and ICLERP.

**[EXPECTATIONS/ACCEPTANCE CRITERIA:** the licensee's submittal must provide the  $\Delta$ CDF,  $\Delta$ LERF, ICCDP, and ICLERP values related to the CSS 7-day CT and confirm that these values meet the associated acceptance guidelines of References 3 and 4 as no more than a small risk increase (i.e., are in Region II or III of the acceptance guidelines figures). The licensee should utilize an "average maintenance" PRA model for this assessment. If the licensee utilizes a "zero maintenance" PRA model for the assessment, they should state they are using a "zero maintenance" model in the evaluation, and provide a discussion as to the ability of that model to produce comparable results to the "average maintenance" assessment.]

2. As shown in Attachment 2, the technical adequacy (quality) of [PLANT NAME'S] plant-specific PRA is acceptable for this application in accordance with the guidance provided in Reference 3. Specifically, the supporting information addresses the following areas:

a. Justification that the plant-specific PRA reflects the as-built, as-operated plant.

b. Discussion of plant-specific PRA updates and upgrades since the individual plant examination (IPE), individual plant examination of external events (IPEEE), and subsequent peer reviews and self-assessment. Reference to past submittals discussing this information is acceptable.

c. Discussion of plant-specific PRA peer reviews and/or self-assessments performed, their overall conclusions, any facts and observations (F&Os) applicable to this application, and the licensee evaluation and resolution (e.g., by implementing model changes and/or sensitivity studies) of these F&Os to demonstrate the conclusions of the plant-specific analyses for this application are not adversely impacted (i.e., continued acceptability of the proposed extension of the CSS CT).

d. Description of the licensee's plant-specific PRA configuration control (quality assurance) program and associated procedures.

e. Overall determination of the adequacy of the plant-specific PRA with respect to this application.

**[EXPECTATION:** The licensee's submittal must describe the scope of the

plant-specific PRA and must justify its technical adequacy (quality) for this application in accordance with the guidance provided in Reference 3. Specifically, the supporting information must address each area in sufficient detail as shown in the following

**ACCEPTANCE CRITERIA:**

a. The licensee must provide a justification that confirms that the plant-specific PRA reflects the as-built, as-operated plant. This should include a description of the licensee's data and model update process, and the frequency of these activities. The licensee should also describe how the plant/corporate PRA staff are involved in (and/or made aware of) plant and operational/procedural modifications.

b. The licensee must provide a summary description of the plant-specific PRA updates and upgrades since the IPE and peer review of their plant and confirm that the changes identified during the IPEEE have been implemented or otherwise dispositioned.

c. The licensee must discuss their plant-specific PRA peer reviews and/or any self-assessments performed (especially noting those conducted per the Nuclear Energy Institute (NEI) industry peer review guidelines and American Society of Mechanical Engineers (ASME) PRA Standard), their overall conclusions, any A&B level F&Os applicable to this application, and the licensee's evaluation and resolution (e.g., by implementing model changes and/or sensitivity studies) of these A&B level F&Os to demonstrate the conclusions of the plant-specific analyses for this application are not adversely impacted (i.e., continued acceptability of the proposed extension of the CSS CT).

d. The licensee must describe their plant-specific PRA configuration control (quality assurance) program and associated procedures.

e. The licensee must make an overall determination of the adequacy of their plant-specific PRA, confirming it is adequate with respect to this application.]

3. Attachment 3 provides supporting information verifying that the plant risk impact associated with external events (e.g., fires, seismic, tornados, high winds, etc.) does not adversely impact or has no impact on the conclusions of the plant-specific analyses for this application and that the overall combined plant CDF and LERF are expected to be within the acceptance guidelines as identified in References 3 and Reference 4 (i.e., total CDF <1E-4/year and total LERF <1E-5/year)

**[EXPECTATIONS:** The licensee's submittal must discuss the plant risks associated with external events and specifically identify (quantitatively and/or qualitatively, as appropriate) that the impact of CSS train CT extension on the risks associated with external events is small. The NRC staff acknowledges that any increase in the external event risk associated with the CSS train CT extension should be minimal. The licensee must address this impact and discuss why the risk overlap with external events (including internal fires) is negligible. Key insights from the IPEEE screening or quantitative approaches may be used to support qualitative arguments.

If the licensee has performed updated analyses of an external event since the staff review and acceptance of their IPEEE, and a quantitative PRA demonstration is used to support the submittal, the licensee must describe the significant changes involved in their updated analyses and the impact of these changes on plant risk associated with this external event and with respect to this application.

**ACCEPTANCE CRITERIA:** For the NRC staff to conclude the quantified risk associated with the extension request is acceptable, the total CDF and LERF values must meet Reference 3 and Reference 4 acceptance guidelines. For external events for which the licensee has a PRA, and the licensee provides those risk values (i.e., CDF and LERF) and risk metrics (i.e.,  $\Delta$ CDF,  $\Delta$ LERF, ICCDP, and ICLERP) associated with the specifically analyzed external events, the licensee must also provide the total "at-power" plant risk and total "at-power" change in risk due to all PRA-analyzed contributors (combining internal events, internal flooding, internal fires, and external events. Results may be provided as a summation of values from separate PRA analyses or as a result of an integrated analysis (using a common PRA model for all contributors) or a combination of the above.

For external events for which the licensee does not have a PRA (and it is not screened out as above), but rather relies on a non-PRA method (e.g., seismic margins analysis (SMA) or fire-induced vulnerability evaluation (FIVE)), to determine if the plant risk is acceptable, the licensee must confirm for this application that there were and still are either no vulnerabilities or outliers associated with these external events, or confirm that any vulnerabilities or outliers that were identified in their documented analyses (most likely in their IPEEE) have been resolved and, as needed, the appropriate



plant/procedural modifications have been implemented as described in their documented analyses.]

4. Supporting information is provided in Attachment 4, consistent with the evaluation summary and conclusions (Sections 7 and 8) provided in Reference 2, in which licensees discuss implementation of procedures that prohibited entry into a 7-day CSS CT for scheduled maintenance purposes if external event conditions or warnings (e.g., severe weather warnings for ice, tornados, high winds, etc.) are in effect or confirm that these external events do not impact the submittal. [LICENSEE'S] discussion confirms that [PLANT NAME'S] procedures include compensatory measures and normal plant practices that help avoid potentially high risk configurations during the proposed extension of the CSS CT. This supporting information must also address the Tier 2 aspects of Reference 4.

**[EXPECTATIONS:** The licensee's submittal must discuss (including licensee commitments related to) implementation of procedures that prohibit entry into a 7-day CSS CT for scheduled maintenance purposes if external event conditions or warnings are in effect. If the licensee does not want to implement this prohibition for specific severe weather conditions or warnings, the licensee must explicitly identify these event conditions/warnings and provide a justification for not including them. If there are no risk significant configurations or risk significant external event conditions identified in the Tier 2 evaluation, then the licensee should include a statement that there are no risk significant configurations that would preclude them from using a 7-day CT.

The licensee must also confirm that its procedures include compensatory measures and normal plant practices that help avoid potentially high risk configurations during the proposed extension of the CSS train CT. This supporting information must also address the Tier 2 aspects of Reference 4. The Tier 2 evaluation is meant to be an early evaluation (at the license submittal stage) to identify and preclude potentially high-risk plan configurations that could result if equipment, in addition to that associated with the proposed license amendment, is taken out of service simultaneously, or if other risk-significant operational factors, such as concurrent system or equipment testing, are also involved.

**[ACCEPTANCE CRITERIA:** The Tier 2 evaluation needs to identify, as part of the licensee's submittal, potentially high-risk plant configurations associated

with the CSS train CT extension that need to be precluded, if any, and identify how this is implemented (i.e., typically these aspects result in licensees establishing compensatory measures/commitments to ensure these configurations are precluded). If, in conducting the evaluation, the licensee identifies no high-risk plant configurations, then the licensee needs to explicitly state this fact.]

5. Attachment 5 provides supporting information, consistent with the evaluation summary and conclusions (Sections 7 and 8) provided in Reference 2, that describes the plant-specific risk-informed CRMP to assess the risk associated with the removal of equipment from service during the 7-day CSS CT. If the licensee utilizes the Maintenance Rule (a)(4) program to evaluate the risk significance of configurations, it should state so in its submittal. In this description, [LICENSEE] confirms that the program provides the necessary assurances that appropriate assessments of plant risk configurations are sufficient to support the proposed CSS CT extension request. This supporting information also addresses the Tier 3 aspects of Reference 4.

**[EXPECTATIONS/ACCEPTANCE CRITERIA:** The licensee's submittal must describe its CRMP or associated (a)(4) program (as appropriate), including how it reflects the current plant PRA model (specifically identifying any deviations and simplifications in the CRMP model from the plant-specific PRA model) and how the CRMP is updated to remain consistent with the plant-specific PRA.

The licensee's submittal must also describe how the CRMP or associated (a)(4) program provides the necessary assurances that appropriate assessments of plant risk configurations are sufficient to support the proposed CT extension request for the CSS.

Finally, the licensee's submittal must address the Tier 3 aspects of Reference 4, including the description of the CRMP, and must confirm that its CRMP or associated (a)(4) program meets all aspects of Section 2.3.7.2 of Reference 4, specifically describing how its program meets each of the four Key Components identified in this Section. The Tier 3 evaluation ensures that the CRMP or associated (a)(4) program is adequate when maintenance is about to commence, as opposed to the early (submittal stage) evaluation performed for Tier 2.]

6. Attachment 6 provides supporting information, consistent with the evaluation summary (Section 7) provided in Reference 2, describing the

relationship between components of the CSS and the shutdown cooling system (SDCS). For plants where components of the two systems may be used as backup to the other, the licensee must either confirm that Tier 2 conditions exist in the licensee's CRMP or associated (a)(4) program that will not allow "at power" maintenance of the CSS and SDCS at the same time or that the risk significance of such maintenance configurations is low. If the CSS and SDCS have backup components, the plant should also describe how this backup capability is considered as part of the plant's shutdown operations program (SOP). If this backup feature is not considered when one train of the SDCS is in maintenance or otherwise unavailable, it should be stated in the licensee's application.

**[EXPECTATION:** The licensee's submittal must describe the relationship/interfaces between the CSS and SDCS.

**[ACCEPTANCE CRITERIA:** If the SDCS can be used as a backup to the CSS, then the licensee must confirm that "at power" maintenance of the CSS and SDCS will not be allowed at the same time and describe how this is controlled (e.g., specifically identified in the CRMP as a configuration that is not allowed) or provide justification that the risks associated with a simultaneous "at-power" outage of one SDCS train and one CSS train is small. If the SDCS cannot be used (and is not credited) as a backup to CSS, then the licensee needs to explicitly state this fact.

If CSS pumps can be used as a backup to the SDCS pumps, then the licensee must confirm that at least one CSS pump is required to be operable when maintenance of the CSS is performed in lower modes of operation (consistent with the plant's Technical Specifications) and must describe how this is controlled or demonstrate that the SOP provides adequate risk management for that configuration. If CSS pumps cannot be used (and are not credited) as a backup to SDCS pumps in lower modes of operation, then the licensee needs to explicitly state this fact.]

7. Attachment 7 provides supporting information confirming that the licensee's Maintenance Rule program includes the ability to compute ICDP (incremental core damage probability), and ILERP (incremental large early release probability).

**[EXPECTATIONS/ACCEPTANCE CRITERIA:** The licensee must confirm that their CRMP quantitative model (e.g., model used to provide quantitative assessments in support of 10 CFR 50.65 (a)(4)) calculates ICDP and ILERP, and



that their CRMP quantitative model (e.g., model used to provide quantitative assessment in support of 10 CFR 50.65 (a)(4)) explicitly models the CSS or has been modified to include the CSS, which will be used whenever CSS components are made unavailable.

8. Attachment 8 provides information addressing how plant-specific systems, structures and components (SSC) are monitored and assessed at the plant under the Maintenance Rule (i.e. 10 CFR 50.65). Maintenance Rule unavailability and unreliability targets for CSS are also provided. These targets will be monitored in accordance with provisions of the Maintenance Rule.

**[EXPECTATIONS/ACCEPTANCE CRITERIA:** The licensee must describe how plant-specific SSC reliability and availability are monitored and assessed at the plant under the Maintenance Rule (i.e., 10 CFR 50.65) to confirm that performance continues to be consistent with the analyses used to justify the 7-day CT. In providing this description, the licensee should also indicate how it periodically assesses previous risk-informed licensing action decisions to ensure that these decisions remain valid (i.e., continue to meet the Reference 3 and Reference 4 acceptance guidelines) for the current plant operations and plant-specific PRA and what actions it takes if a previously-approved risk-informed licensing action decision is determined to no longer meet these acceptance guidelines.]

#### 4.2.2 Regulatory Commitment

The Reference 4 Tier 3 program ensures that, while the plant is following the TS ACTIONS associated with a 7-day CT for restoring an inoperable CSS to operable status, additional activities will not be performed that could further degrade the capabilities of the plant to respond to a condition that the inoperable CSS is designed to mitigate and, as a result, increase plant risk beyond that determined by the Reference 1 analyses. [LICENSEE's] implementation of Reference 4 Tier 3 guidelines generally implies the assessment of risk with respect to CDF. However, the proposed CSS 7-day CT impacts accident sequences that can be mitigated following core damage and, consequently, impacts LERF as well as

CDF. Therefore, [LICENSEE] has enhanced its CRMP, [OPTIONAL: as implemented under 10 CFR 50.65(a)(4), the Maintenance Rule.] to include a LERF assessment to support this application.

### 5.0 Regulatory Analysis

#### 5.1 No Significant Hazards Consideration

[LICENSEE] has reviewed the proposed no significant hazards consideration determination published in the **Federal Register** on [DATE] ([ ] FR [ ]) as part of the CLIP. [LICENSEE] has concluded that the proposed determination presented in the notice is applicable to [PLANT NAME] and the determination is hereby incorporated by reference to satisfy the requirements of 10 CFR 50.91(a).

#### 5.2 Applicable Regulatory Requirements/Criteria

Based on its answers to the Section 4.2.1 questions provided in Attachments 1 through 8 to this application [LICENSEE] determines is based on the following:

1. The traditional engineering evaluation reveals that the loss of one CSS train is well within [PLANT NAME's] design basis analyses. Key principles 1,2,3, and 5 in Section 2 of Reference 3 are met.
2. By meeting the conditions identified in Section 4.2.1, [LICENSEE] believes that its PRA model is acceptable for this application and also concludes that there is minimal impact of the CT extensions for the CSS system on plant operational risk (Tier 1 evaluation).
3. By meeting the conditions identified in Section 4.2.1, [LICENSEE] will ensure that its implementation will identify potentially high risk configurations and the need for any additional constraints or compensatory actions that, if implemented, would avoid or reduce the probability of a risk-significant configuration (Tier 2 evaluation), or state that no Tier 2 limitations have been identified.
4. By meeting the conditions identified in Section 4.2.1, [PLANT NAME] will ensure that its risk-informed CRMP will satisfactorily assess the risk associated with the removal of equipment from service

during the proposed CSS CT (Tier 3 evaluation) and the CRMP and plant risk will be managed by plant procedures, including implementation and monitoring of SSCs (CSS).

In conclusion, based on the consideration discussed above, (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

### 6.0 Environmental Consideration

[LICENSEE] has reviewed the environmental evaluation included in the model safety evaluation as part of the CLIP. [LICENSEE] concluded that the staff's findings presented in that the evaluation are applicable to [PLANT NAME] and the evaluation is hereby incorporated by reference for this application.

### 7.0 References

- [Licensee should include an applicable list of references, including but not limited to]
1. Joint Applications Report: Modification to the Containment Spray System, and Low Pressure Safety Injection System Technical, CE Owners Group, CE NPSD-1045, March 2000.
  2. Safety Evaluation by the Office of Nuclear Reactor Regulation Related to CE Owners Group CE-NPSD-1045, "Joint Application Report, Modification to the Containment Spray System, and the Low Pressure Safety Injection System Technical Specifications, December 21, 1999."
  3. USNRC Regulatory Guide 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis," Revision 1, November 2002.
  4. USNRC Regulatory Guide 1.177, "An Approach for Plant-Specific, Risk-Informed Decisionmaking: Technical Specifications," August 1998.
  5. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," June 1996.

PROPOSED TECHNICAL SPECIFICATION CHANGES (MARK-UP)

Enclosure 2

CHANGES TO TS BASES

Enclosure 3

CONDITION (1)  
[LICENSEE'S] EVALUATION AND SUPPORTING INFORMATION

	Attachemnt 1
CONDITION (2) [LICENSEE'S] EVALUATION AND SUPPORTING INFORMATION	Attachemnt 2
CONDITION (3) [LICENSEE'S] EVALUATION AND SUPPORTING INFORMATION	Attachemnt 3
CONDITION (4) [LICENSEE'S] EVALUATION AND SUPPORTING INFORMATION	Attachemnt 4
CONDITION (5) [LICENSEE'S] EVALUATION AND SUPPORTING INFORMATION	Attachemnt 5
CONDITION (6) [LICENSEE'S] EVALUATION AND SUPPORTING INFORMATION	Attachemnt 6
CONDITION (7) [LICENSEE'S] EVALUATION AND SUPPORTING INFORMATION	Attachemnt 7
CONDITION (8) [LICENSEE'S] EVALUATION AND SUPPORTING INFORMATION	Attachemnt 8

MODEL SAFETY EVALUATION  
U.S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Consolidated Line Item Improvement  
Technical Specification Task Force  
TSTF-409, Revision 2  
"Containment Spray System  
Completion Time Extension"

### 1.0 Introduction

By letter to the Nuclear Regulatory Commission (NRC, Commission) dated [DATE] (Agencywide Documents Access and Management System (ADAMS) Accession Number MLXXXXXXXXXX), [LICENSEE] (the licensee) requested changes to the Technical Specifications (TSs) for [PLANT NAME]. The proposed changes would revise TS 3.6.6A, "Containment Spray and Cooling Systems," by extending from 72 hours to seven days the completion time (CT) to restore an inoperable containment spray system (CSS) train to operable status, and would add a Condition describing the required action and CT when one CSS train and one containment cooling system (CCS) train are inoperable.

The changes are based on Technical Specification Task Force (TSTF) Change Traveler, TSTF-409, Revision 2 (Rev.), "Containment Spray System Completion Time Extension (CE NPSD-2045-A)" and associated TS Bases. TSTF-409, Rev. 2, submitted to the NRC by the TSTF in a letter dated November 10, 2003 (ADMS Accession Number

MLO33280006), was approved by the NRC on [DATE].

TSTF-409, Rev. 2 is based on Combustion Engineering Owner's Group (CEOG) Joint Application Report CE NPSD-1045-A, "Joint Applications Report for Modifications to the Containment Spray System Technical Specifications," dated March 2000 (Reference 1), as accepted by, and subject to the limitations specified in, the associated NRC safety evaluation (SE), dated December 212, 1999 (ADMS Accession Number ML993620241) (Reference 2).

In TSTF-409, Rev. 2, the CEOG states that the longer CT for restoring an inoperable CSS train to operable status will enhance overall plant safety by avoiding potential unscheduled plant shutdowns and allowing greater availability of safety significant components during shutdown. In addition the CEOG states that this extension provides for increased flexibility in scheduling and performing maintenance and surveillance activities in order to enhance plant safety and operational flexibility during lower modes of operation.

### 2.0 Regulatory Evaluation

Since the mid-1980's, the NRC has been reviewing and granting improvements to TS that are based, at least in part, on probabilistic risk assessment (PRA) insights. In its final policy statement on TX improvements dated July 22, 1993 (58 FR 39132), the NRC stated that it:

\* \* \* expects that licensees, in preparing their Technical Specification related submittals, will utilize any plant-specific PSA [probabilistic safety assessment]<sup>1</sup> or risk survey and any available literature on risk insights and PSAs \* \* \* Similarly, the NRC staff will also employ risk insights and PSAs in evaluating Technical Specifications related submittals. Further, as a part of the Commission's ongoing program of improving Technical Specifications, it will continue to consider methods to make better use of risk and reliability information for defining future generic Technical Specification requirements.

The NRC reiterated this point when it issued the revision to 10 CFR 50.36, "Technical Specifications," in July 1995. In August 1995, the NRC adopted a final policy statement on the use of PRA methods in nuclear regulatory activities that encouraged greater use of PRA to improve safety decision-making and regulatory efficiency. The PRA policy statement included the following points:

1. The use of PRA technology should be increased in all regulatory matters to the extent supported by the state-of-the-art in PRA methods and data, and in a manner that complements the NRC's deterministic approach and supports the NRC's traditional defense-in-depth philosophy.

2. PRA and associated analyses (e.g., sensitivity studies, uncertainty analyses, and importance measures) should be used in regulatory matters; where practical within the bounds of the state-

<sup>1</sup> PSA and PRA are used interchangeably herein.

of-the-art, to reduce unnecessary conservatism associated with current regulatory requirements.

3. PRA evaluations in support of regulatory decisions should be as realistic as practicable and appropriate supporting data should be publicly available for review.

In March 1998, the CEOG submitted a joint applications report for the NRC staff's review entitled, "Joint Applications Report for Modifications to the Containment Spray System and Low Pressure Safety System Technical Specifications." The NRC review accepting this joint applications report for referencing in license applications for Combustion Engineering (CE) plants, including appropriate exclusions, conditions, and limitations, is documented in Reference 2. The final, NRC-approved joint applications report, (Reference 1) is dated March 2000.

### 3.0 Technical Evaluation

The NRC staff evaluated the licensee's proposed amendment to extend the TS CT for one CSS train out of service from 72 hours to seven days using insights derived from traditional engineering considerations and the use of PRA methods to determine the safety impact of extending the CT.

#### 3.1 Traditional Engineering Evaluation

The function of the containment heat removal systems under accident conditions is to remove heat from the containment atmosphere, thus maintaining the containment pressure and temperature at acceptably low levels. The systems also serve to limit offsite radiation levels by reducing the pressure differential between the containment atmosphere and the external environment, thereby decreasing the driving force for fission product leakage across the containment. The two containment heat removal systems are the CCS and CSS. The CCS fan coolers are designed to operate during both normal plant operations and under loss-of-coolant accident (LOCA) or main stream line break (MSLB) conditions. The CSS is designed to operate during accident conditions only.

The heat removal capacity of the CCS and CSS is sufficient to keep the containment temperature and pressure below design conditions for any size break, up to and including a double-ended break of the largest reactor coolant pipe. The systems are also designed to mitigate the consequences of any size break, up to and including a double-ended break of a main stream line. The CCS and CSS continue to reduce containment pressure and

temperature and maintain them at acceptable levels post-accident.

The CCS and CSS at [PLANT NAME] each consist of [Substitute plant-specific configuration if it differs from the following description] two redundant loops and are designed such that a single failure does not degrade their ability to provide the required heat removal capability. Two of four containment fan coolers and one CSS loop are powered from one safety-related bus. The other two containment fan coolers and one CSS loop are powered from another independent safety related bus. The loss of one bus does not affect the ability of the containment heat removal systems to maintain containment temperature and pressure below the design values in a post-accident mode.

The [PLANT NAME] CSS consists of [Substitute plant-specific configuration if it differs from the following description] two independent and redundant loops each containing a spray pump, shutdown heat exchanger, piping, valves, spray headers, and spray nozzles. It has two modes of operation, which are:

1. The injection mode, during which the system sprays borated water from the refueling water tank (RWT) into the containment, and
2. The recirculation mode, which is automatically initiated by the recirculation actuation signal (RAS) after low level is reached in the RWT. During this mode of operation, the safety injection system (SIS) sump provides suction for the spray pumps.

Containment spray is automatically initiated by the containment spray actuation signal coincident with the safety injection actuation signal and high containment pressure signal. If required, the operator can manually activate the system from the main control room.

Each CSS pump, together with a CCS loop, provides the flow necessary to remove the heat generated inside the containment following a LOCA or MSLB. Upon system activation, the pumps are started, and borated water flows into the containment spray headers. When low level is reached in the RWT, sufficient water has been transferred to the containment to allow for the recirculation mode of operation. Spray pump suction is automatically realigned to the SIS sump upon a RAS.

During a recirculation mode, the spray water is cooled by the shutdown heat exchangers prior to discharge into the containment. The shutdown heat exchangers are cooled by the component cooling water system. Post-LOCA pH control is provided by [Substitute plant-

specific configuration if it differs from the following description] trisodium phosphate dodecahydrate, which is stored in stainless steel baskets located in the containment near the SIS sump intake.

Based on a review of the design-basis requirements for the CSS, the NRC staff concluded that the loss of one CSS train is well within the design-basis analyses. The plant status with one CSS train and one CCS train inoperable is covered by TS3.6.6A, ACTION D, which states:

"[With] one containment spray and one containment cooling train inoperable, restore containment spray train to OPERABLE status within 72 hours, or restore containment cooling train to OPERABLE status within 72 hours."

ACTION D ensures that the iodine removal capabilities of the CSS are available, along with 100 percent of the heat removal needs after an accident. The supporting analyses performed in Reference 1 did not evaluate the concurrent inoperabilities of one CSS train and one CCS train. Therefore, the current CT of 72 hours is retained in Condition D. The 72-hour CT was development taking into account the redundant heat removal capabilities afforded by combinations of the CSS and CCS, the iodine removal function of the CSS, and the low probabilities of a DBA occurring during this period.

#### 3.2 Probabilistic Risk Assessment Evaluation

The proposed extension of the CSS CT for one inoperable train from 72 hours to seven days affects plant risk by impacting:

1. Accident sequences that can be prevented from leading to core damage.
2. Accident sequences that can be mitigated following core damage.

The CSS therefore affects both core damage frequency (CDF) and large early release frequency (LERF). This is because the CSS performs the critical function of controlling containment temperature and pressure to cool the reactor coolant system (RCS) inventory that is spilled in the sump as a result of a LOCA (core damage prevention role) and preventing the release of radionuclides subsequent to a core damage event (core damage and radionuclide release mitigation role).

[The following paragraph will contain plant-specific information based on the plant's ability to use the shutdown cooling system (SDCS) as a backup to the CSS. The licensee should provide a plant-specific system configuration description based on whether its SDCS can be used a backup to the CSS pump.]

The proposed CT extension also impacts the long-term cooling function

that can be provided by the SDCS following a small-break LOCA, steam generator tube rupture (SGTR), or MSLB. If entry into the 7-day CT is caused by a CSS pump outage, the plants with the ability to use the SDCS as a backup to the CSS pump can still preserve the spray function of the affected train. If, however, a SDCS heat exchanger is removed from service, then both the CSS and SDCS capability of the affected train would be lost unless cross-connect capability with another unaffected system (e.g., service water) is possible. However, this cross-connect capability should not be credited unless it is proceduralized.

The NRC staff used a three-tiered approach to evaluate the plant-specific risk impact associated with the proposed TS changes. The first tier evaluates the plant-specific PRA model and the impact of the proposed CT extension on plant operational risk. The second tier addresses the need to preclude potentially high risk configurations by identifying the need for any additional constraints or compensatory actions that, if implemented, would avoid or reduce the probability of a risk-significant configuration during the time when on CSS train is out of service. The third tier evaluates the licensee's proposed Configuration Risk Management Program (CRMP) to ensure that the applicable plant configuration will be appropriately assessed from a risk perspective before entering into, or during, the proposed CT.

In Reference 2, the NRC staff found that the risk analysis methodology and approach used by the CEOG to estimate the risk impact were reasonable. In its SE, the NRC staff also stated that, for most plants that participated in the joint application report, the risk impact can be shown to be consistent with the acceptance guidelines for change in CDF ( $\Delta$ CDF), change in LERF ( $\Delta$ LERF), incremental conditional core damage probability (ICCDP), and incremental large early release frequency (ICLERP) specified in Regulatory Guide (RG) 1.174 (Reference 3) and RG 1.177 (Reference 4) and the associated Standard Review Plan (SRP) Chapters 19.0 and 16.1 of NUREG-0800 (Reference 5). However, not all CE plants participated in the joint application report, and the estimated risk impacts for some plants exceeded the Reference 3 and/or Reference 4 acceptance guidelines, which would require additional justifications and/or compensatory measures to be provided for these plants to be determined to have acceptable risk impacts.

In Reference 2, the NRC staff also found that the Tier 2 and Tier 3 evaluations, as described in Reference 4, could not be approved generically since they were not complete from the perspective of addressing plant-specific Tier 2 and Tier 3 issues which would require that each individual plant-specific license amendment seeking approval through TSTF-409, Rev. 2 would need to include an assessment with respect to the Tier 2 and Tier 3 principles of Reference 4.

Based on the above discussion, the NRC staff identified conditions that must be addressed in the licensee's plant-specific application requesting adoption of TSTF-409, Revision 2. In its application dated [DATE], the licensee provided supporting information for each of the conditions which met the NRC staff's expectations and acceptance criteria [with the following exceptions: list any exceptions to the conditions stated in the model LAR].

[Provide a discussion of any significant plant-specific exceptions to or modifications of the conditions described in the model LAR].

#### 3.2.1 Commitment

The Reference 4 Tier 3 program ensures that, while the plant is following the TS ACTIONS associated with a 7-day CT for restoring an inoperable CSS to operable status, additional activities will not be performed that could further degrade the capabilities of the plant to respond to a condition that the inoperable CSS is designed to mitigate and, as a result, increase plant risk beyond that determined by the Reference 1 analyses. A licensee's implementation of Reference 4 Tier 3 guidelines indicates that it has assessed risk with respect to CDF. However, the proposed CSS 7-day CT impacts accident sequences that can be mitigated following core damage and, consequently, LERF as well as CDF. Therefore, the licensee enhanced its CRMP [optional: as implemented under 10 CFR 50.65(a)(4), the Maintenance Rule.] to include a LERF assessment. [The licensee should confirm that performance of LERF assessments is included in the plant's Maintenance Rule program.]

#### 3.3 Summary

On [DATE], ([ ] FR [ ]), the NRC announced the availability of TSTF-409, Rev. 2 for adoption by licensees using the consolidated line item improvement program (CLIIP). In its model license amendment request (LAR), the NRC staff asked each licensee to verify several aspects of its plant-specific PRA program including: 1)

verification of PRA quality, 2) plant-specific analyses of the impact of this TS change on overall risk, 3) Maintenance Rule and CRMP considerations associated with the proposed changes, and, 4) system interdependencies. In its [DATE] submittal, the licensee provided satisfactory information related to the eight conditions and one licensee commitments set forth in the model LAR.

Having met the conditions identified in the model LAR, the NRC staff finds that the licensee's plant-specific LAR is consistent with the previous NRC staff approval of Reference 1, as documented in Reference 2 and TSTF-409, Rev. 2, and thus is acceptable. This determination is based on the following:

1. The traditional engineering evaluation reveals that the loss of one CSS train is well within the design-basis analyses.

2. Since the licensee meets the conditions identified in the model LAR, the NRC staff finds that there is minimal impact of the CT extensions for the CSS system on plant operational risk (Tier 1 evaluation).

3. Meeting the conditions identified in the model LAR will ensure that the licensee's implementation will identify potentially high risk configurations and the need for any additional constraints or compensatory actions that, if implemented, would avoid or reduce the probability of a risk-significant configuration (Tier 2 evaluation).

4. Meeting the conditions identified in the model LAR will ensure that the risk-informed CRMP proposed by the licensee will satisfactorily assess the risk associated with the removal of equipment from service during the proposed CSS CT (Tier 3 evaluation) and the CRMP and plant risk will be managed by plant procedures.

#### 4.0 Regulatory Commitment

The licensee's letter dated [DATE], contained the following regulatory commitment: [STATE THE LICENSEE'S COMMITMENT AND ENSURE THAT IT SATISFIES THE COMMITMENT IN SECTION 3.2.1 OF THIS SE].

The NRC staff finds that reasonable controls for the implementation and for subsequent evaluation of proposed changes pertaining to the above regulatory commitment are best provided by the licensee's administrative controls process, including its commitment management program. The above regulatory commitment does not warrant the creation of a license condition (item requiring prior NRC approval of subsequent changes).

## 5.0 State Consultation

In accordance with the Commission's regulations, the [STATE] State official was notified of the proposed issuance of the amendment[s]. The State official had [CHOOSE ONE: (1) No comments, OR (2) the following comments—with subsequent disposition by the staff].

## 6.0 Environmental Consideration

The amendment changes a requirement with respect to the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding [(XX FR XXXXX, dated Monthly DD, YYYY)]. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

## 7.0 Conclusion

The Commission has concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

## 8.0 References

1. *Joint Applications Report: Modification to the Containment Spray System, and Low Pressure Safety Injection System Technical*, CE Owners Group, CE NPSD-1045, March 2000.
2. SE by the Office of Nuclear Reactor Regulation Related to CE Owners Group CE-NPSD-1045, "Joint Application Report, Modification to the Containment Spray System, and the Low Pressure Safety Injection System Technical Specifications," December 21, 1999.
3. U.S. NRC RG 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis," Revision 1, November 2002.

4. U.S. NRC RG 1.177, "An Approach for Plant-Specific, Risk-Informed Decisionmaking: Technical Specifications," August 1998.
5. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," June 1996.

### *Model No Significant Hazards Consideration*

*Description of Amendment Request:* The proposed amendment would revise the technical specifications to extend the completion time (CT) from 72 hours to seven days to restore an inoperable containment spray system (CSS) train to operable status, and add a Condition describing the required Actions and CT when one CSS and one containment cooling system (CCS) are inoperable.

*Basis for proposed no significant hazards consideration determination:* As required by 10 CFR 50.91(a), an analysis of the issue of no significant hazards consideration is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

*Response:* No.

The proposed change extends from 72 hours to 7 days the CT for restoring an inoperable CSS train to operable status. Being in an ACTION is not an initiator of any accident previously evaluated. Consequently, the probability of an accident previously evaluated is not significantly increased. The consequences of an accident while relying on ACTIONS during the 7-day CT are no different than the consequences of an accident while relying on the ACTION during the existing 72-hour CT. Therefore, the consequences of an accident previously evaluated are not significantly increased by this change. Therefore, this change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the change create the possibility of a new or different kind of accident from any accident previously evaluated?

*Response:* No.

The proposed change extends from 72 hours to 7 days the CT for restoring an inoperable CSS train to operable status. The proposed change does not involve a physical alteration of the plant (no new or different type of equipment will be installed) or a change in the methods governing normal plant operation. Thus, this change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

*Response:* No.

The proposed change extends from 72 hours to 7 days the CT for restoring an inoperable CSS train to operable status. The licensee performed risk-based evaluations using its plant-specific probabilistic risk assessment (PRA) model in order to determine the effect of this change on plant risk. The PRA evaluations were based on the conditions stipulated in NRC staff safety evaluations approving both Joint Applications Report CE NPSD-1045-A, "Joint Applications Report, Modifications to the Containment Spray System and The Low Pressure Safety Injection System Technical Specifications," and Technical Specification Task Force Change Traveler, TSTF-409, Revision 2, "Containment Spray System Completion Time Extension (CE NPSD-1045-A)." The results of these plant-specific evaluations determined that the effect of the proposed change on plant risk is very small. Therefore, this change does not involve a significant reduction in a margin of safety.

Based on the above, the proposed change involves no significant hazards consideration under the standards set forth in 10 CFR 50.92(c), and accordingly, a finding of no significant hazards consideration is justified.

Dated at Rockville, Maryland, this XX day of XXXXXXXX, 2006.

FOR THE NUCLEAR REGULATORY COMMISSION  
Project Manager  
Plant Licensing Branch [ ]  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

[FR Doc. 06-9094 Filed 11-6-06; 8:45 am]

BILLING CODE 7590-01-M

## SECURITIES AND EXCHANGE COMMISSION

### Proposed Collections; Comment Request

*Upon Written Request; Copies Available From:* Securities and Exchange Commission, Office of Filings and Information Services, Washington, DC 20549.

#### *Extensions:*

- Rule 14f-1, OMB Control No. 3235-0108, SEC File No. 270-127.
- Rule 12g3-2, OMB Control No. 3235-0119, SEC File No. 270-104.
- Rule 13e-1, OMB Control No. 3235-0305, SEC File No. 270-255.

Notice is hereby given that pursuant to the Paperwork Reduction Act of 1995