

Avenue—5th Floor, Brooklyn, New York 11201-4201
 Regional Director, Region 30, 310 West Wisconsin Avenue, Suite 700, Milwaukee, Wisconsin 53203-2211
 Regional Director, Region 31, 11150 West Olympic Boulevard, Suite 700, Los Angeles, California 90064-1824
 Regional Director, Region 32, Ronald V. Dellums Federal Building and Courthouse, 1301 Clay Street, Suite 300N, Oakland, California 94612-5211
 Regional Director, Region 34, 280 Trumbull Street, 21st Floor, Hartford, Connecticut 06103-3503

[FR Doc. 06-9683 Filed 12-12-06; 8:45 am]

BILLING CODE 7545-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-263]

Nuclear Management Company, LLC; Monticello Nuclear Generating Plant; Exemption

1.0 Background

Nuclear Management Company, LLC (the licensee), is the holder of Facility Operating License No. DPR-22 which authorizes operation of Monticello Nuclear Generating Plant (MNGP). The license provides, among other things, that the facility is subject to all rules, regulations, and orders of the U.S. Nuclear Regulatory Commission (NRC, the Commission) now or hereafter in effect.

The facility consists of a boiling-water reactor located in Wright County in Minnesota.

2.0 Request/Action

Appendix J to Title 10 of the Code of Federal Regulations (10 CFR) specifies the leakage rate test requirements, schedules, and acceptance criteria for tests of the leak-tight integrity of the primary reactor containment and systems and components that penetrate the containment. Option B, Paragraph III.A, of Appendix J requires that the overall integrated leakage rate must not exceed the allowable leakage (La) with margin, as specified in the plant's Technical Specifications. The overall integrated leakage rate, as specified in Appendix J, includes the contribution from main steam pathway leakage (*i.e.*, through the four main steam lines and the main steam drain line at MNGP). Option B, Paragraph III.B requires that the sum of the leakage rates of Type B and Type C local leakage rate tests be less than the performance criterion (La)

with margin, as specified in the Technical Specifications.

By letter dated September 15, 2005, the licensee requested exemption from Option B, Section III.A, requirements to exclude main steam isolation valve (MSIV) leakage from the overall integrated leak rate test measurement, and exemption from Section III.B requirements to exclude the MSIV leakage from the sum of the Type B and Type C tests. The licensee stated that the MNGP MSIV leakage effluent has a different pathway to the environment when compared to a typical containment penetration, *i.e.*, it is not directed into the secondary containment and filtered through the standby gas treatment system. Instead, the main steam leakage is collected and treated via an alternative leakage treatment pathway, having different mitigation characteristics.

In performing accident analyses, it is appropriate to group various leakage effluents according to the treatment they receive before being released to the environment (*e.g.*, from main steam pathways). Accordingly, the licensee's proposed exemption from the Appendix J requirements would more appropriately reflect the MNGP design which employs an alternative leakage treatment pathway. The calculated radiological consequences of the combined leakages were found to be within the criteria of 10 CFR 50.67 and GDC-19. The NRC staff reviewed the licensee's analyses and found them acceptable as described in a safety analysis accompanying an amendment regarding alternative source term methodology to be issued concurrently with this exemption. By separating the MSIV leakage acceptance criteria from the overall integrated leak rate test criteria, and from the Type B and C leakage sum limitation, the MNGP containment leakage testing program will be made more consistent with the limiting assumptions used in the associated accident consequences analyses. The amendment associated with this exemption will revise Technical Specification Surveillance Requirement 3.6.1.3.13 to limit the maximum allowable combined MSIV leakage to 200 standard cubic feet per hour, which is the analytical limit.

Based on the foregoing, the separation of the main steam pathways from the other containment leakage pathways is warranted because a separate radiological consequence term has been provided for these pathways. The revised design basis radiological consequence analyses address these pathways as individual factors,

exclusive of the primary containment leakage.

3.0 Discussion

Pursuant to 10 CFR 50.12, the Commission may, upon application by any interested person or upon its own initiative, grant exemptions from the requirements of 10 CFR Part 50 when (1) The exemptions are authorized by law, will not present an undue risk to public health or safety, and are consistent with the common defense and security; and (2) when special circumstances are present. The licensee's exemption request was submitted in conjunction with an amendment application to employ the alternative source term (AST) methodology for design-basis accidents. The NRC staff had completed its review and is issuing the proposed amendment on the same date as this exemption. The exemption and amendment together would implement the AST methodology. The special circumstances associated with MSIV leakage testing are fully described in the licensee's September 15, 2005, application for amendment and exemption.

Authorized by Law

This exemption would exempt Nuclear Management Company from requirements in 10 CFR Part 50, Appendix J, thus (1) Excluding MSIV leakage in the overall integrated leakage rate test measurement required by Section III. A of Appendix J, Option B; and (2) excluding the sum of local leak rate test measurements required by Section III.B of Appendix J, Option B. As stated above, 10 CFR 50.12 allows the NRC to grant exemptions from the requirements of 10 CFR Part 50. The NRC staff has determined that granting of the licensee's proposed exemption will not result in a violation of the Atomic Energy Act of 1954, as amended, or the Commission's regulations. Therefore, the exemption is authorized by law.

No Undue Risk to Public Health and Safety

The proposed exemption affects only the radiological dose analysis models and the way containment leak-tightness is measured. No new accident precursors are created by the exemption; accordingly, the probability of postulated accidents is not increased and the consequences of postulated accidents are not increased. Therefore, there is no undue risk to public health and safety as a result of the exemption.

Consistent With Common Defense and Security

The proposed exemption, as set forth above, would only affect the radiological dose analysis models and the way containment leak-tightness is measured. Thus, this exemption bears no relation to security issues. Therefore, the common defense and security is not impacted by this exemption.

Special Circumstances

Special circumstances, in accordance with 10 CFR 50.12(a)(2)(ii), are present whenever application of the regulation in the particular circumstances “would not serve the underlying purpose of the rule or is not necessary to achieve the underlying purpose of the rule.” The underlying purpose of Appendix J is to assure that containment leak-tight integrity is maintained as tight as reasonably achievable, and sufficiently tight so as to limit effluent release to values bounded by the analyses of radiological consequences of design-basis accidents. The NRC staff has determined that the intent of the rule is not compromised by the licensee’s proposed action because containment leak rates will continue to be limited by MNGP’s Technical Specifications. Therefore, since the underlying purpose of Appendix J is achieved, the special circumstances required by 10 CFR 50.12(a)(2) for the granting of an exemption from Appendix J exist.

4.0 Conclusion

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12, the exemption is authorized by law, will not present an undue risk to public health and safety, and is consistent with the common defense and security. Also, special circumstances are present. Therefore, the Commission hereby grants MNGP an exemption (1) From the requirements of 10 CFR Part 50, Appendix J, Option B, Paragraph III.A, to allow exclusion of the main steam pathway leakage from the overall integrated leakage rate measured when performing a Type A test; and (2) from the requirements of 10 CFR Part 50, Appendix J, Option B, Paragraph III.B, to allow exclusion of the main steam pathway leakage from the combined leakage rate of all penetrations and valves subject to Type B and C tests.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (71 FR 70996).

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 7th day of December, 2006.

For the Nuclear Regulatory Commission.

Cathy Haney,

Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. E6-21152 Filed 12-12-06; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION**Licensing Support System Advisory Review Panel**

AGENCY: U. S. Nuclear Regulatory Commission.

ACTION: Notice of renewal of the charter of the Licensing Support Network Advisory Review Panel (LSNARP).

SUMMARY: The Licensing Support System Advisory Review Panel was established by the U.S. Nuclear Regulatory Commission as a Federal Advisory Committee in 1989. Its purpose was to provide advice on the fundamental issues of design and development of an electronic information management system to be used to store and retrieve documents relating to the licensing of a geologic repository for the disposal of high-level radioactive waste, and on the operation and maintenance of the system. This electronic information management system was known as the Licensing Support System (LSS). In November, 1998 the Commission approved amendments to 10 CFR Part 2 that renamed the Licensing Support System Advisory Review Panel as the Licensing Support Network Advisory Review Panel.

Membership on the Panel continues to be drawn from those interests that will be affected by the use of the LSN, including the Department of Energy, the NRC, the State of Nevada, the National Congress of American Indians, affected units of local governments in Nevada, the Nevada Nuclear Waste Task Force, and a coalition of nuclear industry groups. Federal agencies with expertise and experience in electronic information management systems may also participate on the Panel.

The Nuclear Regulatory Commission has determined that renewal of the charter for the LSNARP until December 6, 2008 is in the public interest in connection with duties imposed on the Commission by law. This action is being taken in accordance with the Federal Advisory Committee Act after consultation with the Committee Management Secretariat, General Services Administration.

FOR FURTHER INFORMATION CONTACT:

Andrew L. Bates, Office of the Secretary, U.S. Nuclear Regulatory Commission, Washington, DC 20555; Telephone 301-504-1963.

Dated: December 6, 2006.

Andrew L. Bates,

Advisory Committee Management Officer.

[FR Doc. E6-21150 Filed 12-12-06; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION**Notice of Availability of Interim Staff Guidance Documents for Spent Fuel Storage and Transportation Casks**

AGENCY: Nuclear Regulatory Commission.

ACTION: Notice of availability.

FOR FURTHER INFORMATION CONTACT:

Robert Einziger, Sr., Materials Engineer, Structural, Mechanics, and Materials Branch, Division of Spent Fuel Storage and Transportation, Office of Nuclear Material Safety and Safeguards, U.S. Nuclear Regulatory Commission, Washington, DC 20005-0001. Telephone: (301) 415-2597; fax number: (301) 415-8555; e-mail: REE1@nrc.gov.

SUPPLEMENTARY INFORMATION:**I. Introduction**

The Nuclear Regulatory Commission (NRC) prepares draft Interim Staff Guidance (ISG) documents for spent fuel storage or transportation casks or radioactive materials transportation package designs. These ISG documents provide clarifying guidance to the NRC staff when reviewing licensee integrated safety analyses, license applications or amendment requests or other related licensing. The NRC is soliciting public comments on Draft ISG-1 Rev 2, “Damaged Fuel” which will be considered in the final version or subsequent revisions.

II. Summary

The purpose of this notice is to provide the public an opportunity to review and comment on the Draft Interim Staff Guidance-1 Revision 2 concerning the definition of damaged fuel. Draft Interim Staff Guidance-1, Revision 2, provides guidance to NRC staff on what documents should be reviewed and evaluated to ensure that damaged fuel is sufficiently defined to determine if it meets all regulatory functions. Additionally, the ISG provides a technical discussion on gross breaches, a methodology for defining damaged fuel in terms of its function,