

Point of contact for this initiative is Sandra Morris (202) 358-0532, [Sandra.Morris@nasa.gov](mailto:Sandra.Morris@nasa.gov).

**William McNally,**

*Assistant Administrator for Procurement.*

[FR Doc. 2012-3185 Filed 2-9-12; 8:45 am]

**BILLING CODE 7510-01-P**

## NATIONAL ARCHIVES AND RECORDS ADMINISTRATION

### Public Availability of the National Archives and Records Administration FY 2011 Service Contract Inventory

**AGENCY:** National Archives and Records Administration.

**ACTION:** Notice of public availability of FY 2011 Service Contract Inventory.

**SUMMARY:** In accordance with Section 743 of Division C of the Consolidated Appropriations Act of 2010 (Pub. L. 111-117), the National Archives and Records Administration (NARA) is publishing this notice to advise the public of the availability of its FY 2011 Service Contract inventory. This inventory provides information on service contract actions over \$25,000 that were made in FY 2011. The information is organized by function to show how contracted resources are distributed throughout the agency. The inventory has been developed in accordance with guidance issued on November 5, 2010 by the Office of Management and Budget's Office of Federal Procurement Policy (OFPP). OFPP's guidance is available at <http://www.whitehouse.gov/sites/default/files/omb/procurement/memo/service-contract-inventories-guidance-11052010.pdf>. NARA has posted its inventory and a summary of the inventory on the NARA homepage at the

following link: <http://www.archives.gov/contracts/>.

#### FOR FURTHER INFORMATION CONTACT:

Robert Singman, Deputy Director Acquisitions Division, National Archives and Records Administration, 8601 Adelphi Road, College Park, MD 20740-6001. Telephone: 301-837-0712. Email: [Robert.singman@nara.gov](mailto:Robert.singman@nara.gov).

Dated: February 3, 2012.

**Charles K. Piercy,**

*Executive Business Support Services.*

[FR Doc. 2012-3078 Filed 2-9-12; 8:45 am]

**BILLING CODE 7515-01-P**

## NUCLEAR REGULATORY COMMISSION

[Docket No. 50-247]

### Entergy Nuclear Indian Point 2, LLC; Entergy Nuclear Operations, Inc.; Indian Point Nuclear Generating Unit No. 2; Exemption

#### 1.0 Background

Entergy Nuclear Operations, Inc. (Entergy or the licensee) is the holder of Facility Operating License No. DPR-026, which authorizes operation of Indian Point Nuclear Generating Unit No. 2 (IP2). The license provides, among other things, that the facility is subject to all rules, regulations, and orders of the U.S. Nuclear Regulatory Commission (NRC or the Commission) now or hereafter in effect.

IP2 is a pressurized-water reactor located approximately 24 miles north of the New York City boundary line on the east bank of the Hudson River in Westchester County, New York.

#### 2.0 Request/Action

Title 10 of the Code of Federal Regulations (10 CFR) part 50, Section 50.48(b), requires that nuclear power

plants that were licensed to operate before January 1, 1979, satisfy the requirements of 10 CFR part 50, Appendix R, "Fire Protection Program for Nuclear Power Facilities Operating Prior to January 1, 1979," Section III.G, "Fire protection of safe shutdown capability." The circuit separation and protection requirements being addressed in this request for exemption are specified in Section III.G.2. Since IP2 was licensed to operate before January 1, 1979, IP2 is required to meet Section III.G.2 of Appendix R to 10 CFR part 50.

The underlying purpose of Section III.G of Appendix R to 10 CFR part 50 is to establish reasonable assurance that safe shutdown (SSD) of the reactor can be achieved and maintained in the event of a postulated fire in any plant area. Circuits which could cause maloperation or prevent operation of redundant trains of equipment required to achieve and maintain hot shutdown conditions as a result of fire in a single fire area must be protected in accordance with III.G.2. If conformance with the technical requirements of III.G.2 cannot be assured in a specific fire area, an alternative or dedicated shutdown capability must be provided in accordance with Section III.G.3, or an exemption obtained in accordance with 10 CFR 50.12, "Specific exemptions."

By letter dated March 6, 2009, Entergy requested an exemption from the requirements of 10 CFR part 50, Appendix R, in accordance with 10 CFR 50.12. Specifically, Entergy requested an exemption to allow the use of Operator Manual Actions (OMAs) in lieu of meeting certain technical requirements of III.G.2 in Fire Areas C, F, H, J, K, P, and YD of IP2. The table below provides the dates and topics of the submittals related to this request.

Subject	Author	Date	Description	ADAMS Accession
Exemption Request from Appendix R.	Entergy .....	March 6, 2009 .....	Original Submittal .....	ML090770151.
Revised Exemption Request.	Entergy .....	October 1, 2009 .....	Revision to March 2009 submittal, incorporated changes to Attachment 2, <i>Technical Basis in Support of Exemption Request</i> .	ML092810231
Request for Additional Information (RAI) #1.	NRC .....	January 20, 2010 .....	Request for information on the overall defense-in-depth for each fire zone..	ML100150128
RAI Response #1 .....	Entergy .....	May 4, 2010 .....	Response to the staff's January 20, 2010, RAI.	ML101320230
RAI #2 .....	NRC .....	August 11, 2010 .....	RAI on reactor coolant system makeup, separation distances, <i>etc</i> .	ML102180331
RAI Response #2 .....	Entergy .....	September 29, 2010 ....	Response to the staff's August 11, 2010, RAI ..	ML102930237
RAI #3 .....	NRC .....	December 16, 2010 .....	RAI on reactor coolant system makeup .....	ML103500204
RAI Response #3 .....	Entergy .....	January 19, 2011 .....	Responses to the staff's December 16, 2010, RAI.	ML110310013
Letter to revise previously submitted information.	Entergy .....	February 10, 2011 .....	Letter updating tables contained in previous submittals.	ML110540321