

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <http://ehd1.nrc.gov/ehd/>, unless excluded pursuant to an order of the Commission, or the presiding officer. Participants are requested not to include personal privacy information, such as social security numbers, home addresses, or home phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

Petitions for leave to intervene must be filed no later than 60 days from the date of publication of this notice. Non-timely filings will not be entertained absent a determination by the presiding officer that the petition or request should be granted or the contentions should be admitted, based on a balancing of the factors specified in 10 CFR 2.309(c)(1)(i)-(viii).

For further details with respect to this license amendment application, see the application for amendment dated December 5, 2011, which is available for public inspection at the Commission's PDR, located at One White Flint North, File Public Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available documents created or received at the NRC are accessible electronically through ADAMS in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov.

Attorney for licensee: Lara S. Nichols, Associate General Counsel, Duke Energy Corporation, 526 South Church Street—EC07H, Charlotte, NC 28202.

Dated at Rockville, Maryland, this 1st day of August 2012.

For the Nuclear Regulatory Commission.

Jon H. Thompson,

Project Manager, Plant Licensing Branch II-1, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2012-19540 Filed 8-8-12; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Advisory Committee on Reactor Safeguards (ACRS); Meeting of the ACRS Subcommittees on Reliability and PRA and Fukushima; Revision to Notice of Meetings

The (ACRS) Subcommittee on Fukushima originally scheduled for the afternoon of August 14, 2012, has been moved to the morning of August 15, 2012, 8:30 a.m. until 12 p.m.

The ACRS Subcommittee on Reliability and PRA which was to be held on August 15, 2012, Room T-2B1, 11545 Rockville Pike, Rockville, Maryland has been cancelled.

These notices were previously published in the **Federal Register** on Wednesday, August 1, 2012 (77 FR 45698-45699).

Further information regarding these meetings can be obtained by contacting the Designated Federal Official (DFO), Derek Widmayer (Telephone 301-415-7366 or Email: Derek.Widmayer@nrc.gov) between 8:15 a.m. and 5 p.m.

Dated: August 1, 2012.

Cayetano Santos,

Chief, Technical Support Branch, Advisory Committee on Reactor Safeguards.

[FR Doc. 2012-19548 Filed 8-8-12; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-293; License No. DPR-35; NRC-2012-0186]

Entergy Nuclear Operations, Inc.; Pilgrim Nuclear Power Station Receipt of Request for Action

Notice is hereby given that by petition dated July 19, 2010, as supplemented by letter dated August 6, 2010, Ms. Mary Lampert (the Petitioner) has requested that pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) 2.206, "Requests for Action under this Subpart," the U.S. Nuclear Regulatory Commission (NRC or the Commission) take action with regard to the Pilgrim Nuclear Power Station (Pilgrim). The Petitioner requested that the NRC take the following actions: (1) Issue a Demand for Information Order requiring that Entergy Nuclear Operations, Inc. (Entergy or the licensee) demonstrate that all inaccessible cables at Pilgrim are capable of performing their required function, be it safety- or nonsafety-related, (2) certify that the location, age, and repair history of all cables (accessible and inaccessible) have been identified, (3) ensure that the licensee

monitors all cables before continued operation to demonstrate that the cables can perform their design functions, (4) ensure that the licensee incorporates in its monitoring program, at a minimum, recommendations for certain aging management guidelines and NRC generic guidance, (5) commit to verifying, during the license renewal period, Entergy's implementation through routine baseline inspections, and (6) commit to a timely upgrade of the regulatory guidance for maintaining cable qualification and the verification that the cables can perform their design functions.

The NRC's Petition Review Board initially met on November 4, 2010, and later reconvened on June 4, 2012, considered the petition, including all supplemental information provided as previously described, and made a final recommendation to accept the petition for review, in part. The following specific issues and concerns identified in the July 19, 2010, petition and/or supplemented during the teleconferences meet the criteria for review under 10 CFR 2.206, and are being accepted for review:

(1) NRC regulations require that plant owners ensure that electrical wiring is qualified to perform in the environmental conditions experienced during normal operation and during accidents. Pilgrim has no program today as required by NRC regulations to ensure operability of the submerged and/or wetted wires.

(2) Most electrical cables at Pilgrim have been exposed to significant moisture over the past 40 years since initial construction. The wires and possibly the connections and splices inside conduits are designed to operate properly only in a dry environment and not designed to operate in a moist or wet environment; thus, there is no assurance that they will not fail if wet or submerged or previously exposed to moisture.

(3) Wires degrade with age, and the oldest wires are the most susceptible to degradation. Pilgrim is one of the oldest operating commercial reactors in the country, and the majority of the conduits and wires at Pilgrim were installed during the initial construction. There are no existing methods to ensure operability, short of visual inspection and/or replacement with cables designed to operate in a wet or submerged environment.

(4) As identified in several pertinent sections of Pilgrim's license renewal application and the safety evaluation report, Pilgrim's aging management program, for the period 2012-2032, is