

temporary items). Master files of an electronic information system containing information on explosive devices used for reference purposes by the Explosive Ordnance Disposal community of the Armed Services.

10. Department of State, Bureau of Diplomatic Security (DAA-0059-2011-0010, 3 items, 3 temporary items). Investigative case files of criminal and administrative misconduct involving personnel, contractors, and dependents at posts abroad and administrative misconduct by Department employees and contractors domestically. Also included are master files of an electronic information system that provides case tracking and management of information related to investigative cases.

11. Department of the Treasury, Internal Revenue Service (N1-58-11-1, 8 items, 8 temporary items). Master files, outputs, and documentation for an electronic system used to administer a low-income housing program. Also includes forms and other administrative records from this program.

12. National Oceanic and Atmospheric Administration, National Marine Fisheries Service (N1-370-12-2, 2 items, 2 temporary items). Master files of an electronic information system used to track appeals. Also includes appeals case files.

13. National Oceanic and Atmospheric Administration, National Environmental Satellite, Data and Information Services (DAA-0370-2012-0001, 1 item, 1 temporary item). Non-disclosure agreements that prohibit unauthorized disclosure of information related to satellite systems and vendors.

Paul M. Wester, Jr.,
Chief Records Officer for the U.S.
Government.

[FR Doc. 2012-21713 Filed 8-31-12; 8:45 am]

BILLING CODE 7515-01-P

NATIONAL SCIENCE FOUNDATION

Notice of Permits Issued Under the Antarctic Conservation Act of 1978

AGENCY: National Science Foundation.

ACTION: Notice of permits cancelled under the Antarctic Conservation Act of 1978, Public Law 95-541.

SUMMARY: The National Science Foundation (NSF) is required to publish notice of permits cancelled under the Antarctic Conservation Act of 1978. This is the required notice.

FOR FURTHER INFORMATION CONTACT: Nadene G. Kennedy, Permit Office, Office of Polar Programs, Rm. 755,

National Science Foundation, 4201 Wilson Boulevard, Arlington, VA 22230.

SUPPLEMENTARY INFORMATION: The permits were issued to Raytheon Polar Services Company (RPSC), the civilian support contractor to the National Science Foundation's Office of Polar Programs. On March 31, 2012, the contract expired and a new civilian support contractor, Lockheed Martin, Antarctic Support Contract took over on April 1, 2012. Effective on August 30, 2012, the following Raytheon Permits will be cancelled:

Permit No. 2012-009

Permit No. 2011-008

Permit No. 2011-009

Permit No. 2011-010

Permit No. 2011-011

Permit No. 2011-012

Permit No. 2011-013

Permit No. 2011-014

Permit No. 2011-015

Lockheed Martin has been issued some permits to replace those held by the previous support contractor. A notice of permits issued was published in the **Federal Register** on August 21, 2012.

Nadene G. Kennedy,
Permit Officer.

[FR Doc. 2012-21609 Filed 8-31-12; 8:45 am]

BILLING CODE 7555-01-P

NUCLEAR REGULATORY COMMISSION

[NRC-2012-0205]

Biweekly Notice;

Applications and Amendments to Facility Operating Licenses and Combined Licenses Involving No Significant Hazards Considerations

Background

Pursuant to Section 189a. (2) of the Atomic Energy Act of 1954, as amended (the Act), the U.S. Nuclear Regulatory Commission (the Commission or NRC) is publishing this regular biweekly notice. The Act requires the Commission publish notice of any amendments issued, or proposed to be issued and grants the Commission the authority to issue and make immediately effective any amendment to an operating license or combined license, as applicable, upon a determination by the Commission that such amendment involves no significant hazards consideration, notwithstanding the pendency before the Commission of a request for a hearing from any person.

This biweekly notice includes all notices of amendments issued, or

proposed to be issued from August 8, 2012, to August 21, 2012. The last biweekly notice was published on August 21, 2012, (77 FR 50534).

ADDRESSES: You may access information and comment submissions related to this document, which the NRC possesses and are publicly available, by searching on <http://www.regulations.gov> under Docket ID NRC-2012-0205.

You may submit comments by any of the following methods:

- **Federal rulemaking Web site:** Go to <http://www.regulations.gov> and search for Docket ID NRC-2012-0205. Address questions about NRC dockets to Carol Gallagher; telephone: 301-492-3668; email: Carol.Gallagher@nrc.gov.

- **Mail comments to:** Cindy Bladey, Chief, Rules, Announcements, and Directives Branch (RADB), Office of Administration, Mail Stop: TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

- **Fax comments to:** RADB at 301-492-3446.

For additional direction on accessing information and submitting comments, see "Accessing Information and Submitting Comments" in the **SUPPLEMENTARY INFORMATION** section of this document.

SUPPLEMENTARY INFORMATION:

I. Accessing Information and Submitting Comments

A. Accessing Information

Please refer to Docket ID NRC-2012-0205 when contacting the NRC about the availability of information regarding this document. You may access information related to this document, which the NRC possesses and is publicly available, by the following methods:

- **Federal Rulemaking Web Site:** Go to <http://www.regulations.gov> and search for Docket ID NRC-2012-0205.

- **NRC's Agencywide Documents Access and Management System (ADAMS):** You may access publicly available documents online in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. Documents may be viewed in ADAMS by performing a search on the document date and docket number.

- **NRC's PDR:** You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One

White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments

Please include Docket ID NRC–2012–0205 in the subject line of your comment submission, in order to ensure that the NRC is able to make your comment submission available to the public in this docket.

The NRC cautions you not to include identifying or contact information in comment submissions that you do not want to be publicly disclosed. The NRC posts all comment submissions at <http://www.regulations.gov> as well as entering the comment submissions into ADAMS, and the NRC does not edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information in their comment submissions that they do not want to be publicly disclosed. Your request should state that the NRC will not edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment submissions into ADAMS.

Notice of Consideration of Issuance of Amendments to Facility Operating Licenses and Combined Licenses, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing

The Commission has made a proposed determination that the following amendment requests involve no significant hazards consideration. Under the Commission's regulations in section 50.92 of Title 10 of the Code of Federal Regulations (10 CFR), this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. The basis for this proposed determination for each amendment request is shown below.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of

publication of this notice. The Commission may issue the license amendment before expiration of the 60-day period provided that its final determination is that the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment period should circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example in derating or shutdown of the facility. Should the Commission take action prior to the expiration of either the comment period or the notice period, it will publish in the **Federal Register** a notice of issuance. Should the Commission make a final No Significant Hazards Consideration Determination, any hearing will take place after issuance. The Commission expects that the need to take this action will occur very infrequently.

Within 60 days after the date of publication of this notice, any person(s) whose interest may be affected by this action may file a request for a hearing and a petition to intervene with respect to issuance of the amendment to the subject facility operating license or combined license. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested person(s) should consult a current copy of 10 CFR 2.309, which is available at the NRC's PDR, located at One White Flint North, Room O1–F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. The NRC regulations are accessible electronically from the NRC Library on the NRC's Web site at <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or a presiding officer designated by the Commission or by the Chief Administrative Judge of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the Chief Administrative Judge of the Atomic Safety and Licensing Board will issue a notice of a hearing or an appropriate order.

As required by 10 CFR 2.309, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the

following general requirements: (1) The name, address, and telephone number of the requestor or petitioner; (2) the nature of the requestor's/petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the requestor's/petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the requestor's/petitioner's interest. The petition must also identify the specific contentions which the requestor/petitioner seeks to have litigated at the proceeding.

Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the requestor/petitioner shall provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the requestor/petitioner intends to rely in proving the contention at the hearing. The requestor/petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the requestor/petitioner intends to rely to establish those facts or expert opinion. The petition must include sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the requestor/petitioner to relief. A requestor/petitioner who fails to satisfy these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held

would take place before the issuance of any amendment.

All documents filed in the NRC adjudicatory proceedings, including a request for hearing, a petition for leave to intervene, any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities participating under 10 CFR 2.315(c), must be filed in accordance with the NRC E-Filing rule (72 FR 49139; August 28, 2007). The E-Filing process requires participants to submit and serve all adjudicatory documents over the Internet, or in some cases to mail copies on electronic storage media. Participants may not submit paper copies of their filings unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by email at hearing.docket@nrc.gov, or by telephone at 301-415-1677, to request (1) a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign documents and access the E-Submittal server for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a request or petition for hearing (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals/apply-certificates.html>. System requirements for accessing the E-Submittal server are detailed in the NRC's "Guidance for Electronic Submission," which is available on the agency's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>. Participants may attempt to use other software not listed on the Web site, but should note that the NRC's E-Filing system does not support unlisted software, and the NRC Meta System Help Desk will not be able to offer assistance in using unlisted software.

If a participant is electronically submitting a document to the NRC in accordance with the E-Filing rule, the

participant must file the document using the NRC's online, Web-based submission form. In order to serve documents through the Electronic Information Exchange System, users will be required to install a Web browser plug-in from the NRC's Web site. Further information on the Web-based submission form, including the installation of the Web browser plug-in, is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>.

Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then submit a request for hearing or petition for leave to intervene. Submissions should be in Portable Document Format (PDF) in accordance with NRC guidance available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>. A filing is considered complete at the time the documents are submitted through the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email notice confirming receipt of the document. The E-Filing system also distributes an email notice that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the documents on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before a hearing request/petition to intervene is filed so that they can obtain access to the document via the E-Filing system.

A person filing electronically using the agency's adjudicatory E-Filing system may seek assistance by contacting the NRC Meta System Help Desk through the "Contact Us" link located on the NRC's Web site at <http://www.nrc.gov/site-help/e-submittals.html>, by email at MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Meta System Help Desk is available between 8 a.m. and 8 p.m., Eastern Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing requesting authorization to

continue to submit documents in paper format. Such filings must be submitted by: (1) First class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, Sixteenth Floor, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, Attention: Rulemaking and Adjudications Staff. Participants filing a document in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <http://ehd1.nrc.gov/ehd/>, unless excluded pursuant to an order of the Commission, or the presiding officer. Participants are requested not to include personal privacy information, such as Social Security numbers, home addresses, or home phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

Petitions for leave to intervene must be filed no later than 60 days from the date of publication of this notice. Non-timely filings will not be entertained absent a determination by the presiding officer that the petition or request should be granted or the contentions should be admitted, based on a balancing of the factors specified in 10 CFR 2.309(c)(1)(i)-(viii).

For further details with respect to this license amendment application, see the application for amendment which is available for public inspection at the NRC's PDR, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. Publicly available documents created or received at the NRC are

accessible electronically through ADAMS in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's PDR Reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov.

Calvert Cliffs Nuclear Power Plant, LLC, Docket Nos. 50-317 and 50-318, Calvert Cliffs Nuclear Power Plant, Units 1 and 2, Calvert County, Maryland

Date of amendments request: July 2, 2012.

Description of amendments request: The amendment would revise Technical Specification (TS) 5.5.16 by increasing the calculated peak containment internal pressure (P_a) from 49.4 pounds per square inch gauge (psig) to 49.7 psig for the design basis loss-of-coolant accident (LOCA). In support of the revised P_a , the amendment would also revise the initial internal containment pressure limit in TS 3.6.4 by decreasing the upper bound initial pressure limit from 1.8 psig to 1.0 psig.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed change to P_a and the initial containment pressure limit does not alter the assumed initiators to any analyzed event. The probability of an accident previously evaluated will not be increased by this proposed change. The change in P_a and the initial containment pressure limit will not affect radiological dose consequence analyses. The radiological dose consequence analyses assume a certain containment atmosphere leak rate based on the maximum allowable containment leakage rate, which is not affected by the change in P_a . The Title 10 of the Code of Federal Regulations (10 CFR) Part 50, Appendix J containment leak rate testing program will continue to ensure that containment leakage remains within the leakage assumed in the offsite dose consequence analyses.

Therefore, operation of the facility in accordance with the proposed change to TSs 3.6.4 and 5.5.16 will not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different type of accident from any accident previously evaluated?

Response: No.

The proposed change provides a higher P_a than currently described in the TS. This change is a result of an increase in the mass and energy release input for the LOCA containment response analysis. The P_a remains below the containment design pressure of 50 psig because of the change in the initial containment pressure limit, which is an initial condition of the peak pressure calculation. This change does not involve any alteration in the plant configuration, no new or different type of equipment will be installed, or make changes in the methods governing normal plant operation.

Therefore, operation of the facility in accordance with the proposed change to TSs 3.6.4 and 5.5.16 would not create the possibility of a new or different kind of accident from any previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

The P_a remains below the containment design pressure of 50 psig. Since the radiological consequence analyses are based on the maximum allowable containment leakage rate, which is not being revised, the change in the calculated peak containment pressure does not represent a significant change in the margin of safety.

Therefore, operation of the facility in accordance with the proposed change to TSs 3.6.4 and 5.5.16 does not involve a significant reduction in the margin of safety.

The Nuclear Regulatory Commission (NRC) staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendments request involves no significant hazards consideration.

Attorney for licensee: Steven L. Miller, General Counsel, Constellation Energy Nuclear Group, LLC, 100 Constellation Way, Suite 200c, Baltimore, MD 21202.

NRC Branch Chief: George Wilson.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit 2, New London County, Connecticut

Date of amendment request: July 31, 2012.

Description of amendment request: The proposed amendment would revise the Millstone Power Station, Unit 2 (MPS2) Technical Specification requirements regarding steam generator tube inspections and reporting as described in TSTF-510, Revision 2, "Revision to Steam Generator Program Inspection Frequencies and Tube Sample Selection;" however, Dominion Nuclear Connecticut, Inc. is proposing minor variations and deviations from TSTF-510.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the

issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed change revises the Steam Generator (SG) Program to modify the frequency of verification of SG tube integrity and SG tube sample selection. A steam generator tube rupture (SGTR) event is one of the design basis accidents that are analyzed as part of a plant's licensing basis. The proposed SG tube inspection frequency and sample selection criteria will continue to ensure that the SG tubes are inspected such that the probability of a SGTR is not increased. The consequences of a SGTR are bounded by the conservative assumptions in the design basis accident analysis. The proposed change will not cause the consequences of a SGTR to exceed those assumptions. The proposed change to reporting requirements and clarifications of the existing requirements have no effect on the probability or consequences of SGTR.

Therefore, it is concluded that this change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed changes to the SG Program will not introduce any adverse changes to the plant design basis or postulated accidents resulting from potential tube degradation. The proposed change does not affect the design of the SGs or their method of operation. In addition, the proposed change does not impact any other plant system or component.

Therefore, it is concluded that this change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in the margin of safety?

Response: No.

The SG tubes in pressurized water reactors are an integral part of the reactor coolant pressure boundary and, as such, are relied upon to maintain the primary system's pressure and inventory. As part of the reactor coolant pressure boundary, the SG tubes are unique in that they are also relied upon as a heat transfer surface between the primary and secondary systems such that heat can be removed from the primary system. In addition, the SG tubes also isolate the radioactive fission products in the primary coolant from the secondary system. In summary, the safety function of a SG is maintained by ensuring the integrity of its tubes.

Steam generator tube integrity is a function of the design, environment, and the physical condition of the tube. The proposed change does not affect tube design or operating environment. The proposed change will continue to require monitoring of the

physical condition of the SG tubes such that there will not be a reduction in the margin of safety compared to the current requirements.

Therefore, it is concluded that the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Lillian M. Cuoco, Senior Counsel, Dominion Resources Services, Inc., 120 Tredegar Street, RS-2, Richmond, VA 23219.

NRC Branch Chief: George A. Wilson.

Dominion Nuclear Connecticut, Inc., Docket No. 50-423, Millstone Power Station, Unit 3, New London County, Connecticut

Date of amendment request: July 31, 2012.

Description of amendment request: The proposed amendment would revise the Millstone Power Station, Unit 3 (MPS3) Technical Specification requirements regarding steam generator tube inspections and reporting as described in TSTF-510, Revision 2, "Revision to Steam Generator Program Inspection Frequencies and Tube Sample Selection;" however, Dominion Nuclear Connecticut, Inc. is proposing minor variations and deviations from TSTF-510.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed change revises the Steam Generator (SG) Program to modify the frequency of verification of SG tube integrity and SG tube sample selection. A steam generator tube rupture (SGTR) event is one of the design basis accidents that are analyzed as part of a plant's licensing basis. The proposed SG tube inspection frequency and sample selection criteria will continue to ensure that the SG tubes are inspected such that the probability of a SGTR is not increased. The consequences of a SGTR are bounded by the conservative assumptions in the design basis accident analysis. The proposed change will not cause the consequences of a SGTR to exceed those assumptions. The proposed change to reporting requirements and clarifications of the existing requirements have no effect on the probability or consequences of SGTR.

Therefore, it is concluded that this change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed changes to the SG Program will not introduce any adverse changes to the plant design basis or postulated accidents resulting from potential tube degradation. The proposed change does not affect the design of the SGs or their method of operation. In addition, the proposed change does not impact any other plant system or component.

Therefore, it is concluded that this change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in the margin of safety?

Response: No.

The SG tubes in pressurized water reactors are an integral part of the reactor coolant pressure boundary and, as such, are relied upon to maintain the primary system's pressure and inventory. As part of the reactor coolant pressure boundary, the SG tubes are unique in that they are also relied upon as a heat transfer surface between the primary and secondary systems such that heat can be removed from the primary system. In addition, the SG tubes also isolate the radioactive fission products in the primary coolant from the secondary system. In summary, the safety function of a SG is maintained by ensuring the integrity of its tubes.

Steam generator tube integrity is a function of the design, environment, and the physical condition of the tube. The proposed change does not affect tube design or operating environment. The proposed change will continue to require monitoring of the physical condition of the SG tubes such that there will not be a reduction in the margin of safety compared to the current requirements.

Therefore, it is concluded that the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Lillian M. Cuoco, Senior Counsel, Dominion Resources Services, Inc., 120 Tredegar Street, RS-2, Richmond, VA 23219.

NRC Branch Chief: George A. Wilson.

Exelon Generation Company, LLC (EGC), Docket Nos. STN 50-456 and STN 50-457, Braidwood Station, Units 1 and 2 (Braidwood), Will County, Illinois; Docket Nos. STN 50-454 and STN 50-455, Byron Station, Units 1 and 2 (Byron), Ogle County, Illinois

Date of amendment request: June 6, 2012.

Description of amendment request: The proposed amendment would modify Braidwood and Byron Technical Specifications (TS) to add a Note to Surveillance Requirements (SR) 3.3.1.7, 3.3.1.8, and 3.3.1.12 in TS 3.3.1, "Reactor Trip System (RTS) Instrumentation," and SRs 3.3.2.2 and 3.3.2.6 in TS 3.3.2, "Engineered Safety Features Actuation System (ESFAS) Instrumentation," to exclude the Solid State Protection System input relays from the Channel Operational Test Surveillance for RTS and ESFAS Functions with installed bypass capability which the U.S. Nuclear Regulatory Commission (NRC) approved by letters dated March 30, 2012, and April 9, 2012.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The Reactor Protection System (RPS) and ESFAS provide plant protection and are part of the accident mitigating response. The RTS and ESFAS functions do not themselves act as a precursor or an initiator for any transient or design basis accident. Therefore, the proposed change does not significantly increase the probability of any accident previously evaluated.

The proposed change does not alter the design assumptions, conditions, or configuration of the facility. The structural and functional integrity of the RTS and ESFAS, and any other plant system, is unaffected. The proposed change does not alter or prevent the ability of any structures, systems, and components from performing their intended function to mitigate the consequences of an initiating event within the applicable acceptance criteria. Surveillance testing in the bypass condition will not cause any design or analysis acceptance criteria to be exceeded.

The impact of using bypass testing capability upon nuclear safety have been previously evaluated by the NRC and determined to be acceptable in [Westinghouse Atomic Power] WCAP 10271-P-A, Revision 1, WCAP 14333-P-A, Revision 1, and WCAP 15376-P-A, Revision 1. Thus, testing in bypass does not involve

a significant increase in the probability or consequences of an accident previously evaluated.

Implementation of the bypass testing capability does not affect the integrity of the fission product barriers utilized for the mitigation of radiological dose consequences as a result of an accident. The plant response as modeled in the safety analyses is unaffected by this change. Hence, the release used as input to the dose calculations are unchanged from those previously assumed.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed change does not result in a change in the manner in which the RTS and ESFAS provide plant protection. The RTS and ESFAS will continue to have the same setpoints after the proposed change is implemented. In addition, no new failure modes are being created for any plant equipment. The change does not result in the creation of any changes to the existing accident scenarios nor do they create any new or different accident scenarios. The types of accidents defined in the UFSAR [Updated Final Safety Analysis Report] continue to represent the credible spectrum of events to be analyzed which determine safe operation.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

No safety analyses are changed or modified as a result of the proposed TS change to reflect installed bypass testing capability. The proposed change does not alter the manner in which the safety limits, limiting safety system setpoints, of limiting conditions for operation are determined. Margins associated with the current applicable safety analyses acceptance criteria are unaffected. The current safety analyses remain bounding since their conclusions are not affected by performing surveillance testing in bypass. The safety systems credited in the safety analyses will continue to be available to perform their mitigation functions.

Redundant RTS and ESFAS trains are maintained, and diversity with regard of the signals that provide reactor trip and engineered safety features actuation is also maintained. All signals credited as primary or secondary, and all operator actions credited in the accident analyses will remain the same. The proposed change will not result in plant operation in a configuration outside the design basis. Although there was no attempt to quantify any positive human factors benefit due to excluding the relays from the [Channel Operational Text] COT Surveillance for those RTS and ESFAS Functions that have installed bypass test capability, it is expected that there would be

a new benefit due to a reduced potential for spurious reactor trips and actuations associated with testing.

Implementation of the proposed change is expected to result in an overall improvement of safety, as reduced testing will result in fewer inadvertent reactor trips, less frequent actuation of ESFAF components, less frequent distraction of operations personnel with significant affecting RTS and ESFAS reliability.

Therefore, the proposed change does not result in a significant reduction in the margin of safety.

Based on the above evaluation, EGC concludes that the proposed amendments do not involve a significant hazards consideration under the standards set forth in 10 CFR 50.92, (c), and, accordingly, a finding of no significant hazards consideration is justified.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the requested amendments involve no significant hazards consideration.

Attorney for licensee: Mr. Bradley J. Fewell, Associate General Counsel, Exelon Nuclear 4300 Winfield Road, Warrenville, IL 60555.

NRC Branch Chief: Michael I. Dudek, *Exelon Generation Company, LLC, and PSEG Nuclear LLC, Docket Nos. 50-277 and 50-278, Peach Bottom Atomic Power Station, Units 2 and 3, York and Lancaster Counties, Pennsylvania*

Date of application for amendments: July 18, 2012.

Description of amendment request: The proposed amendment would revise the Technical Specifications (TSs) for Peach Bottom Atomic Power Station (PBAPS), Units 2 and 3 to change the operability requirements for the normal heat sink (NHS). The NHS for PBAPS is the Susquehanna River. Currently, in accordance with TS 3.7.2, the NHS is considered operable with a maximum water temperature of 90 °F. However, TS 3.7.2 also currently contains provisions to allow plant operation to continue if the NHS water temperature exceeds the 90 °F limit. Specifically, the NHS is still considered operable as long as the NHS temperature: (1) does not exceed 92 °F and; (2) is verified at least once per hour to be less than or equal to 90 °F when averaged over the previous 24-hour period. The proposed amendment would change the NHS water temperature limit such that the NHS would be considered operable as long as the maximum water temperature was less than or equal to 92 °F.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the

licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed change allows plant operation to continue if the Normal Heat Sink (NHS) temperature does not exceed 92 °F. The water temperature limit imposed for the NHS exists to ensure the ability of safety systems to mitigate the consequences of an accident and does not involve the prevention or identification of any precursors of an accident. The water temperature of the NHS cannot adversely affect the initiator of any accident previously evaluated. This change does not affect the normal operation of the plant to the extent that any accident previously evaluated would be more likely to occur.

The safety objective of the water temperature limit for the NHS is to ensure that the heat removal capability of the Emergency Service Water (ESW) and High Pressure Service Water (HPSW) Systems is adequate to allow safety related equipment that is relied upon to mitigate the consequences of an accident or operational transient to perform its design function. The design basis heat removal capability of the affected components and systems is maintained at the NHS temperature limit, thus ensuring that the affected safety related components continuously perform their safety related function at the NHS temperature limit. The limits for equipment degradation ensure that the affected components continue to perform their design basis function. Consequently, the affected components maintain their design basis capability as previously assumed in [the] plant safety analyses.

Therefore, the proposed amendment does not involve a significant increase in the probability or consequence of a previously evaluated accident.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed change allows plant operation to continue if the Normal Heat Sink (NHS) temperature does not exceed 92 °F. The method of operation of components (heat exchangers, coolers, etc.), which rely on the NHS for cooling, is not altered by this activity. The water temperature limit imposed for the NHS exists to ensure the ability of plant safety equipment to mitigate the consequences of an accident and does not have the potential to create an accident initiator. This activity does not involve a physical change to any plant structure, system or component that is considered an accident initiator. The design basis heat removal capability of the affected components is maintained.

This license amendment request does not involve any changes to the operation, testing, or maintenance of any safety-related, or

otherwise important to safety systems. All systems important to safety will continue to be operated and maintained within their design bases.

Therefore, no new failure modes are introduced and the possibility of a new or different kind of accident is not created.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

Operation of PBAPS, Units 2 and 3 under the NHS temperature limit (92 °F) does not reduce the margin of safety as defined in the basis for any Technical Specification. Technical Specification Surveillance Requirement (SR) 3.7.2.2 defines the value for satisfying the Limiting Condition for Operation for the temperature of the NHS. A portion of the Technical Specification Bases for SR 3.7.2.2 states:

Verification of the Normal Heat Sink temperature ensures that the heat removal capability of the ESW and HPSW Systems is within the DBA [design-basis accident] analysis.

The basis for SR 3.7.2.2 has not changed as a result of the proposed [change]. The heat removal capability of the components that rely on the ESW and HPSW Systems for cooling is based on the Technical Specification temperature limit (92 °F) of the NHS and the performance capability of the equipment. Periodic testing and cleaning are required to verify and ensure that the assumed degree of degradation is not reached. The limits for equipment degradation ensure that affected components continue to perform their design basis function.

Therefore, since the design basis capability of the affected components is maintained at the NHS temperature limit (92 °F), this change does not involve a significant reduction in the margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for Licensee: Mr. J. Bradley Fewell, Assistant General Counsel, Exelon Generation Company, LLC, 200 Exelon Way, Kennett Square, PA 19348.

NRC Branch Chief: Meena K. Khanna.

FirstEnergy Nuclear Operating Company, et al., Docket Nos. 50-334 and 50-412, Beaver Valley Power Station, Units 1 and 2, Beaver County, Pennsylvania

Date of amendment request: July 25, 2012.

Description of amendment request: The proposed amendment would modify Technical Specification (TS) 3.1.3 to allow the normally required near-end of life Moderator Temperature Coefficient (MTC) measurement to not be performed under certain conditions. If these specified conditions are met, the

MTC measurement would be replaced by a calculated value.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below, with NRC edits in brackets:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

This amendment request would change the near-end of life (EOL) moderator temperature coefficient (MTC) surveillance requirement (SR) to allow [] the required MTC measurement [to be eliminated] under certain conditions. This change would not result in physical alteration of a plant structure, system or component, or installation of new or different types of equipment. Modification of the surveillance requirement under certain conditions would not affect the probability of accidents previously evaluated in the Updated Final Safety Analysis Report (UFSAR) or cause a change to any of the dose analyses associated with the UFSAR accidents because accident mitigation functions would remain unchanged. Existing MTC TS limits would remain unchanged and would continue to be satisfied.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

This amendment request would change the near EOL MTC SR to allow [] the required MTC measurement [to be eliminated] under certain conditions. No new accident scenarios, failure mechanisms, or limiting single failures are introduced as a result of the proposed change. No physical plant alterations are made as a result of the proposed change. The proposed change does not challenge the performance or integrity of any safety related system. MTC is a variable that must remain within limits but is not an accident initiator.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

This amendment request would change the near EOL MTC SR to allow [] the required MTC measurement to be eliminated under certain conditions. The margin of safety associated with the acceptance criteria of accidents previously evaluated in the UFSAR is unchanged. The proposed change would have no effect on the availability, operability, or performance of the safety-related systems and components. A change to a surveillance is proposed based on an alternate method of confirming that the surveillance requirement is met. The Technical Specification limiting

condition for operation (LCO) limits for MTC remain unchanged.

The Technical Specifications establish limits for the moderator temperature coefficient based on assumptions in the UFSAR accident analyses. Applying the conditional [elimination of] the moderator temperature coefficient measurement changes the method of meeting the surveillance requirement; however this change does not modify the TS values and ensures adherence to the current TS limits. The basis for derivation of the moderator temperature coefficient limits from the moderator density coefficient assumed in the accident analysis would not change.

Therefore, the margin of safety as defined in the TS is not reduced and the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and based on this review, with the edits noted above, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: David W. Jenkins, FirstEnergy Nuclear Operating Company, FirstEnergy Corporation, 76 South Main Street, Akron, OH 44308.

NRC Branch Chief: Meena Khanna.

Florida Power and Light Company, Docket Nos. 50-250 and 50-251, Turkey Point Plant, Units 3 and 4, Miami-Dade County, Florida

Date of amendment request: July 16, 2012, as supplemented by letter dated August 10, 2012.

Description of amendment request: The proposed amendments would modify Technical Specification (TS) requirements regarding steam generator tube inspections and reporting as described in Technical Specification Task Force Traveler 510, Revision 2, "Revision to Steam Generator Program Inspection Frequencies and Tube Sample Selection." The proposed changes would revise TS 3/4.4.5, "Steam Generator (SG) Tube Integrity," TS 6.8.4.j, "Steam Generator (SG) Program." and TS 6.9.1.8, "Steam Generator Tube Inspection Report."

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed change revises the Steam Generator (SG) Program to modify the frequency of verification of SG tube integrity

and SG tube sample selection. A steam generator tube rupture (SGTR) event is one of the design basis accidents that are analyzed as part of a plant's licensing basis. The proposed SG tube inspection frequency and sample selection criteria will continue to ensure that the SG tubes are inspected such that the probability of a SGTR is not increased. The consequences of a SGTR are bounded by the conservative assumptions in the design basis accident analysis. The proposed change will not cause the consequences of a SGTR to exceed those assumptions.

Therefore, it is concluded that this change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed changes to the Steam Generator Program will not introduce any adverse changes to the plant design basis or postulated accidents resulting from potential tube degradation. The proposed change does not affect the design of the SGs or their method of operation. In addition, the proposed change does not impact any other plant system or component.

Therefore, it is concluded that this change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

The SG tubes in pressurized water reactors are an integral part of the reactor coolant system pressure boundary and, as such, are relied upon to maintain the primary system's pressure and inventory. As part of the reactor coolant system pressure boundary, the SG tubes are unique in that they are also relied upon as a heat transfer surface between the primary and secondary systems such that residual heat can be removed from the primary system. In addition, the SG tubes also isolate the radioactive fission products in the primary coolant from the secondary system. In summary, the safety function of a SG is maintained by ensuring the integrity of its tubes.

Steam generator tube integrity is a function of the design, environment, and the physical condition of the tube. The proposed change does not affect tube design or operating environment. The proposed change will continue to require monitoring of the physical condition of the SG tubes such that there will not be a reduction in the margin of safety compared to the current requirements.

Therefore, it is concluded that the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: M.S. Ross, Attorney, Florida Power & Light, P.O. Box 14000, Juno Beach, Florida 33408-0420.

NRC Acting Branch Chief: Jessie F. Quichocho.

Southern Nuclear Operating Company, Inc., Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric Authority of Georgia, City of Dalton, Georgia, Docket Nos. 50-321 and 50-366, Edwin I. Hatch Nuclear Plant (HNP), Units 1 and 2, Appling County, Georgia

Date of amendment request: July 5, 2012.

Description of amendment request: The proposed amendments would revise Technical Specification (TS) Limiting Condition for Operation (LCO) for the plant service water (PSW) and ultimate heat sink (UHS). Specifically, the surveillance requirement (SR) for the minimum water level in each PSW pump well of the intake structure would be revised from the existing value to a lower value. This change is based on updated design basis analyses that demonstrate that at the new minimum level sufficient water inventory remains available from the Altamaha River for PSW and residual heat removal service water (RHRSW) to handle Loss of Coolant Accident (LOCA) cooling requirements for 30 days post-accident with no additional makeup water source available.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed TS change revises the minimum water level in the PSW pump well, as required by SR 3.7.2.1, from 60.7 [feet] ft [mean sea level] MSL to 60.5 ft MSL. TS SR 3.7.2.1 verifies that the UHS is OPERABLE by ensuring the water level in the PSW pump well of the intake structure is sufficient for the PSW, RHRSW and standby service water pumps to supply post-LOCA cooling requirements for 30 days. The safety function of the UHS is to mitigate the impact of an accident. The proposed TS change does not result in or require any physical changes to HNP systems, structures, and components, including those intended for the prevention of accidents. The potential impact of the lower PSW pump well minimum water level on pump operation requirements, supply of water for 30 days post-LOCA, and potential environmental impact have been evaluated and found to be acceptable.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed TS change revises the minimum water level in the PSW pump well, as required by SR 3.7.2.1, from 60.7 ft MSL to 60.5 ft MSL. TS SR 3.7.2.1 verifies that the UHS is OPERABLE by ensuring the water level in the PSW pump well of the intake structure is sufficient for the PSW, RHRSW and standby service water pumps to supply post-LOCA cooling requirements for 30 days. The proposed TS change does not result in or require any physical changes to HNP systems, structures, and components. The potential impact of the lower PSW pump well minimum water level on pump operation requirements, supply of water for 30 days post-LOCA, and potential environmental impact have been evaluated and found to be acceptable.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

The proposed TS change revises the minimum water level in the PSW pump well, as required by SR 3.7.2.1, from 60.7 ft MSL to 60.5 ft MSL. TS SR 3.7.2.1 verifies that the UHS is OPERABLE by ensuring the water level in the PSW pump well of the intake structure is sufficient for the PSW, RHRSW and standby service water pumps to supply post-LOCA cooling requirements for 30 days. The proposed TS change does not result in or require any physical changes to HNP systems, structures, and components. The potential impact of the lower PSW pump well minimum water level on pump operation requirements, supply of water for 30 days post-LOCA, and potential environmental impact have been evaluated and found to be acceptable.

Therefore, the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Ernest L. Blake, Jr., Esquire, Shaw, Pittman, Potts and Trowbridge, 2300 N Street NW., Washington, DC 20037.

NRC Branch Chief: Nancy L. Salgado.

Wolf Creek Nuclear Operating Corporation, Docket No. 50-482, Wolf Creek Generating Station, Coffey County, Kansas

Date of amendment request: May 2, 2012.

Description of amendment request: The amendment would revise Technical Specification (TS) 3.6.6, "Containment Spray and Cooling Systems," to replace the 10-year surveillance frequency for testing the containment spray nozzles as required by TS Surveillance Requirement 3.6.6.8 with an event-based frequency.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The Containment Spray System and its spray nozzles are not accident initiators and therefore, the proposed change does not involve a significant increase in the probability of an accident. The revised surveillance requirement will require event-based Frequency verification in lieu of fixed Frequency verification. The proposed change does not have a detrimental impact on the integrity of any plant structure, system, or component that may initiate an analyzed event. The proposed change will not alter the operation or otherwise increase the failure probability of any plant equipment that can initiate an analyzed accident.

This change does not affect the plant design. There is no increase in the likelihood of formation of significant corrosion products. Due to their location at the top of the containment, introduction of foreign material into the spray headers is unlikely. Foreign material introduced during maintenance activities would be the most likely source for obstruction, and verification following such maintenance would confirm the nozzles remain unobstructed. Since the Containment Spray System will continue to be available to perform its accident mitigation function, the consequences of accidents previously evaluated are not significantly increased.

Therefore, the consequences of an accident previously evaluated are not significantly affected by the proposed change.

2. Do the proposed changes create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed change will not physically alter the plant (no new or different type of equipment will be installed) or change the methods governing normal plant operation. The proposed change does not introduce new accident initiators or impact assumptions made in the safety analysis. Testing

requirements continue to demonstrate that the Limiting Conditions for Operation are met and the system components are functional.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any previously evaluated.

3. Do the proposed changes involve a significant reduction in a margin of safety?

Response: No.

The system is not susceptible to corrosion-induced obstruction or obstruction from sources external to the system. Maintenance activities that could introduce foreign material into the system would require subsequent verification to ensure there is no nozzle blockage. The spray header nozzles are expected to remain unblocked and available in the event that the safety function is required. Therefore, the capacity of the system would remain unaffected. The proposed change does not relax any criteria used to establish safety limits and will not relax any safety system settings. The safety analysis acceptance criteria are not affected by this change.

Therefore the proposed change does not involve a reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Jay Silberg, Esq., Pillsbury Winthrop Shaw Pittman LLP, 2300 N Street NW., Washington, DC 20037.

NRC Branch Chief: Michael T. Markley.

Wolf Creek Nuclear Operating Corporation, Docket No. 50-482, Wolf Creek Generating Station, Coffey County, Kansas

Date of amendment request: April 26, 2012.

Description of amendment request: The amendment would revise the Technical Specifications (TSs) to adopt Technical Specification Task Force (TSTF) Change Traveler TSTF-510, Revision 2, "Revision to Steam Generator Program Inspection Frequencies and Tube Sample Selection," using the consolidated line item improvement program (CLIIP). The NRC staff issued a notice of availability of the model for referencing in license amendment applications in the **Federal Register** on October 27, 2011 (76 FR 66763).

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed change revises the Steam Generator (SG) Program to modify the frequency of verification of SG tube integrity and SG tube sample selection. A steam generator tube rupture (SGTR) event is one of the design basis accidents that are analyzed as part of a plant's licensing basis. The proposed SG tube inspection frequency and sample selection criteria will continue to ensure that the SG tubes are inspected such that the probability of a SGTR is not increased. The consequences of a SGTR are bounded by the conservative assumptions in the design basis accident analysis. The proposed change will not cause the consequences of a SGTR to exceed those assumptions.

Therefore, it is concluded that this change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed changes to the SG Program will not introduce any adverse changes to the plant design basis or postulated accidents resulting from potential tube degradation. The proposed change does not affect the design of the SGs or their method of operation. In addition, the proposed change does not impact any other plant system or component.

Therefore, it is concluded that this change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

The SG tubes in pressurized water reactors are an integral part of the reactor coolant pressure boundary and, as such, are relied upon to maintain the primary system's pressure and inventory. As part of the reactor coolant pressure boundary, the SG tubes are unique in that they are also relied upon as a heat transfer surface between the primary and secondary systems such that residual heat can be removed from the primary system. In addition, the SG tubes also isolate the radioactive fission products in the primary coolant from the secondary system. In summary, the safety function of a SG is maintained by ensuring the integrity of its tubes.

Steam generator tube integrity is a function of the design, environment, and the physical condition of the tube. The proposed change does not affect tube design or operating environment. The proposed change will continue to require monitoring of the physical condition of the SG tubes such that there will not be a reduction in the margin of safety compared to the current requirements.

Therefore, it is concluded that the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Jay Silberg, Esq., Pillsbury Winthrop Shaw Pittman LLP, 2300 N. Street NW., Washington, DC 20037.

NRC Branch Chief: Michael T. Markley.

Notice of Issuance of Amendments to Facility Operating Licenses and Combined Licenses

During the period since publication of the last biweekly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or combined license, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** as indicated.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.22(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the NRC's Public Document Room (PDR), located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. Publicly available documents created or received at the NRC are accessible

electronically through the Agencywide Documents Access and Management System (ADAMS) in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the PDR's Reference staff at 1-800-397-4209, 301-415-4737 or by email to pdr.resource@nrc.gov.

Calvert Cliffs Nuclear Power Plant, LLC, Docket Nos. 50-317 and 50-318, Calvert Cliffs Nuclear Power Plant, Units 1 and 2, Calvert County, Maryland

Date of application for amendments: August 8, 2011, as supplemented by letters dated January 11, May 7, and July 18, 2012.

Brief description of amendments: The amendments would modify Technical Specification (TS) 3.8.1, "AC Sources—Operating," Surveillance Requirement (SR) 3.8.1.11 by revising the required power factor value to be achieved by the diesel generators (DGs) during conduct of the surveillance test. The proposed change would also modify the existing note in SR 3.8.1.11 to allow the DG to not achieve the required power factor if the grid conditions do not permit and the test is performed with DG synchronized with offsite power.

Date of issuance: August 22, 2012.

Effective date: As of the date of issuance to be implemented within 90 days.

Amendment Nos.: 302 and 279.

Renewed Facility Operating License Nos. DPR-53 and DPR-69: Amendments revised the License and TSs.

Date of initial notice in Federal Register: November 29, 2011 (76 FR 73729).

The Commission's related evaluation of these amendments is contained in a Safety Evaluation dated August 22, 2012.

No significant hazards consideration comments received: No.

Dominion Nuclear Connecticut, Inc., Docket No. 50-336, Millstone Power Station, Unit 2, New London County, Connecticut

Date of application for amendment: July 17, 2011, as supplemented by two letters dated August 9, 2012.

Brief description of amendment: The amendment revises Final Safety Analysis Report (FSAR) Section 9.7.2.1.2, and Appendix B to provide additional operating margin for measurement of the Ultimate Heat Sink (UHS) temperature. The proposed change to Appendix B is to remove a license condition that is no longer needed.

Date of issuance: August 10, 2012.

Effective date: As of the date of issuance, and shall be implemented within 30 days.

Amendment No.: 311.

Renewed Facility Operating License No. DPR-65: Amendment revised the License and Appendix B.

Public comments requested as to proposed no significant hazards consideration (NSHC): No.

The Commission's related evaluation of the amendment, finding of emergency circumstances, and final determination of no significant hazards consideration are contained in a Safety Evaluation dated August 10, 2012.

Attorney for licensee: Lillian M. Cuoco, Senior Counsel, Dominion Resources Services, Inc., 120 Tredegar Street, RS-2, Richmond, VA 23219.

NRC Branch Chief: George A. Wilson.

Entergy Nuclear Operations, Inc., Docket No. 50-293, Pilgrim Nuclear Power Station, Plymouth County, Massachusetts

Date of application for amendment: October 28, 2011, as supplemented on May 16, 2012.

Brief description of amendment: This amendment request would revise the Technical Specifications (TSs) to increase the condensate storage tank low water level setpoint for the interlock to the high pressure coolant injection pump suction valves. Additionally, the amendment would correct typographical errors in TS numbering and referencing made in prior license amendment nos. 223 and 228.

Date of issuance: August 7, 2012.

Effective date: As of the date of issuance, and shall be implemented within 60 days.

Amendment No.: 237.

Facility Operating License No. DPR-35: The amendment revised the License and Technical Specifications.

Date of initial notice in Federal Register: January 10, 2012 (77 FR 1517).

The supplemental letter dated May 16, 2012, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of this amendment is contained in a Safety Evaluation dated August 7, 2012.

No significant hazards consideration comments received: No.

Southern Nuclear Operating Company, Inc., Docket Nos. 50-424 and 50-425, Vogtle Electric Generating Plant, Units 1 and 2, Burke County, Georgia

Date of application for amendments: July 26, 2011.

Brief description of amendments: The amendments revised the Technical Specifications (TSs). Specifically, the change revised the minimum indicated nitrogen cover pressure specified for the accumulators in TS surveillance requirement (SR) 3.5.1.3 from 617 psig (pounds per square inch, gauge) to 626 psig. The amendments also correct a typographical error in the text associate with SR 3.6.2.1 changing the word "rage" to "rate."

Date of issuance: August 14, 2012.

Effective date: As of the date of issuance and shall be implemented within 60 days from the date of issuance.

Amendment Nos.: Unit 1-166 and Unit 2-148.

Facility Operating License Nos. NPF-68 and NPF-81: Amendments revised the licenses and the technical specifications.

Date of initial notice in Federal Register: September 6, 2011.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated August 14, 2012.

No significant hazards consideration comments received: No.

STP Nuclear Operating Company, Docket Nos. 50-498 and 50-499, South Texas Project, Units 1 and 2, Matagorda County, Texas

Date of amendment request: August 23, 2011.

Brief description of amendments: The amendments revised the application of Risk-Managed Technical Specifications (RMTS) to Technical Specification (TS) 3.7.7, "Control Room Makeup and Cleanup Filtration System." The amendments corrected a potential misapplication of the Configuration Risk Management Program (CRMP) that is currently allowed by the TSs.

Date of issuance: August 14, 2012.

Effective date: As of the date of issuance and shall be implemented within 60 days of issuance.

Amendment Nos.: Unit 1-199; Unit 2-187.

Facility Operating License Nos. NPF-76 and NPF-80: The amendments revised the Facility Operating Licenses and Technical Specifications.

Date of initial notice in Federal Register: November 1, 2011 (76 FR 67490).

The Commission's related evaluation of the amendments is contained in a

Safety Evaluation dated August 14, 2012.

No significant hazards consideration comments received: No.

Notice of Issuance of Amendments to Facility Operating Licenses and Combined Licenses and Final Determination of No Significant Hazards Consideration and Opportunity for a Hearing (Exigent Public Announcement or Emergency Circumstances)

During the period since publication of the last biweekly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Because of exigent or emergency circumstances associated with the date the amendment was needed, there was not time for the Commission to publish, for public comment before issuance, its usual notice of consideration of issuance of amendment, proposed no significant hazards consideration determination, and opportunity for a hearing.

For exigent circumstances, the Commission has either issued a **Federal Register** notice providing opportunity for public comment or has used local media to provide notice to the public in the area surrounding a licensee's facility of the licensee's application and of the Commission's proposed determination of no significant hazards consideration. The Commission has provided a reasonable opportunity for the public to comment, using its best efforts to make available to the public means of communication for the public to respond quickly, and in the case of telephone comments, the comments have been recorded or transcribed as appropriate and the licensee has been informed of the public comments.

In circumstances where failure to act in a timely way would have resulted, for example, in derating or shutdown of a nuclear power plant or in prevention of either resumption of operation or of increase in power output up to the plant's licensed power level, the Commission may not have had an opportunity to provide for public comment on its no significant hazards consideration determination. In such

case, the license amendment has been issued without opportunity for comment. If there has been some time for public comment but less than 30 days, the Commission may provide an opportunity for public comment. If comments have been requested, it is so stated. In either event, the State has been consulted by telephone whenever possible.

Under its regulations, the Commission may issue and make an amendment immediately effective, notwithstanding the pendency before it of a request for a hearing from any person, in advance of the holding and completion of any required hearing, where it has determined that no significant hazards consideration is involved.

The Commission has applied the standards of 10 CFR 50.92 and has made a final determination that the amendment involves no significant hazards consideration. The basis for this determination is contained in the documents related to this action. Accordingly, the amendments have been issued and made effective as indicated.

Unless otherwise indicated, the Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.12(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the application for amendment, (2) the amendment to Facility Operating License or Combined License, as applicable, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment, as indicated. All of these items are available for public inspection at the NRC's Public Document Room (PDR), located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. Publicly available documents created or received at the NRC are accessible electronically through the Agencywide Documents Access and Management System (ADAMS) in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the PDR's Reference staff at 1-800-397-4209, 301-415-4737 or by email to pdr.resource@nrc.gov.

The Commission is also offering an opportunity for a hearing with respect to the issuance of the amendment. Within 60 days after the date of publication of this notice, any person(s) whose interest may be affected by this action may file a request for a hearing and a petition to intervene with respect to issuance of the amendment to the subject facility operating license or combined license. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested person(s) should consult a current copy of 10 CFR 2.309, which is available at the NRC's PDR, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852, and electronically on the Internet at the NRC's Web site, <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. If there are problems in accessing the document, contact the PDR's Reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or a presiding officer designated by the Commission or by the Chief Administrative Judge of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the Chief Administrative Judge of the Atomic Safety and Licensing Board will issue a notice of a hearing or an appropriate order.

As required by 10 CFR 2.309, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements: (1) The name, address, and telephone number of the requestor or petitioner; (2) the nature of the requestor's/petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the requestor's/petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the requestor's/petitioner's interest. The petition must also identify the specific contentions which the requestor/petitioner seeks to have litigated at the proceeding.

Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the requestor/petitioner shall

provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. The petition must include sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact.¹ Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A requestor/petitioner who fails to satisfy these requirements with respect to at least one contention will not be permitted to participate as a party.

Each contention shall be given a separate numeric or alpha designation within one of the following groups:

1. Technical—primarily concerns/issues relating to technical and/or health and safety matters discussed or referenced in the applications.
2. Environmental—primarily concerns/issues relating to matters discussed or referenced in the environmental analysis for the applications.
3. Miscellaneous—does not fall into one of the categories outlined above.

As specified in 10 CFR 2.309, if two or more petitioners/requestors seek to co-sponsor a contention, the petitioners/requestors shall jointly designate a representative who shall have the authority to act for the petitioners/requestors with respect to that contention. If a requestor/petitioner seeks to adopt the contention of another sponsoring requestor/petitioner, the requestor/petitioner who seeks to adopt the contention must either agree that the sponsoring requestor/petitioner shall act as the representative with respect to that contention, or jointly designate with the sponsoring requestor/petitioner a representative who shall have the authority to act for the petitioners/requestors with respect to that contention.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to

¹To the extent that the applications contain attachments and supporting documents that are not publicly available because they are asserted to contain safeguards or proprietary information, petitioners desiring access to this information should contact the applicant or applicant's counsel and discuss the need for a protective order.

intervene, and have the opportunity to participate fully in the conduct of the hearing. Since the Commission has made a final determination that the amendment involves no significant hazards consideration, if a hearing is requested, it will not stay the effectiveness of the amendment. Any hearing held would take place while the amendment is in effect.

All documents filed in the NRC adjudicatory proceedings, including a request for hearing, a petition for leave to intervene, any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities participating under 10 CFR 2.315(c), must be filed in accordance with the NRC E-Filing rule (72 FR 49139; August 28, 2007). The E-Filing process requires participants to submit and serve all adjudicatory documents over the Internet, or in some cases to mail copies on electronic storage media. Participants may not submit paper copies of their filings unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by email at hearing.docket@nrc.gov, or by telephone at 301-415-1677, to request (1) a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign documents and access the E-Submittal server for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a request or petition for hearing (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals/apply-certificates.html>. System requirements for accessing the E-Submittal server are detailed in NRC's "Guidance for Electronic Submission," which is available on the agency's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>. Participants may attempt to use other software not listed on the Web site, but should note that the NRC's E-Filing system does not

support unlisted software, and the NRC Meta System Help Desk will not be able to offer assistance in using unlisted software.

If a participant is electronically submitting a document to the NRC in accordance with the E-Filing rule, the participant must file the document using the NRC's online, Web-based submission form. In order to serve documents through the Electronic Information Exchange System, users will be required to install a Web browser plug-in from the NRC's Web site. Further information on the Web-based submission form, including the installation of the Web browser plug-in, is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>.

Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then submit a request for hearing or petition for leave to intervene. Submissions should be in Portable Document Format (PDF) in accordance with NRC guidance available on the NRC public Web site at <http://www.nrc.gov/site-help/e-submittals.html>. A filing is considered complete at the time the documents are submitted through the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email notice confirming receipt of the document. The E-Filing system also distributes an email notice that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the documents on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before a hearing request/petition to intervene is filed so that they can obtain access to the document via the E-Filing system.

A person filing electronically using the agency's adjudicatory E-Filing system may seek assistance by contacting the NRC Meta System Help Desk through the "Contact Us" link located on the NRC's Web site at <http://www.nrc.gov/site-help/e-submittals.html>, by email at MSHD.Resource@nrc.gov, or by a toll-free call at 1-866-672-7640. The NRC Meta System Help Desk is available between 8 a.m. and 8 p.m., Eastern

Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing requesting authorization to continue to submit documents in paper format. Such filings must be submitted by: (1) First class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, Sixteenth Floor, One White Flint North, 11555 Rockville Pike, Rockville, Maryland, 20852, Attention: Rulemaking and Adjudications Staff. Participants filing a document in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <http://ehd1.nrc.gov/ehd/>, unless excluded pursuant to an order of the Commission, or the presiding officer. Participants are requested not to include personal privacy information, such as social security numbers, home addresses, or home phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

Dated at Rockville, Maryland, this 24th day of August 2012.

For The Nuclear Regulatory Commission.

Michele G. Evans,

Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2012-21545 Filed 8-31-12; 8:45 am]

BILLING CODE 7590-01-P

OVERSEAS PRIVATE INVESTMENT CORPORATION

Sunshine Act Cancellation Notice— OPIC September 6, 2012 Public Hearing

OPIC's Sunshine Act notice of its Public Hearing in Conjunction with each Board meeting was published in the **Federal Register** (Volume 77, Number 159, Pages 49472 and 49473) on August 16, 2012. No requests were received to provide testimony or submit written statements for the record; therefore, OPIC's public hearing scheduled for 3 p.m., September 6, 2012 in conjunction with OPIC's September 13, 2012 Board of Directors meeting has been cancelled.

Contact Person For Information:
Information on the hearing cancellation may be obtained from Connie M. Downs at (202) 336-8438, or via email at Connie.Downs@opic.gov.

Dated: August 30, 2012.

Connie M. Downs,

OPIC Corporate Secretary.

[FR Doc. 2012-21794 Filed 8-30-12; 11:15 am]

BILLING CODE 3210-01-P

OVERSEAS PRIVATE INVESTMENT CORPORATION

Sunshine Act Cancellation Notice— OPIC's September 6, 2012 Annual Public Hearing

OPIC's Sunshine Act notice of its Annual Public Hearing was published in the **Federal Register** (Volume 77, Number 143, Page 43618) on July 25, 2012. No requests were received to provide testimony or submit written statements for the record; therefore, OPIC's Annual Public Hearing scheduled for 2 p.m., September 6, 2012 has been cancelled.

CONTACT PERSON FOR INFORMATION:

Information on the hearing cancellation may be obtained from Connie M. Downs at (202) 336-8438, via facsimile at (202) 218-0136, or via email at Connie.Downs@opic.gov.

Dated: August 30, 2012.

Connie M. Downs,

OPIC Corporate Secretary.

[FR Doc. 2012-21795 Filed 8-30-12; 11:15 am]

BILLING CODE 3210-01-P