

Available Retrofit requirements in CAA section 169(b)(2)(A) and the Visibility Impairment requirements in CAA section 110(a)(2)(D)(i)(II). This action will not modify this relationship. Thus, Executive Order 13132 does not apply to this action.

F. Executive Order 13175—Consultation and Coordination With Indian Tribal Governments

This FIP withdrawal action does not have tribal implications, as specified in Executive Order 13175 (65 FR 67249, November 9, 2000). In this action, EPA is not addressing any Tribal Implementation Plans. This action is limited to the withdrawal of the New Mexico RH and IT FIP for PNM's San Juan Generating Station. Thus, Executive Order 13175 does not apply to this action. Consistent with EPA policy, EPA offered consultation to tribes regarding this rulemaking action.

G. Executive Order 13045—Protection of Children From Environmental Health Risks and Safety Risks

EPA interprets Executive Order 13045 (62 FR 19885, April 23, 1997) as applying only to those regulatory actions that concern health or safety risks, such that the analysis required under section 5–501 of the executive order has the potential to influence the regulation. This action is not subject to EO 13045 because EPA is withdrawing the New Mexico RH and IT FIP for PNM's San Juan Generating Station, as authorized by the CAA, EPA considers visibility and not health or safety risks.

H. Executive Order 13211—Actions Concerning Regulations That Significantly Affect Energy Supply, Distribution, or Use

This FIP withdrawal action is not subject to Executive Order 13211 (66 FR 28355, May 22, 2001) because it is exempt from review under Executive Order 12866.

I. National Technology Transfer and Advancement Act

Section 12(d) of the National Technology Transfer and Advancement Act of 1995 (NTTAA), Public Law 104–113, 12(d) (15 U.S.C. 272 note) directs EPA to use voluntary consensus standards in its regulatory activities unless to do so would be inconsistent with applicable law or otherwise impractical. Voluntary consensus standards are technical standards (e.g., materials specifications, test methods, sampling procedures, and business practices) that are developed or adopted by voluntary consensus standards bodies. NTTAA directs EPA to provide

Congress, through OMB, explanations when the Agency decides not to use available and applicable voluntary consensus standards. This FIP withdrawal action for PNM's San Juan Generating Station does not involve technical standards. Therefore, EPA did not consider the use of any voluntary consensus standards.

J. Executive Order 12898—Federal Actions To Address Environmental Justice in Minority Populations and Low-Income Populations

This final rule does not provide EPA with the discretionary authority to address, as appropriate, disproportionate human health or environmental effects, using practicable and legally permissible methods, under Executive Order 12898 (59 FR 7629, February 16, 1994).

K. Congressional Review Act

The Congressional Review Act, 5 U.S.C. 801 *et seq.*, as added by the Small Business Regulatory Enforcement Fairness Act of 1996, generally provides that before a rule may take effect, the agency promulgating the rule must submit a rule report, which includes a copy of the rule, to each House of the Congress and to the Comptroller General of the United States. EPA will submit a report containing this action and other required information to the U.S. Senate, the U.S. House of Representatives, and the Comptroller General of the United States prior to publication of the rule in the **Federal Register**. A major rule cannot take effect until 60 days after it is published in the **Federal Register**. This action is not a “major rule” as defined by 5 U.S.C. 804(2).

L. Petitions for Judicial Review

Under section 307(b)(1) of the Clean Air Act, petitions for judicial review of this action must be filed in the United States Court of Appeals for the appropriate circuit by December 8, 2014. Filing a petition for reconsideration by the Administrator of this final rule does not affect the finality of this action for the purposes of judicial review nor does it extend the time within which a petition for judicial review may be filed, and shall not postpone the effectiveness of such rule or action. This action may not be challenged later in proceedings to enforce its requirements. (See section 307(b)(2).)

List of Subjects in 40 CFR Part 52

Environmental protection, Air pollution control, Incorporation by reference, Intergovernmental relations, Nitrogen dioxide, Particulate matter,

Regional haze, Reporting and recordkeeping requirements, Sulfur dioxide, and Visibility.

Dated: September 26, 2014.

Gina McCarthy,
Administrator.

For the reasons stated in the preamble, Title 40, chapter I, of the Code of Federal Regulations is amended as follows:

PART 52—APPROVAL AND PROMULGATION OF IMPLEMENTATION PLANS

- 1. The authority citation for part 52 continues to read as follows:

Authority: 42 U.S.C. 7401 *et seq.*

§ 52.1628 [Removed and Reserved]

- 2. Section 52.1628 is removed and reserved.

[FR Doc. 2014–23905 Filed 10–8–14; 8:45 am]

BILLING CODE 6560–50–P

ENVIRONMENTAL PROTECTION AGENCY

40 CFR Part 52

[EPA–R06–OAR–2014–0214; FRL–9917–63–Region 6]

Approval and Promulgation of Implementation Plans; New Mexico; Regional Haze and Interstate Transport Affecting Visibility State Implementation Plan Revisions

AGENCY: Environmental Protection Agency (EPA).

ACTION: Final rule.

SUMMARY: The Environmental Protection Agency (EPA) is taking final action under the Clean Air Act (CAA) to approve a revision to the New Mexico Regional Haze State Implementation Plan (SIP) that addresses the Best Available Retrofit Technology (BART) requirement for oxides of nitrogen (NO_x) for the Public Service Company of New Mexico (PNM) San Juan Generating Station (SJGS) in San Juan County, New Mexico. EPA is also taking final action under the CAA to approve a revision to the New Mexico Visibility Transport SIP that addresses the CAA requirement that emissions from sources in New Mexico do not interfere with programs in other states to protect visibility. The SIP meets this requirement through emission limitations for NO_x and sulfur dioxide (SO₂) at SJGS.

DATES: This final rule will be effective November 10, 2014.

ADDRESSES: EPA has established a docket for this action under Docket ID No. EPA-R06-OAR-2014-0214. All documents in the docket are listed in the <http://www.regulations.gov> index. Although listed in the index, some information is not publicly available, e.g., Confidential Business Information or other information the disclosure of which is restricted by statute. Certain other material, such as copyrighted material, will be publicly available only in hard copy. Publicly available docket materials are available either electronically in <http://www.regulations.gov> or in hard copy at the Air Planning Section (6PD-L), Environmental Protection Agency, 1445 Ross Avenue, Suite 700, Dallas, Texas 75202-2733. The file will be made available by appointment for public inspection in the Region 6 FOIA Review Room between the hours of 8:30 a.m. and 4:30 p.m. weekdays except for legal holidays. Contact the person listed in the **FOR FURTHER INFORMATION CONTACT** paragraph below or Mr. Bill Deese at 214-665-7253 to make an appointment. If possible, please make the appointment at least two working days in advance of your visit. A 15 cent per page fee will be charged for making photocopies of documents. On the day of the visit, please check in at the EPA Region 6 reception area on the seventh floor at 1445 Ross Avenue, Suite 700, Dallas, Texas 75202-2733.

FOR FURTHER INFORMATION CONTACT: Mr. Michael Feldman (214) 665-9793, email feldman.michael@epa.gov.

SUPPLEMENTARY INFORMATION: Throughout this document whenever “we,” “us,” or “our” is used, we mean EPA.

Table of Contents

- I. What is the background for this action?
- II. What final action is EPA taking?
- III. Response to Comments
- IV. Statutory and Executive Order Reviews

I. What is the background for this action?

The background for today’s final rule is discussed in detail in our May 12, 2014 document, in which we proposed to approve New Mexico’s SIP revisions. See 79 FR 26909. The comment period on the proposed action was open for 30 days, and several comments were received.

II. What final action is EPA taking?

We are approving New Mexico’s regional haze SIP revisions submitted on October 7, 2013 and November 5, 2013 (“2013 RH SIP revision”), that build on a SIP revision submitted on

July 5, 2011 (“2011 RH SIP revision”).¹ The 2013 RH SIP revision contains a new NO_x BART determination for the SJGS (referred to as the “State Alternative”). The State Alternative consists of a previously un-contemplated control scenario involving unit shutdowns at the SJGS. With this approval, the State Alternative supersedes the State’s previous NO_x BART determination that was included in the 2011 RH SIP revision. The State Alternative reflects the terms of the tentative agreement signed between the PNM, the New Mexico Environment Department (NMED), and EPA to address the regional haze requirements applicable to the SJGS. This agreement is included as Exhibit 5 of the 2013 RH SIP revision.² The 2013 RH SIP revision also includes a preconstruction permit submitted on November 5, 2013,³ that sets a NO_x emission limit based upon the State Alternative, compliance schedules, a compliance deadline for the shutdown of two units, and monitoring and testing requirements. More specifically, the 2013 RH SIP revision requires the following:

- Fifteen (15) months after EPA’s final approval of the 2013 RH SIP revision, but no earlier than January 31, 2016, PNM will complete installation of SNCR technology on SJGS Units 1 and 4 and meet an emission limit of 0.23 lb/MMBtu on a rolling 30-day average basis;⁴
- PNM will retire SJGS Units 2 and 3 by December 31, 2017; and
- PNM will commence a program of testing and evaluation, after the installation of the SNCRs, to determine if additional NO_x emission reductions can be achieved. The Testing Program, consisting of SNCR performance testing, fuel performance testing, and long-term performance evaluation, must be

¹ We are acting on everything not yet acted upon in the 2011 RH SIP revision that pertains to the 2013 NO_x BART determination. The 2013 RH SIP revision explains that the revised, more recent NO_x BART determination would “supersede” the 2011 NO_x BART determination if EPA approves it. Certain NMED documents from the 2011 RH SIP revision are relevant to the state’s 2013 conclusions regarding NO_x BART, but other information that relates solely to the 2011 NO_x BART determination is now moot with EPA’s finalized approval of the superseding BART determination.

² Term Sheet Between the U.S. Environmental Protection Agency, Public Service Company of New Mexico and the State of New Mexico (“Term Sheet”), February 15, 2013.

³ NSR Technical Permit Revision, NSR Permit No. 0063-M6R3, November 1, 2013.

⁴ The permit conditions at A112C specify the averaging time and calculation methodology for the enforceable emission limit for NO_x on Units 1 and 4 of 0.23 lb/MMBtu on a boiler-operating-day basis, averaged across the two units.

completed no later than January 31, 2017.⁵

In addition to approving New Mexico’s revised enforceable NO_x BART determination for SJGS, we are also approving New Mexico’s 2011 Visibility Transport SIP revision, as revised in 2013, because it demonstrates that emissions from all sources in New Mexico are sufficiently controlled to eliminate interference with the visibility programs of other states. We are also approving as part of New Mexico’s SIP the operative sections of the 2013 permit for SJGS on the basis that the SO₂ and NO_x emission limits for the SJGS will sufficiently prevent emissions from sources in New Mexico from interfering with the visibility programs of other states.

New Mexico has incorporated emission limits and requirements for unit shutdowns into the 2013 preconstruction permit that was submitted as part of the SIP revisions. Specifically, as a source-specific requirement of the New Mexico SIP for regional haze and visibility transport, section A112C of the 2013 SJGS permit provides a more stringent SO₂ emission limit (i.e., than previously permitted or SIP-required) as part of the State Alternative and a NO_x emission limit reflecting the State Alternative. The permit contains three independent scenarios under section A112: A, B, and C. Consistent with the terms of the permit, our final approval puts Scenario C into effect, while the other two scenarios are now moot.

We have determined that the 2013 RH SIP revision and corresponding visibility transport SIP revisions are approvable because the revisions were adopted and submitted in accordance with the CAA and EPA’s regulations regarding the regional haze program and meet the CAA provisions concerning non-interference with programs to protect visibility in other states. We are taking this final action today under section 110 and part C of the CAA. Consistent with the discussion provided in our proposal, the 2011 RH SIP provision for NO_x BART is fully superseded and/or moot with today’s approval and does not constitute a SIP submittal pending EPA review and action.

In addition, as our May 12, 2014 proposal explained, the approval of the SIP submittals enables EPA to withdraw or rescind the Federal Implementation Plan (FIP) that was earlier promulgated

⁵ A delay may be allowed under special circumstances that would limit the number of evaluation days during both summer and winter months, as discussed in the paragraph 1(d)(iv) of the Term Sheet.

to address the same requirements. See 79 FR 26909. Accordingly, as a result of today's approval action, we are also taking action to withdraw the regional haze FIP for New Mexico at 40 CFR 52.1628. The action to withdraw the FIP is in a separate action contained in today's **Federal Register**. Upon the effective date of the **Federal Register** documents, the requirements in the approved SIP apply and the FIP requirements for the SJGS are withdrawn.

III. Response to Comments

We received several comments on our proposed approval of the 2013 RH SIP revision that were submitted by PNM, NMED, the Navajo Nation, the National Park Service, Tucson Electric Power Company, Utah Associated Municipal Power Systems, a consortium of environmental organizations,⁶ Santa Fe Monthly Meeting Peace and Social Concerns Committee, and Earth Justice. Copies of the comments are available in the docket for this rulemaking. Summaries of the issues raised in the comment letters, and our responses, follow:

Comment: A commenter, identified as a part owner of SJGS Unit 4, requested a 12-month extension of the SIP's compliance period for meeting the new NO_x limits. The commenter referred to the EPA proposal, "Carbon Pollution Emission Guidelines for Existing Stationary Sources: Electric Utility Generating Units," subsequently published at 79 FR 34829 (June 18, 2014), and asserted that an extension would allow for adequate consideration of the impacts of the proposal relative to the investment considerations of installing SNCRs at the SJGS. The commenter stated that ownership of SJGS presently includes utilities from five Western states, and the interstate nature of ownership and emissions complicates a coordinated compliance planning process. Another commenter, identified as a part owner of SJGS Units 1 and 2, supported the costs, anticipated haze reduction, and other environmental benefits associated with the 2013 RH SIP revision, but similarly

requested that EPA amend its approval and provide additional time for installation of SNCR on the basis that more time is needed to study the proposed standards for reducing carbon pollution at existing EGUs.

Response: EPA believes that CAA section 111(d) efforts and actions will tend to contribute to overall air quality improvements and thus should be complementary to criteria pollutant and regional haze SIP efforts but do not provide a basis for delaying implementation of these efforts. See 79 FR at 34931. The 111(d) proposal specifically mentions the next 10-year SIP revision for regional haze that is due by July 2018 and covers the time period through 2028, explaining that the timeframes proposed for submittal of the CAA section 111(d) state plans will allow considerable time for coordination by states in the development of their respective plans. The proposal does not suggest that further delays are warranted for implementing the regional haze requirements that were first due in December 2007. Indeed, states and affected sources will be able to take into account requirements of programs such as Regional Haze in considering the development of state plans under section 111(d).

More importantly here, EPA cannot alter an otherwise approvable SIP revision to extend a compliance date. The 2013 RH SIP revision submitted by New Mexico provides the compliance date. Moreover, the compliance dates that New Mexico set are as "expeditious as practicable," as required by the CAA. See CAA section 169A(b)(2)(A), (g)(2). Because the compliance dates meet CAA requirements, EPA cannot establish different compliance dates when taking action on the SIP revision. See CAA section 110(k)(3), (l).

Comment: A commenter stated that unit retirements and NO_x controls at SJGS would reduce regional haze and provide other significant environmental, economic, and health benefits, and states that "these additional benefits must be recognized." The commenter requested, however, that EPA's approval contain a statement reflecting EPA's willingness to consider eliminating the NO_x emission control requirements on Units 1 and 4 if, by December 31, 2016, there is a commitment to permanently retire Unit 1 and/or 4 within a reasonably short time-frame. PNM responded to this request in its own comment (although it mistakenly cited the date of December 31, 2015 when paraphrasing the comment). PNM's comment stated that EPA should reject the request for an EPA statement

regarding the retirement of additional capacity because the Agency lacks any analysis or basis upon which to evaluate the efficacy or legality of the request.

Response: We decline to endorse a proposal not before us, as suggested by the commenter. Because the 2013 RH SIP revision meets CAA requirements, we are required to approve it. See CAA section 110(k)(3), (l).

Comment: PNM submitted a comment supporting the proposed rule, agreeing that the 2013 RH SIP revision is reasonable, even when EPA's estimated SCR costs are used. PNM asserted, however, that its own estimated SCR capital costs were confirmed by detailed bids from engineering, procurement, and construction contractors, and that none of the bids were in the range of EPA's estimated SCR costs. PNM believed that these bids should satisfy any requirement for enhanced documentation to support higher SCR costs, but acknowledged that their cost estimates provide different treatment to items such as sorbent injection, apportionment of balanced draft costs, and fees and contingencies.

Response: We appreciate PNM's comment supporting approval. As identified by the comment, EPA's cost analysis for SCR was based on a different design (e.g., no costs for sorbent injection) than the design PNM used when soliciting bids from vendors. PNM's bids were not submitted with the comment and, based on the available documentation, we remain unable to conclude that certain line items in PNM's SCR cost estimates are well supported. While the BART Guidelines explain that data from vendor bids may be used in developing equipment cost estimates, this does not mean that bottom-line figures can serve as a substitute for a full cost analysis or that all costs included therein would be appropriate for making an assessment of cost-effectiveness. The expectation remains that the cost analysis maintain and improve consistency through adherence to the OAQPS Control Cost Manual, where possible. Moreover, the BART Guidelines state that documentation is expected, and indeed especially important, where a state believes that costs will be unreasonable even though other recent retrofits have cost-effectiveness values that are within what has been considered a reasonable range. As we established in our FIP, recent SCR retrofits at coal-fired power plants have been found to be cost-effective, and this cost effectiveness is generally validated by large emission reductions even when there are large capital costs.

⁶ Western Resource Advocates, New Energy Economy, WildEarth Guardians, Conservation Voters of New Mexico, Physicians for Social Responsibility (NM), Environment New Mexico/Environment New Mexico Research and Policy Center, New Mexico Independent Power Producers Climate Change Leadership Institute, Santa Fe Innovation Park, The Global Warming Express, Chainbreaker Collective, Center for Civic Policy, Citizens' Climate Lobby, and 350.org. These stakeholders also submitted a letter that has been added to the docket as a late comment; it raises no issues not already addressed by our response to comments.

Comment: NMED provided comments in support of approval and stated that they generally concur with our description and evaluation of the State Alternative for NO_x BART.

Response: We appreciate this comment.

Comment: NMED commented that states cannot be required to take a unit-specific (or unit-by-unit) approach to assessing the BART factors. In *American Corn Growers v. EPA*, 291 F.3d 1, 8 (D.C. Cir. 2002), a reviewing court held that it was invalid to consider visibility impacts on a multiple-source basis while employing a source-specific approach to the other four BART factors. The commenter stated that requiring states to assess visibility on a facility-wide basis while considering the other factors on a unit-by-unit basis would be similarly unsupported by the statute and would impermissibly constrain state authority.

Response: We disagree with this comment. In *American Corn Growers*, the D.C. Circuit held that EPA could not adopt a “group-BART approach” to the visibility factor because it could force states to require BART controls at some sources without any empirical evidence of a particular source’s contribution to visibility impairment in a Class I area. As a result, the Regional Haze Rule and BART Guidelines require states to analyze the five statutory factors for each BART-eligible source without reference to the benefits that BART will achieve at other sources. Beyond this, however, the court did not opine on how the BART factors should be analyzed or weighed by states, let alone prescribe a unit-specific or prescribe a facility-wide approach to BART.

As we recently explained in our action on the Wyoming regional haze SIP, see 79 FR 5031 (Jan. 30, 2014), the BART Guidelines prescribe that states “must conduct a visibility improvement determination for the source(s) as part of the BART determination,”⁷ and we interpret this language as requiring states to consider the visibility improvement from BART applied to the BART-eligible source as a whole. We do not believe that either the CAA or the BART Guidelines mandate either a unit-specific or a facility-wide approach to analyzing or weighing the remaining BART factors. In most circumstances, however, we believe that states should use a unit-specific approach to assessing the technical feasibility and costs of controls options, as well as the existing controls and remaining useful life of BART-eligible units. This approach is clearly contemplated by the BART

Guidelines and has been used for decades in other CAA contexts, such as the evaluation of Best Available Control Technology (BACT) for new and modified major stationary sources.⁸ A unit-specific approach to these factors is appropriate because the age, type, size, location, and emission characteristics of the various emission units at a source can differ greatly, and many control options by design apply to a single unit. However, in unique circumstances, such as in situations where a control strategy can be implemented facility-wide or where the benefits of unit shutdowns must be taken into account, then we believe that the CAA and BART Guidelines provide states with the flexibility to analyze and weigh the BART factors for the source as a whole, rather than for its constituent emission units.

Comment: NMED responded to a statement in the proposal that expressed some concern with the appropriateness of including SO₂ reductions from units 1 and 4 in one of the NO_x BART control options analyzed, rather than as part of the facility’s baseline emissions, by explaining that the SO₂ limit of 0.10 lbs/MMBtu is required by the 2013 RH SIP revision alone and would not be required if the FIP continues to remain in force.

Response: While the inclusion of the SO₂ reductions in the SIP helps to further demonstrate non-interference with the visibility protection programs of other states, in keeping with the visibility transport requirements of CAA section 110(a)(2)(D)(i)(I), and helps in showing the overall visibility benefits of the 2013 RH SIP revision, we had noted that those reductions do not specifically lend support to a visibility improvement determination for NO_x BART through the application of NO_x controls. However, no commenters took issue with the inclusion of SO₂ reductions in the studied scenarios or insisted that refinements were necessary on this point, and it remains our view that the inclusion of the reductions did not meaningfully impact the evaluation of visibility benefits due to NO_x reductions at the facility.

Comment: The Navajo Nation submitted a comment supporting the proposal as the best scenario for meeting BART, endorsing it for having reasonable costs of compliance and a realistic timeframe. The comment also stated that the 2013 RH SIP revision addressed concerns regarding potential job losses faced by Navajo work forces

at the SJGS and San Juan mine more effectively than EPA’s FIP.

Response: We appreciate this comment supporting approval.

Comment: One commenter stated that the 2013 RH SIP revision appears to be an alternative consistent with the intent of 40 CFR 51.308(e)(2) and therefore needs to demonstrate greater reasonable progress than EPA’s BART determination. The fact that the 2013 RH SIP revision does not demonstrate greater reasonable progress than EPA’s BART determination gave the commenter concern because the commenter considered it a departure from rules and guidance. The commenter also asserted that previous EPA decisions have required a source to demonstrate its proposed alternative is better than EPA’s BART determination, citing actions for Idaho and the Four Corners Power Plant.⁹

Response: We disagree that the 2013 RH SIP revision appears to be a BART alternative under section 51.308(e)(2). New Mexico explicitly stated that it was not evaluating a BART alternative when responding to comments during the state process and again when submitting comments to support our proposed approval. Therefore, New Mexico was not required to make a demonstration of greater reasonable progress. Instead, New Mexico evaluated a new, source-specific BART determination under section 51.308(e)(1). To fully account for the source owner’s proposed unit shutdowns, New Mexico chose to weigh the BART factors in light of source-wide considerations. As explained in our proposal and elsewhere in our responses to comments, we believe that this approach is permissible under the CAA and the BART Guidelines. The prior EPA actions cited by the commenter are not relevant to our action on New Mexico’s NO_x BART determination for SJGS. While both the Four Corners and Idaho actions contained BART alternatives that demonstrated greater reasonable progress, we are not evaluating a BART alternative here. Moreover, while the Idaho action also involved two new BART determinations that happened to be more stringent than the state’s original BART determinations, neither the CAA nor our regulations require a new BART determination to be more stringent in every instance in order to supersede a prior BART determination.

Comment: One commenter argued that the CAA requires that any

⁹ The comment provided a citation to 79 FR 23273 (April 28, 2014) relating to the Tasco facility in Idaho, and one to “78 FR 24112,” which we interpret as having intended to refer to 78 FR 60700 (October 2, 2013) (bearing “FR Doc. 2013–24112”).

⁸ See New Source Review Workshop Manual (Oct. 1990), available at <http://www.epa.gov/ttn/nsr/gen/wkshpman.pdf>.

⁷ 40 CFR part 51, app. Y, section IV.D.5.

alternative regional haze strategy must outperform the visibility gains of the existing strategy or, in other words, be “better than BART,” and the 2013 RH SIP revision fails to accomplish this. Citing to CAA section 7410(a) and (j), the commenter argued that the characterization of the 2013 RH SIP revision as including a new BART determination is plainly unlawful because the State has not undertaken the BART analysis required by the CAA and BART Guidelines, and EPA did not provide any explanation for why the SIP revision is approvable when the FIP had a more stringent BART determination.

Response: As explained above, the 2013 RH SIP revision was not submitted to meet section 51.308(e)(2) requirements, so it is not required to be better than BART. As we stated in the proposal, the 2013 RH SIP revision contains a new, source-specific BART analysis that is based on different underlying facts than those that were present when we evaluated our FIP. Thus, the commenter’s assertion that the state failed to undertake a BART analysis is clearly incorrect. Finally, contrary to the commenter’s assertion, CAA section 110(j) does not prohibit a state from submitting a SIP that is less stringent than a FIP. Our proposal provided an analysis conducted under section 110(j), which showed that the 2013 RH SIP revision would not interfere with the attainment or maintenance of any NAAQS or any other CAA requirement. See 79 FR at 26920. Because New Mexico complied with the CAA’s visibility protection provisions, the Regional Haze Rule, and the BART Guidelines, and made a reasonable control determination based on the weighing of the five factors, EPA is required to approve the 2013 RH SIP revision.

Comment: One commenter stated that the 2013 RH SIP revision does not comply with the mandatory unit-specific analytical approach required by the CAA. The commenter argued that the BART Guidelines require BART to be determined on a unit-specific basis because a BART emission limit must be established for each affected emission unit. The commenter also pointed out that the BART Guidelines provide an example of a unit-specific approach where they state that “control options must be analyzed for Units B through H as well as Unit A.” Consequently, the commenter concluded that New Mexico and EPA are required to follow the unit-specific approach.

Response: We disagree with this comment. The portion of the BART Guidelines cited by the commenter explains how all BART units at the

subject to BART source must be included in the BART analysis. The 2013 SIP revision implements BART at each BART-subject unit by requiring either shutdowns or controls. Also, while the BART Guidelines clearly contemplate that states will analyze technical feasibility and cost-effectiveness on a unit-specific basis, they do not explicitly require such an approach, nor do they provide guidance for situations in which a source proposes unit shutdowns as an emission-reduction strategy. Moreover, contrary to the commenter’s assertion, the CAA does not mandate any specific analytical approach. Consequently, in situations where a state is contemplating a novel control scenario not contemplated by the BART Guidelines, such as one that involves unit shutdowns, we believe that states have the flexibility to tailor their BART analyses by evaluating and weighing the BART factors on a facility-wide (i.e., “source”) basis rather than on a unit-specific basis in order to account for the emission reductions and benefits that would directly result from the shutdowns. Moreover, while BART emission limits are also typically established for each unit that comprises the BART-eligible source, as New Mexico chose to do here, nothing in the CAA or BART Guidelines prevents a state from setting an emission limit that averages emissions across multiple units, so long as that limit is “based on the degree of reduction achievable through the best system of continuous emission reduction for each pollutant.” See 40 CFR 51.301.

Comment: One commenter stated that a facility-wide BART determination is inconsistent with other EPA actions. The commenter cited to EPA actions in Indiana and Montana to support this contention.¹⁰ The commenter also pointed out that EPA used a unit-specific approach to analyzing the first four factors when promulgating its FIP for SJGS. The commenter called EPA’s proposal an unexplained departure from EPA’s past practice in implementing its binding guidelines.

Response: We disagree with this comment for the same reasons explained above. EPA’s actions in Indiana, Montana, and our FIP for SJGS did not involve unit shutdowns and therefore are not determinative of how the BART statutory factors should be

¹⁰ Specifically, the commenter cited our Indiana regional haze SIP action (77 FR 3975, 3982 (Jan. 26, 2012)) for its statement that a source needs to “implement BART at each BART-subject unit,” and the Montana regional haze FIP (77 FR 57864, Sept. 18, 2012) for discussing statutory BART factors for units at a BART source.

considered and weighed in this context. Also, contrary to the commenter’s assertion, we explained in our proposal why New Mexico’s approach was reasonable in light of the unique circumstances presented and, on that basis, cannot validly be seen as any departure from past actions. As was stated, the state’s approach reasonably takes into account the visibility, energy, and non-air quality environmental benefits associated with unit shutdowns. See 79 FR 26918. Furthermore, the 2013 SIP revision implements BART at each BART-subject unit by requiring either shutdowns or controls.

Comment: A commenter stated that EPA’s proposal arbitrarily rejected SCR in favor of less effective pollution controls even though EPA found that an emission limitation based on SCR was BART in the FIP. The commenter explained that SCR provides the best visibility outcomes and is cost-effective.

Response: Under different factual circumstances, we determined that SCR for the four SJGS units had reasonable average cost-effectiveness values and would promote significant visibility improvements, thereby supporting the basis for the emission limits set forth in the FIP. In the 2013 RH SIP revision, New Mexico demonstrated that SNCR in tandem with shutdowns has visibility benefits on par with those anticipated from the FIP at much lower overall costs, while also reducing overall energy and non-air quality environmental impacts. Although we continue to believe that SCR is a cost-effective control and are not abandoning the legal and technical basis for our FIP, we believe that when cost, energy and non-air quality environmental impacts, and anticipated visibility benefits are all taken into consideration, New Mexico’s determination that the State Alternative is BART is reasonable. While SCR remains cost-effective on a \$/ton basis, the incremental visibility benefit of the four-SCR scenario of the FIP over the State Alternative is small at most Class I areas, and New Mexico reasonably concluded that this small additional visibility benefit, when considered with the difference in the energy and non-air quality environmental impacts, did not justify the large increase in costs associated with the installation of SCR on all four units.

Comment: One commenter stated that the visibility impacts of the State Alternative are significantly worse than the four-SCR scenario in the FIP. The commenter explained that the difference in visibility impacts between the two scenarios will be 0.47 dv at Mesa Verde, 0.24 dv at Canyonlands, and 0.13 dv at

Weminuche. The sum of these visibility differences is 0.84 dv, which is above the 0.5 dv threshold that is used to determine "significance." Also, the State Alternative will result in five more days with impacts over 1 dv at Mesa Verde, three more days at Arches, and two more days at both Canyonlands and La Garita when compared to the four-SCR scenario in the FIP.

Response: As we stated in the proposal when comparing the two scenarios, while we have some concern with the modeled visibility differences between the two control scenarios for Mesa Verde and Canyonlands, we find that the State's decision to select the State Alternative was ultimately reasonable, especially considering the costs of compliance and the energy and non-air quality environmental impacts of the two scenarios. We noted that the difference in visibility impacts between the two scenarios are negligible at most of the Class I areas examined. The average difference at the 13 other Class I areas (other than Mesa Verde, Canyonlands, and Weminuche) is less than 0.1 dv between the two control scenarios. In considering the number of days impacted, eleven Class I areas show no difference in the number of days with impacts over 1 dv. We also note that the typical application of 0.5 dv as a contribution threshold comes in the context of assessing impacts at a single Class I area, not cumulative impacts across multiple Class I areas.

Comment: One commenter stated that the CAA requires EPA to either improve the State Alternative or reject it altogether.

Response: We disagree with this comment. As we explained earlier, EPA is required to approve any SIP revision that meets CAA requirements. See CAA section 110(k)(3), (I). EPA does not have authority to improve a SIP revision that is otherwise approvable, and the commenter has provided no basis for EPA to disapprove the 2013 RH SIP revision.

Comment: One commenter stated that EPA based its proposed approval on a fundamentally flawed cost-benefit analysis that artificially inflated the cost and artificially reduced the benefits of SCR. The commenter also thought that New Mexico underestimated the costs of SNCR. The commenter argued that EPA had no rational basis for concluding that cost refinements would not change the result. The commenter cited to *Center for Biological Diversity v. National Highway Traffic Safety Administration*, 538 F.3d 1172, 1201–03 (9th Cir. 2008), for the proposition that EPA must recalculate a cost value that would significantly alter the analysis. With

cost corrections, the commenter believed that New Mexico's capital cost assumptions for SCR would be cut in half, demonstrating that SCR remains cost-effective at Units 1 and 4. The commenter provided an attachment that highlighted how New Mexico's cost range for SCR at SJGS was well above the cost per kilowatt for SCR demonstrated by other cost studies for comparable retrofits.

Response: We maintain our view that SCR has favorable and reasonable average cost-effectiveness values at SJGS under the technical record developed for the FIP, and we agree with the comment that New Mexico's cost range for SCR is still high compared to other cost studies. Even so, as discussed in response to comments from PNM concerning cost, the state's BART selection in this case is reasonable. New Mexico was advantaged with the full technical record that we developed to promulgate the FIP, and the state declared that it would favor the 2013 RH SIP revision even if it were to adopt and utilize the lower costs for SCR that we had relied on in promulgating the FIP. In addition, in our proposed action, we recalculated the annual cost and incremental cost-effectiveness of the four-SCR option using the cost estimates presented in the FIP. Thus, there is a significant record basis for our finding that lower SCR costs would not change the result of our action.

As to the state's alleged underestimation of SNCR costs, the comment does not provide any details to enable us to provide a response. We also considered the Ninth Circuit's decision in *Center for Biological Diversity v. National Highway Traffic Safety Administration* and do not see how it has any bearing on the issue of costs in this case. In that case, the Ninth Circuit faulted NHTSA for its failure to monetize the value of carbon emissions in setting fuel economy standards. In addition to the fact that the case did not concern BART determinations, the comment does not identify any particular line item in the state's analysis of SCR costs that has not been monetized.

Comment: One commenter stated that our proposal failed to consider the prospect of installing SCR on Units 1 and 4, while still shutting down Units 2 and 3. The commenter noted that such a scenario would lead to even greater visibility benefits. The commenter provided modeled visibility results and estimates of the level of emission reductions that would result from this scenario and concluded that the State Alternative was inferior.

Response: While we acknowledge that a scenario at SJGS involving two shutdowns and two SCR's would result in superior visibility benefits than the State Alternative or even the FIP, the state did not present this scenario to us in the 2013 RH SIP revision. As we explained above, we are required to evaluate the SIP revision that is before us. Moreover, in situations that involve the voluntary retirement of units, states need the flexibility to analyze control scenarios that have the support of the source owner. There is no evidence in the record indicating that PNM would have volunteered to retire two of its units if SCR were required on the remaining units.

Comment: One commenter stated that the NMED's BART analysis contains a flawed visibility analysis. The commenter argued that NMED arbitrarily ignored fourteen Class I areas between 300 km and 440 km from SJGS in its cumulative visibility analysis, which was an arbitrary and unexplained departure from EPA's analytical approach that was followed in analyzing the Big Stone and Colstrip power plants. The commenter concluded that the failure to assess impacts at more distant Class I areas masked the full visibility benefit of SCR. Finally, the commenter referred to comments submitted by the National Park Service to New Mexico on their proposed SIP revision, which stated that the visibility modeling was not done according to the BART Guidelines.

Response: We disagree with this comment. In regard to selecting a model and developing a modeling protocol, the BART Guidelines refer to our Guideline on Air Quality Models¹¹ and the Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 report.¹² The IWAQM report reviewed model-performance evaluations of CALPUFF as a function of distance from the source and recommended the use of CALPUFF for transport distances of order 200 km and less. The report also recommended that the use of CALPUFF for characterizing transport beyond 200 to 300 km should be done cautiously with

¹¹ Appendix W to 40 CFR Part 51 "Guideline to Air Quality Models" states: "It was concluded from these case studies that the CALPUFF dispersion model had performed in a reasonable manner, and had no apparent bias toward over or under prediction, so long as the transport distance was limited to less than 300 km."

¹² Environmental Protection Agency, 1998. Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long-Range Transport Impacts. Publication No. EPA-454/R-98-019. Office of Air Quality Planning & Standards, Research Triangle Park, NC. (NTIS No. PB 99-121089)

an awareness of the likely problems involved. Consistent with this recommendation, we believe that it is reasonable to use CALPUFF to evaluate visibility impacts up to 300 km. While we agree with the commenter that emissions from SJGS may impact Class I areas at distances greater than 300 km, the IWAQM report cautions that CALPUFF results are less reliable at distances greater than 300 km. Therefore, we do not think that it is arbitrary to exclude more distant receptors from a visibility analysis or to base the visibility assessment for a BART determination on visibility impacts within 300 km from the source.

Contrary to the commenter's suggestion, this was the same approach followed when modeling the visibility benefits associated with various control scenarios at the Colstrip power plant. See 77 FR 57867–68. In regard to the Big Stone power plant, South Dakota performed modeling for Class I areas beyond 300 km only because there were no Class I areas within 300 km of the source. As a result, South Dakota worked with EPA to develop a special modeling protocol that incorporated CALPUFF's puff-splitting option despite the IWAQM report's conceptual concerns with that feature. Moreover, South Dakota expressly acknowledged that it was departing from EPA's guidance. Consequently, we believe that Big Stone presented an exception to the general rule that CALPUFF be applied to assess visibility impacts only on those Class I areas within 300 km of the source. Finally, in regard to NPS's comments concerning the visibility analysis during the state process, we agree with the response provided at the time by NMED¹³ and note that NPS did not raise these concerns again in their comments on our proposed action.

Comment: A commenter stated that the proposed 0.23 lb/MMBtu limit does not apply to each unit due to a cross-unit averaging provision, so the emissions from a given unit could be higher than 0.23 lb/MMBtu.

Response: In this case, it is appropriate for the 2013 RH SIP revision to allow SJGS to average emissions across its BART-eligible emission units within the fence line. The BART Guidelines allow this approach when, as here, the reductions would be equal to those reductions that would be obtained by simply controlling each of the BART-eligible units that constitute the BART source. Because SJGS is required to demonstrate continuous compliance over a reasonable averaging

time, the reductions associated with the assigned limit are assured. As part of its five-factor analysis, New Mexico evaluated the control effectiveness of SNCR and determined that SNCR could achieve an emission rate of 0.23 lb/MMBtu on each unit based on tests and an updated performance guarantee from the vendor.¹⁴ Consistent with the BART Guidelines, the permit conditions at A112C specify the averaging time and calculation methodology for the enforceable emission limit, which must be calculated on a 30-boiler-operating-day basis, averaged across the two units. While we agree with the commenter that emissions from either unit may exceed 0.23 lb/MMBtu on a given day, the combined emissions from both units cannot exceed 0.23 lb/MMBtu over the course of the averaging period, so total emission reductions will be equal to those that would be obtained under two separate limits.

Comment: One commenter alleged that our proposal implied that PNM's decision to retire Units 2 and 3 was solely taken for the purpose of meeting BART. The commenter suggested that EPA should explicitly state whether this was the case for the record or discuss whether independent reasons would require or motivate the shutdown of the units.

Response: We fail to see how this comment is relevant to our evaluation of the 2013 RH SIP revision. Nevertheless, we note that, when developing the FIP, we assumed that the remaining useful life of all four units at SJGS exceeded 30 years, and the 2013 RH SIP revision provides no information that would change that assumption. Nor does the SIP revision provide any information to suggest that PNM had motivations other than creating a more cost-effective BART-compliance scenario when volunteering to shut down Units 2 and 3.

Comment: A commenter stated that, while our proposal implied that there will be no capacity increase elsewhere or at the SJGS to replace the lost capacity from Units 2 and 3, the final rule should make this explicit to properly give weight to the benefits from their retirement.

Response: We disagree with this comment. As an initial matter, our proposal did not imply that the retirement of Units 2 and 3 could be undertaken without the possible need to address lost capacity. Most likely, the lost capacity will be replaced through some combination of conservation,

efficiency, and new capacity. More importantly, however, the CAA does not require an analysis of the statutory factors to include the consideration of hypothetical emissions increases at other facilities or even at the same facility due to lost capacity. We also note that any emissions units that might be constructed at SJGS in the future would likely be subject to both BACT and any applicable new source performance standards. Moreover, all emission units would be subject to analysis under the regional haze requirements for reasonable progress in future planning periods.

Comment: One commenter asserted that our proposal failed to explain how New Mexico could permissibly reach a conclusion that directly opposes EPA's conclusion in the FIP. The commenter stated that the voluntary retirement of Units 2 and 3 did not change the fact that SCR remains cost-effective at the Units 1 and 4.

Response: We disagree that the 2013 RH SIP reached a conclusion that directly opposes the conclusion we made in promulgating the FIP. Under different factual circumstances, we determined that SCR for the four SJGS units had reasonable average cost-effectiveness values and would promote significant visibility improvements, thereby supporting the basis for the emission limits set forth in the FIP. As we stated in the proposal, the 2013 RH SIP revision contains a new, source-specific BART analysis that is based on different underlying facts than those that were present when we evaluated our FIP. We were not presented with the retirement of Units 2 and 3 when we promulgated the FIP. With this information in hand, New Mexico permissibly conducted a new BART analysis using a facility-wide approach that allowed the full range of visibility, energy, and non-air quality environmental benefits associated with the shutdowns to be taken into account. While the average cost-effectiveness of SCR on Units 1 and 4 remains reasonable, New Mexico demonstrated that the incremental cost-effectiveness of the four-SCR scenario in our FIP over the State Alternative was high when compared against the additional visibility improvements from the former, while also considering the energy, and non-air quality environmental benefits associated with the State Alternative.

Comment: One commenter thought that the timeline for the installation of SNCR was too long because SNCR is a simpler technology to install than SCR.

Response: We agree that SNCR is a simpler technology to install than SCR

¹³ Available as NMED Ex. 14 of the 2013 RH SIP revision.

¹⁴ Public Service Company of New Mexico, San Juan Generating Station, Revised SNCR Analysis, February 11, 2011 (2011 NM RH SIP, NMED Ex. 7).

and requires less time for installation. New Mexico determined, and we agree, that the compliance timeframe in the 2013 RH SIP revision is as expeditious as practicable, as required under 40 CFR 51.308(e)(1)(iv).

Comment: One commenter thought that the 0.05 lb/MMBtu rate used for the study of SCR as a BART control option was likely too high. The commenter suggested that many units, such as those in Dry Fork, WY and Morgantown, MD, are routinely achieving emission rates in the range of 0.02–0.04 lb/MMBtu. Reducing the studied emission limit for SCR to 0.04 lb/MMBtu would show the option to be even more cost-effective.

Response: We disagree that lower control rates needed to be evaluated for SCR. We evaluated the monthly emission data from these two facilities for the past several years (available at EPA's Air Market Program data Web site: www.epa.gov/ampd). All three units have monthly emission rates that sometimes exceed 0.04 lb/MMBtu. Indeed, the Morgantown units have months where the monthly emission rate is 0.05 lb/MMBtu or higher. In promulgating the FIP, we evaluated the performance of both new and retrofit SCRs and determined that 0.05 lb/MMBtu on a 30-boiler-operating-day average was the appropriate emission limit for SCR at the SJGS units. See 76 FR 491 and 76 FR 52388. New Mexico appropriately used this same rate in their cost and visibility analyses for the four-SCR scenario as part of its BART evaluation.

IV. Statutory and Executive Order Reviews

The Administrator is required to approve a SIP submission that complies with the provisions of the Clean Air Act and applicable Federal regulations. 42 U.S.C. 7410(k); 40 CFR 52.02(a). Thus, in reviewing SIP submissions, EPA's role is to approve state choices, provided that they meet the criteria of the Clean Air Act. Accordingly, this action merely approves state law as meeting Federal requirements and does not impose additional requirements beyond those imposed by state law. For that reason, this action:

- Is not a "significant regulatory action" subject to review by the Office of Management and Budget under Executive Order 12866 (58 FR 51735, October 4, 1993);
- does not impose an information collection burden under the provisions of the Paperwork Reduction Act (44 U.S.C. 3501 *et seq.*);
- is certified as not having a significant economic impact on a

substantial number of small entities under the Regulatory Flexibility Act (5 U.S.C. 601 *et seq.*);

- does not contain any unfunded mandate or significantly or uniquely affect small governments, as described in the Unfunded Mandates Reform Act of 1995 (Pub. L. 104–4);
- does not have Federalism implications as specified in Executive Order 13132 (64 FR 43255, August 10, 1999);
- is not an economically significant regulatory action based on health or safety risks subject to Executive Order 13045 (62 FR 19885, April 23, 1997);
- is not a significant regulatory action subject to Executive Order 13211 (66 FR 28355, May 22, 2001);
- is not subject to requirements of Section 12(d) of the National Technology Transfer and Advancement Act of 1995 (15 U.S.C. 272 note) because application of those requirements would be inconsistent with the Clean Air Act; and
- does not provide EPA with the discretionary authority to address, as appropriate, disproportionate human health or environmental effects, using practicable and legally permissible methods, under Executive Order 12898 (59 FR 7629, February 16, 1994).

In addition, the SIP is not approved to apply on any Indian reservation land or in any other area where EPA or an Indian tribe has demonstrated that a tribe has jurisdiction. In those areas of Indian country, the rule does not have tribal implications as specified by Executive Order 13175 (65 FR 67249, November 9, 2000), nor will it impose substantial direct costs on tribal governments or preempt tribal law. Consistent with EPA policy, EPA offered consultation to tribes regarding this rulemaking action.

The Congressional Review Act, 5 U.S.C. 801 *et seq.*, as added by the Small Business Regulatory Enforcement Fairness Act of 1996, generally provides that before a rule may take effect, the agency promulgating the rule must submit a rule report, which includes a copy of the rule, to each House of the Congress and to the Comptroller General of the United States. EPA will submit a report containing this action and other required information to the U.S. Senate, the U.S. House of Representatives, and the Comptroller General of the United States prior to publication of the rule in the **Federal Register**. A major rule cannot take effect until 60 days after it is published in the **Federal Register**. This action is not a "major rule" as defined by 5 U.S.C. 804(2).

Under section 307(b)(1) of the Clean Air Act, petitions for judicial review of this action must be filed in the United States Court of Appeals for the appropriate circuit by December 8, 2014. Filing a petition for reconsideration by the Administrator of this final rule does not affect the finality of this action for the purposes of judicial review nor does it extend the time within which a petition for judicial review may be filed, and shall not postpone the effectiveness of such rule or action. This action may not be challenged later in proceedings to enforce its requirements. (See section 307(b)(2).)

List of Subjects in 40 CFR Part 52

Environmental protection, Air pollution control, Incorporation by reference, Intergovernmental relations, Nitrogen dioxide, Particulate matter, Regional haze, Reporting and recordkeeping requirements, Sulfur dioxide, and Visibility.

Dated: September 26, 2014.

Samuel Coleman,

Acting Regional Administrator, Region 6

Therefore, 40 CFR part 52 is amended as follows:

PART 52—APPROVAL AND PROMULGATION OF IMPLEMENTATION PLANS

- 1. The authority citation for part 52 continues to read as follows:

Authority: 42 U.S.C. 7401 *et seq.*

- 2. In § 52.1620:

- a. In paragraph (d), the table titled "EPA-Approved New Mexico Source-Specific Requirements" is amended by adding a first entry for "Units 1, 2, 3, & 4 of the San Juan Generating Station" to the table.

- b. In paragraph (e), the second table entitled "EPA Approved Nonregulatory Provisions and Quasi-Regulatory Measures in the New Mexico SIP," is amended by revising the entry for "Regional Haze SIP under 40 CFR 51.309, Statewide (except Bernalillo County)" and adding a new entry at the end for "Revision to satisfy the requirements of Clean Air Act 110(a)(2)(D)(i)(II) with respect to visibility for the 8-hour Ozone and PM_{2.5} NAAQS".

The additions and revisions read as follows:

§ 52.1620. Identification of plan.

* * * * *

(d) * * *

EPA-APPROVED NEW MEXICO SOURCE-SPECIFIC REQUIREMENTS

Name of source	Permit number	State approval/ effective date	EPA Approval date	Explanation
Units 1, 2, 3, & 4 of the San Juan Generating Station.	NSR Permit No. 0063-M6R3, Section A112C.	11/1/2013	10/9/14 [Insert FR citation]	Ch. 10 (BART) of SIP under 40 CFR 51.309(g).

(e) * * *

* * * * *

EPA APPROVED NONREGULATORY PROVISIONS AND QUASI-REGULATORY MEASURES IN THE NEW MEXICO SIP

Name of SIP provision	Applicable geographic or nonattainment area	State submittal/ effective date	EPA approval date	Explanation
Regional Haze SIP under 40 CFR 51.309.	Statewide (except Bernalillo County).	6/24/2011, 10/7/2013, 11/1/2013	11/27/2012, 77 FR 70693, 10/9/14 [Insert FR citation].	
Revision to satisfy the requirements of Clean Air Act 110(a)(2)(D)(i)(II) with respect to visibility for the 8-hour Ozone and PM _{2.5} NAAQS.	Statewide (except Bernalillo County).	10/7/2013, 11/1/2013	10/9/14 [Insert FR citation].	

§ 52.1629 [Removed and Reserved]

■ 3. Section 52.1629 is removed and reserved.

[FR Doc. 2014-23904 Filed 10-8-14; 8:45 am]

BILLING CODE 6560-50-P

ENVIRONMENTAL PROTECTION AGENCY

40 CFR Part 60

[EPA-R08-OAR-2014-0272; FRL-9917-49-Region 9]

Automatic Delegation of Authority to the States of Colorado, Montana, North Dakota, South Dakota, Utah, and Wyoming To Implement and Enforce New Source Performance Standards

AGENCY: Environmental Protection Agency (EPA).

ACTION: Direct final rule.

SUMMARY: This action informs the public that on February 27, 2014, the EPA authorized automatic delegation to implement and enforce Clean Air Act (CAA) New Source Performance Standards (NSPS) to the states of Colorado, Montana, North Dakota, South Dakota, Utah, and Wyoming (hereafter Region 8 states). Also in this action, EPA is taking direct final action to delete the delegation status table of NSPS for Region 8 states in the Code of Federal Regulations (CFR) and replace it with a Web page address reflecting current delegation status of Region 8 states.

DATES: This rule is effective on December 8, 2014 without further notice, unless EPA receives adverse comment by November 10, 2014. If adverse comment is received, EPA will publish a timely withdrawal of the direct final rule in the **Federal Register** informing the public that the rule will not take effect.

ADDRESSES: Submit your comments, identified by Docket ID No. EPA-R08-OAR-2014-0272, by one of the following methods:

- <http://www.regulations.gov>. Follow the on-line instructions for submitting comments.
- Email: fulton.abby@epa.gov.
- Fax: (303) 312-6064 (please alert the individual listed in the **FOR FURTHER INFORMATION CONTACT** if you are faxing comments).
- Mail: Director, Air Program, Environmental Protection Agency (EPA), Region 8, Mailcode 8P-AR, 1595 Wynkoop Street, Denver, Colorado 80202-1129.
- Hand Delivery: Director, Air Program, Environmental Protection Agency (EPA), Region 8, Mailcode 8P-AR, 1595 Wynkoop Street, Denver, Colorado 80202-1129. Such deliveries are only accepted Monday through Friday, 8:00 a.m. to 4:30 p.m., excluding Federal holidays. Special arrangements should be made for deliveries of boxed information.

Instructions: Direct your comments to Docket EPA-R08-OAR-2014-0272. EPA's policy is that all comments received will be included in the public docket without change and may be

made available online at <http://www.regulations.gov>, including any personal information provided, unless the comment includes information claimed to be Confidential Business Information (CBI) or other information whose disclosure is restricted by statute. Do not submit information that you consider to be CBI or otherwise protected through <http://www.regulations.gov> or email. The <http://www.regulations.gov> Web site is an "anonymous access" system, which means EPA will not know your identity or contact information unless you provide it in the body of your comment. If you send an email comment directly to EPA, without going through <http://www.regulations.gov> your email address will be automatically captured and included as part of the comment that is placed in the public docket and made available on the Internet. If you submit an electronic comment, EPA recommends that you include your name and other contact information in the body of your comment and with any disk or CD-ROM you submit. If EPA cannot read your comment due to technical difficulties and cannot contact you for clarification, EPA may not be able to consider your comment. Electronic files should avoid the use of special characters, any form of encryption, and be free of any defects or viruses. For additional instructions on submitting comments, go to Section I. General Information of the **SUPPLEMENTARY INFORMATION** section of this document.