

License Amendment No. 34 to COLs, NPF-91 and NPF-92, to the licensee. The exemption is required by Paragraph A.4 of Section VIII, "Processes for Changes and Departures," Appendix d, to 10 CFR part 52 to allow the licensee to depart from Tier 1 information. With the requested amendment, the licensee sought proposed changes that would revise the Updated Final Safety Analysis Report by making changes to the Initial Test Program (ITP), and making changes to the corresponding Tier 1 information. Specifically, the licensee redefined certain "construction and installation tests" as "component tests" and moved them to the first phase of the ITP. Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemption and issued the amendment concurrently, rather than in sequence. This included issuing a combined safety evaluation containing the NRC staff's review of both the exemption request and the license amendment. The exemption met all applicable regulatory criteria set forth in 10 CFR 50.12, 10 CFR 52.7, and Section VIII.A.4 of Appendix d to 10 CFR part 52. The license amendment was found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML15138A140.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to the licensee for VEGP Units 3 and 4 (COLs NPF-91 and NPF-92). The exemption documents for VEGP Units 3 and 4 can be found in ADAMS under Accession Nos. ML15138A127 and ML15138A132, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COLs NPF-91 and NPF-92 are available in ADAMS under Accession Nos. ML15138A116 and ML15138A120, respectively. A summary of the amendment documents is provided in Section III of this document.

## II. Exemption

Reproduced below is the exemption document issued to VEGP Units 3 and Unit 4. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In a letter dated November 21, 2014, the licensee requested from the Commission an exemption to allow departures from Tier 1 information in

the certified DCD incorporated by reference in 10 CFR part 52, Appendix d, as part of license amendment request 14-010, "Initial Test Program Changes."

For the reasons set forth in Section 3.1 of the NRC staff's Safety Evaluation that supports this license amendment, which can be found in ADAMS under Accession No. ML15138A140, the Commission finds that:

A. The exemption is authorized by law;

B. the exemption presents no undue risk to public health and safety;

C. the exemption is consistent with the common defense and security;

D. special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;

E. the special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption; and

F. the exemption will not result in a significant decrease in the level of safety otherwise provided by the design.

2. Accordingly, the licensee is granted an exemption from the certified DCD Tier 1 Section 3.4, as described in the licensee's request dated November 21, 2014. This exemption is related to, and necessary for, the granting of License Amendment No. 34, which is being issued concurrently with this exemption.

3. As explained in Section 5 of the NRC staff's Safety Evaluation that supports this license amendment (ADAMS Accession No. ML15138A140), this exemption meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

## III. License Amendment Request

By letter dated November 21, 2014, the licensee requested that the NRC amend the COLs for VEGP, Units 3 and 4, COLs NPF-91 and NPF-92. The proposed amendment is described in Section I of this **Federal Register** notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or COL, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** on January 6, 2015 (80 FR 520). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

## IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the staff granted the exemption and issued the amendment that the licensee requested on November 21, 2014.

The exemption and amendment were issued on June 4, 2015, as part of a combined package to the licensee (ADAMS Accession No. ML15138A052).

Dated at Rockville, Maryland, this 13th day of December 2016.

For the Nuclear Regulatory Commission.

**Jennifer Dixon-Herrity,**

*Chief, Licensing Branch 4, Division of New Reactor Licensing, Office of New Reactors.*

[FR Doc. 2016-30631 Filed 12-19-16; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-025 and 52-026; NRC-2008-0252]

### **Southern Nuclear Operating Company, Inc., Vogtle Electric Generating Plant, Units 3 and 4; Compressed and Instrument Air System High Pressure Air Subsystem Changes**

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Exemption and combined license amendment; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from the certification information of Tier 1 of the generic design control document (DCD) and is issuing License Amendment No. 46 to Combined Licenses (COL), NPF-91 and NPF-92. The COLs were issued to Southern Nuclear Operating Company, Inc., and Georgia Power Company, Oglethorpe Power Corporation, MEAG Power SPVM, LLC, MEAG Power SPVJ, LLC, MEAG Power SPVP, LLC, Authority of Georgia, and

the City of Dalton, Georgia (the licensee); for construction and operation of the Vogtle Electric Generating Plant (VEGP) Units 3 and 4, located in Burke County, Georgia.

The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

**DATES:** The Exemption was issued on February 25, 2016.

**ADDRESSES:** Please refer to Docket ID NRC-2008-0252 when contacting the NRC about the availability of information regarding this document. You may access information related to this document, which the NRC possesses and is publicly available, using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0252. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated August 14, 2014 (ADAMS Accession No. ML14227A707), and supplemented by letter dated January 16, 2015 (ADAMS Accession No. ML15016A416).

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

**FOR FURTHER INFORMATION CONTACT:** Chandu Patel, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone:

301-415-3025; email: [Chandu.Patel@nrc.gov](mailto:Chandu.Patel@nrc.gov).

## SUPPLEMENTARY INFORMATION:

### I. Introduction

The NRC is granting an exemption from paragraph B of Section III, "Scope and Contents," of Appendix d, "Design Certification Rule for the AP1000," to part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), and issuing License Amendment No. 46 to COLs, NPF-91 and NPF-92, to the licensee. The exemption is required by Paragraph A.4 of Section VIII, "Processes for Changes and Departures," Appendix d, to 10 CFR part 52 to allow the licensee to depart from Tier 1 information. With the requested amendment, the licensee sought proposed changes that would revise the Updated Final Safety Analysis Report in the form of departures from the plant-specific licensing basis documents, with regard to removing an air supply line from the compressed and instrument air system to the generator breaker package as a result of the change from an air-blast type generator circuit breaker (GCB) to a sulfur hexafluoride gas type GCB. Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemption and issued the amendment concurrently, rather than in sequence. This included issuing a combined safety evaluation containing the NRC staff's review of both the exemption request and the license amendment. The exemption met all applicable regulatory criteria set forth in 10 CFR 50.12, 10 CFR 52.7, and Section VIII.A.4 of Appendix d to 10 CFR part 52. The license amendment was found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML16019A419.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to the licensee for VEGP Units 3 and 4 (COLs NPF-91 and NPF-92). The exemption documents for VEGP Units 3 and 4 can be found in ADAMS under Accession Nos. ML16019A400 and ML16019A402, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COLs NPF-91 and NPF-92 are available in ADAMS under Accession Nos. ML16019A390 and ML16019A393, respectively. A summary of the amendment documents is provided in Section III of this document.

### II. Exemption

Reproduced below is the exemption document issued to VEGP Units 3 and Unit 4. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In a letter dated August 14, 2014, and supplemented by letter dated January 16, 2015, the licensee requested from the Commission an exemption to allow departures from Tier 1 information in the certified DCD incorporated by reference in 10 CFR part 52, Appendix d, as part of license amendment request 14-009, "Compressed and Instrument Air System High Pressure Air Subsystem Changes."

For the reasons set forth in Section 3.1 of the NRC staff's Safety Evaluation that supports this license amendment, which can be found in ADAMS under Accession No. ML16019A419, the Commission finds that:

A. The exemption is authorized by law;

B. the exemption presents no undue risk to public health and safety;

C. the exemption is consistent with the common defense and security;

D. special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;

E. the special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption; and

F. the exemption will not result in a significant decrease in the level of safety otherwise provided by the design.

2. Accordingly, the licensee is granted an exemption from the certified DCD Tier 1 information, as described in the licensee's request dated August 14, 2014, and supplemented by letter dated January 16, 2015. This exemption is related to, and necessary for the granting of License Amendment No. 46, which is being issued concurrently with this exemption.

3. As explained in Section 5.0 of the NRC staff's Safety Evaluation (ADAMS Accession No. ML16019A419), this exemption meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

### III. License Amendment Request

By letter dated August 14, 2014, and supplemented by letter dated January 16, 2015, the licensee requested that the NRC amend the COLs for VEGP, Units 3 and 4, COLs NPF-91 and NPF-92. The proposed amendment is described in Section I of this **Federal Register** notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or COL, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** on November 12, 2014 (79 FR 67204). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

### IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the staff granted the exemption and issued the amendment that the licensee requested on August 14, 2014, and supplemented by letter dated January 16, 2015.

The exemption and amendment were issued on February 25, 2016, as part of a combined package to the licensee (ADAMS Accession No. ML16019A374).

Dated at Rockville, Maryland, this 13th day of December 2016.

For the Nuclear Regulatory Commission,  
**Jennifer Dixon-Herrity**,  
Chief, Licensing Branch 4, Division of New  
Reactor Licensing, Office of New Reactors.  
[FR Doc. 2016-30607 Filed 12-19-16; 8:45 am]

**BILLING CODE 7590-01-P**

### NUCLEAR REGULATORY COMMISSION

[NRC-2016-0256]

#### Biweekly Notice; Applications and Amendments to Facility Operating Licenses and Combined Licenses Involving No Significant Hazards Considerations

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Biweekly notice.

**SUMMARY:** Pursuant to Section 189a. (2) of the Atomic Energy Act of 1954, as amended (the Act), the U.S. Nuclear Regulatory Commission (NRC) is publishing this regular biweekly notice. The Act requires the Commission to publish notice of any amendments issued, or proposed to be issued, and grants the Commission the authority to issue and make immediately effective any amendment to an operating license or combined license, as applicable, upon a determination by the Commission that such amendment involves no significant hazards consideration, notwithstanding the pendency before the Commission of a request for a hearing from any person.

This biweekly notice includes all notices of amendments issued, or proposed to be issued, from November 22, 2016, to December 5, 2016. The last biweekly notice was published on December 6, 2016.

**DATES:** Comments must be filed by January 19, 2017. A request for a hearing must be filed by February 21, 2017.

**ADDRESSES:** You may submit comments by any of the following methods (unless this document describes a different method for submitting comments on a specific subject):

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID: NRC-2016-0256. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *Mail comments to:* Cindy Bladey, Office of Administration, Mail Stop: OWFN-12-H08, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

For additional direction on obtaining information and submitting comments, see "Obtaining Information and Submitting Comments" in the **SUPPLEMENTARY INFORMATION** section of this document.

**FOR FURTHER INFORMATION CONTACT:** Shirley Rohrer, Office of Nuclear

Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-5411, email: [Shirley.Rohrer@nrc.gov](mailto:Shirley.Rohrer@nrc.gov).

#### SUPPLEMENTARY INFORMATION:

##### I. Obtaining Information and Submitting Comments

###### A. Obtaining Information

Please refer to Docket ID NRC-2016-0256, facility name, unit number(s), plant docket number, application date, and subject when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- *Federal rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID: NRC-2016-0256.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

###### B. Submitting Comments

Please include Docket ID NRC-2016-0256, facility name, unit number(s), plant docket number, application date, and subject in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <http://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission.