

blanket authorization, under 18 CFR part 34, of future issuances of securities and assumptions of liability.

Any person desiring to intervene or to protest should file with the Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426, in accordance with Rules 211 and 214 of the Commission's Rules of Practice and Procedure (18 CFR 385.211 and 385.214). Anyone filing a motion to intervene or protest must serve a copy of that document on the Applicant.

Notice is hereby given that the deadline for filing protests with regard to the applicant's request for blanket authorization, under 18 CFR part 34, of future issuances of securities and assumptions of liability, is January 5, 2017.

The Commission encourages electronic submission of protests and interventions in lieu of paper, using the FERC Online links at <http://www.ferc.gov>. To facilitate electronic service, persons with Internet access who will eFile a document and/or be listed as a contact for an intervenor must create and validate an eRegistration account using the eRegistration link. Select the eFiling link to log on and submit the intervention or protests.

Persons unable to file electronically should submit an original and 5 copies of the intervention or protest to the Federal Energy Regulatory Commission, 888 First Street, NE., Washington, DC 20426.

The filings in the above-referenced proceeding are accessible in the Commission's eLibrary system by clicking on the appropriate link in the above list. They are also available for electronic review in the Commission's Public Reference Room in Washington, DC. There is an eSubscription link on the Web site that enables subscribers to receive email notification when a document is added to a subscribed docket(s). For assistance with any FERC Online service, please email FERCOnlineSupport@ferc.gov or call (866) 208-3676 (toll free). For TTY, call (202) 502-8659.

Dated: December 16, 2016.

Nathaniel J. Davis, Sr.,

Deputy Secretary.

[FR Doc. 2016-30839 Filed 12-21-16; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 619-164]

Pacific Gas and Electric Company and City of Santa Clara, California; Notice of Application Tendered for Filing With the Commission and Establishing Procedural Schedule for Licensing and Deadline for Submission of Final Amendments

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

a. *Type of Application:* New Major License

b. Project No.: 619-164

c. *Date Filed:* December 12, 2016

d. *Applicant:* Pacific Gas and Electric Company (PG&E) and City of Santa Clara, California

e. *Name of Project:* Bucks Creek Hydropower Project

f. *Location:* The Bucks Creek Project is located on Bucks, Grizzly, and Milk Ranch Creeks in Plumas County, California. Portions of the project are located within the Plumas National Forest.

g. *Filed Pursuant to:* Federal Power Act, 16 U.S.C. 791 (a)-825(r)

h. *Applicant Contact:* Alan Soneda, PG&E, Mail Code N13C, P. O. Box 770000, San Francisco, California 94177-0001; (415) 973-4054

i. *FERC Contact:* Alan Mitchnick at (202) 502-6074 or alan.mitchnick@ferc.gov.

j. This application is not ready for environmental analysis at this time.

k. The Project *Description:*

Bucks Lake Dam and Reservoir (Bucks Creek Development)

The Bucks Lake dam consists of a rock-fill with concrete face dam. It has a structural height of 123 feet and a length of 1,320 feet. Bucks Creek dam impounds Bucks Lake, which extends 5 miles from the dam. Total storage in the 1,827-acre reservoir is approximately 105,605 acre-feet at the normal maximum water surface elevation of approximately 5,157 feet. From Bucks Lake, the project's water flow is released immediately downstream into Lower Bucks Lake.

Three Lakes Dam and Reservoir, and Milk Ranch Conduit (Bucks Creek Development)

The Three Lakes dam consists of a rock-fill dam with a structural height of 30 feet and a length of 584 feet. Three Lakes dam impounds the flow of Milk

Ranch Creek, forming Upper Lake, Middle Lake, and Lower Lake, collectively known as Three Lakes reservoir. These water bodies are hydraulically linked and are approximately 0.75 mile from the dam. Total storage in the 40-acre reservoir is approximately 513 acre-feet at the normal maximum water surface elevation of approximately 6,074 feet.

Milk Ranch conduit conveys the project's water flow from Three Lakes reservoir and feeder diversions to Lower Bucks Lake. The maximum capacity of the approximately 8-mile-long conduit is about 70 cubic foot per second (cfs). It collects additional flow from several diversions located on unnamed tributaries.

Lower Bucks Lake Dam and Reservoir (Bucks Creek Development)

The Lower Bucks Lake dam consists of a concrete arch dam with a structural height of 99 feet and a length of 500 feet. Lower Bucks Creek dam impounds Lower Bucks Lake, which extends approximately 1.1 miles from the dam. Total storage in the 136-acre reservoir is approximately 5,843 acre-feet at the normal maximum water surface elevation of approximately 5,022 feet. Water is conveyed from Lower Bucks Lake to the Grizzly powerhouse by the Grizzly powerhouse tunnel.

Grizzly Powerhouse Tunnel (Grizzly Development)

The 12,320-foot-long Grizzly powerhouse tunnel (including a 4,900-foot-long buried penstock) conveys the water flow from Lower Bucks Lake to Grizzly powerhouse. The maximum flow capacity is 400 cfs.

Grizzly Powerhouse (Grizzly Development)

The Grizzly powerhouse is a 65-foot-long by 55-foot-wide, steel frame and concrete building constructed from reinforced concrete, with a maximum capacity of 20 megawatts (MW) and an average annual generation production of 48.9 gigawatt-hours (GWh). Grizzly powerhouse discharges the project's water flow directly into the Grizzly forebay.

A 3.2-mile-long, 115-kilovolt (kV) transmission line transmits power from Grizzly powerhouse to PG&E's 115-kV Caribou-Sycamore transmission line, part of the interconnected system.

Grizzly Forebay Dam and Reservoir (Bucks Creek Development)

The Grizzly forebay dam consists of a concrete arch dam with a structural height of 98 feet and a length of 520 feet. Grizzly forebay dam impounds the

Grizzly forebay, forming the Grizzly forebay reservoir that extends approximately 0.8 mile. Total storage in the 38-acre reservoir is approximately 1,112 acre-feet at the normal maximum water surface elevation of approximately 4,316 feet.

Grizzly Forebay Tunnel (Bucks Creek Development)

From Grizzly forebay, the project's water flow is conveyed through the horseshoe-shaped Grizzly forebay tunnel. The tunnel is 9,575-foot-long with two 4,786-foot-long penstocks leading to Bucks Creek powerhouse. The maximum flow capacity is 400 cfs.

Bucks Creek Powerhouse (Bucks Creek Development)

The project's water flow is conveyed through the Grizzly forebay tunnel to Bucks Creek powerhouse. The Bucks

Creek powerhouse is a 47-foot-long by 132-foot-wide, steel frame and concrete building constructed from reinforced concrete. The powerhouse has a total maximum capacity of 65 MW with an average annual generation of 234.8 GWh. The powerhouse connects directly to the non-project switchyard adjacent to the powerhouse part of the interconnected transmission system.

Bucks Creek powerhouse discharges the project's water flow in the North Fork Feather River, one mile upstream of Rock Creek powerhouse, part of PG&E's Rock Creek-Cresta Hydroelectric Project (FERC Project No. 1962).

1. Locations of the Application: A copy of the application is available for review at the Commission in the Public Reference Room or may be viewed on the Commission's Web site at <http://www.ferc.gov> using the "eLibrary" link. Enter the docket number excluding the

last three digits in the docket number field to access the document. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov, (866) 208-3676 (toll free), or (202) 502-8659 (TTY). A copy is also available for inspection and reproduction at the address in item (h) above.

m. You may also register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via email of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

n. Procedural Schedule:

The application will be processed according to the following preliminary Hydro Licensing Schedule. Revisions to the schedule may be made as appropriate.

Milestone	Target date
Notice of Acceptance/Notice of Ready for Environmental Analysis	February 2017.
Filing of recommendations, preliminary terms and conditions	April 2017.
Commission issues Draft Environmental Impact Statement (EIS)	October 2017.
Comments on Draft EIS	December 2017.
Modified Terms and Conditions	February 2018.
Commission Issues Final EIS	May 2018.

o. Final amendments to the application must be filed with the Commission no later than 30 days from the issuance date of the Notice of Ready for Environmental Analysis.

Dated: December 16, 2016.

Kimberly D. Bose,

Secretary.

[FR Doc. 2016-30851 Filed 12-21-16; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Combined Notice of Filings #2

Take notice that the Commission received the following electric rate filings:

Docket Numbers: ER16-1967-001.

Applicants: PJM Interconnection, L.L.C.

Description: Compliance filing: Compliance filing per 4/21/2016 order-Docket No. EL13-88 re: Generator Deactivat to be effective 2/14/2017.

Filed Date: 12/15/16.

Accession Number: 20161215-5249.

Comments Due: 5 p.m. ET 1/5/17.

Docket Numbers: ER16-2656-001.

Applicants: Arizona Public Service Company.

Description: Tariff Amendment: APS Response to Request for Additional Information to be effective 11/23/2016.

Filed Date: 12/16/16.

Accession Number: 20161216-5125.

Comments Due: 5 p.m. ET 1/6/17.

Docket Numbers: ER17-468-001.

Applicants: Ohio Valley Electric Corporation.

Description: Compliance filing: Errata to Amendment J, K and P to be effective 10/14/2016.

Filed Date: 12/16/16.

Accession Number: 20161216-5182.

Comments Due: 5 p.m. ET 1/6/17.

Docket Numbers: ER17-563-000.

Applicants: Arizona Public Service Company.

Description: § 205(d) Rate Filing: Administrative Filing for Collation Correction to be effective 12/16/2016.

Filed Date: 12/16/16.

Accession Number: 20161216-5082.

Comments Due: 5 p.m. ET 1/6/17.

Docket Numbers: ER17-565-000.

Applicants: PJM Interconnection, L.L.C.

Description: § 205(d) Rate Filing: Revisions to OATT Definitions and Att Q RE: Refinements to PJM's Credit Policy to be effective 2/14/2017.

Filed Date: 12/16/16.

Accession Number: 20161216-5098.

Comments Due: 5 p.m. ET 1/6/17.

Docket Numbers: ER17-566-000.

Applicants: Niagara Mohawk Power Corporation, New York Independent System Operator, Inc.

Description: § 205(d) Rate Filing: Cost Reimbursement Agreement 2324-Niagara Mohawk and Erie Boulevard Hydropower to be effective 11/18/2016.

Filed Date: 12/16/16.

Accession Number: 20161216-5114.

Comments Due: 5 p.m. ET 1/6/17.

Docket Numbers: ER17-567-000.

Applicants: Duke Energy Progress, LLC.

Description: § 205(d) Rate Filing: Southampton Solar Affected System Operating Agreement to be effective 1/19/2017.

Filed Date: 12/16/16.

Accession Number: 20161216-5145.

Comments Due: 5 p.m. ET 1/6/17.

Docket Numbers: ER17-568-000.

Applicants: Midcontinent Independent System Operator, Inc.

Description: § 205(d) Rate Filing: 2016-12-16 Attachment X-Quarterly Operating Limits to be effective 2/15/2017.

Filed Date: 12/16/16.

Accession Number: 20161216-5155.

Comments Due: 5 p.m. ET 1/6/17.

Docket Numbers: ER17-569-000.

Applicants: National Choice Energy LLC.

Description: Baseline eTariff Filing: Baseline New to be effective 12/30/2016.