

2016, and October 26, 2016, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 13, 2017.

*No significant hazards consideration comments received:* No.

*Susquehanna Nuclear, LLC, Docket No. 50-388, Susquehanna Steam Electric Station, Unit 2, Luzerne County, Pennsylvania*

*Date of amendment request:* January 28, 2016, as supplemented by letters April 6, 2016, and October 10, 2016.

*Brief description of amendment:* The amendment revised Technical Specification (TS) 3.7.1, "Residual Heat Removal Service Water (RHRSW) System and the Ultimate Heat Sink (UHS)," and TS 3.8.7, "Distribution Systems—Operating," to increase the completion time for Conditions A and B of TS 3.7.1, and Condition C of TS 3.8.7, from 72 hours to 7 days, in order to accommodate 480 volt engineered safeguard system load center transformer replacements on the Susquehanna Steam Electric Station, Unit 1. The change is temporary and will be annotated by a note in each TS that specifies the allowance expires on June 15, 2020.

*Date of issuance:* January 26, 2017.

*Effective date:* As of the date of issuance and shall be implemented within 30 days of issuance.

*Amendment No.:* 248. A publicly-available version is in ADAMS under Accession No. ML17004A250; documents related to this amendment are listed in the Safety Evaluation enclosed with the amendment.

*Facility Operating License No. NPF-22:* The amendment revised the Renewed Facility Operating License and TSs.

*Date of initial notice in Federal Register:* May 24, 2016 (81 FR 32810). The supplemental letter dated October 10, 2016, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 26, 2017.

*No significant hazards consideration comments received:* No.

*Tennessee Valley Authority, Docket Nos. 50-259, 50-260, and 50-296, Browns Ferry Nuclear Plant, Units 1, 2 and 3, Limestone County, Alabama*

*Date of amendment request:* August 12, 2016.

*Brief description of amendments:* The amendments revised Technical Specification (TS) 4.3.1.2, "Fuel Storage Criticality," for Units 1, 2, and 3, to preclude the placement of fuel in the new fuel storage vaults. This TS change removed the existing TS 4.3.1.2 criticality criteria wording in its entirety, and replaced it with language that specifically restricts the placement of fuel in the new fuel storage vaults.

*Date of issuance:* January 17, 2017.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment Nos.:* 296 (Unit 1), 320 (Unit 2), and 280 (Unit 3). A publicly-available version is in ADAMS under Accession No. ML16330A158; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

*Renewed Facility Operating License Nos. DPR-33, DPR-52, and DPR-68:* Amendments revised the Renewed Facility Operating Licenses and TSs.

*Date of initial notice in Federal Register:* October 11, 2016 (81 FR 70187).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 17, 2017.

*No significant hazards consideration comments received:* No.

*Tennessee Valley Authority, Docket Nos. 50-390 and 50-391, Watts Bar Nuclear Plant, Units 1 and 2, Rhea County, Tennessee*

*Date of amendment request:* December 8, 2015, as supplemented by letters dated March 11, October 13, December 1, and December 8, 2016.

*Brief description of amendment:* The amendment revised the Watts Bar Nuclear Plant, Units 1 and 2, Technical Specification (TS) 3.8.1, "AC Sources—Operating," to extend the Completion Time for one inoperable Diesel Generator from 72 hours to 10 days based on the availability of a supplemental alternating current power source (specifically, the FLEX DG added as part of the mitigating strategies for beyond-design-basis events in response to NRC Order EA-12-049). The amendment also made clarifying changes to certain TS 3.8.1 Conditions,

Required Actions, and Surveillance Requirements.

*Date of issuance:* January 13, 2017.

*Effective date:* As of the date of issuance and shall be implemented within 60 days of issuance.

*Amendment No.:* 110 (Unit 1) and 5 (Unit 2). A publicly-available version is in ADAMS under Accession No. ML17006A271; documents related to this amendment are listed in the Safety Evaluation enclosed with the amendment.

*Facility Operating License Nos. NPF-90 and NPF-96:* Amendments revised the Facility Operating Licenses and Technical Specifications.

*Date of initial notice in Federal Register:* May 24, 2016 (81 FR 32810). The supplemental letters dated October 13, November 1, and December 8, 2016, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 13, 2017.

*No significant hazards consideration comments received:* No.

Dated at Rockville, Maryland, this 6th day of February 2017.

For the Nuclear Regulatory Commission.

**Anne T. Boland,**

*Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.*

[FR Doc. 2017-02795 Filed 2-13-17; 8:45 am]

**BILLING CODE 7590-01-P**

## NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-025 and 52-026; NRC-2008-0252]

### Southern Nuclear Operating Company, Inc., Vogtle Electric Generating Station, Units 3 and 4; Fire Pump Head and Diesel Fuel Day Tank Changes

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Exemption and combined license amendment issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from the certification information of Tier 1 of the generic design control document (DCD) and is issuing License Amendment No. 58 to Combined Licenses (COL), NPF-91 and NPF-92. The COLs were issued to Southern Nuclear Operating

Company, Inc., and Georgia Power Company, Oglethorpe Power Corporation, MEAG Power SPVM, LLC, MEAG Power SPVJ, LLC, MEAG Power SPVP, LLC, Authority of Georgia, and the City of Dalton, Georgia (the licensee); for construction and operation of the Vogtle Electric Generating Plant (VEGP) Units 3 and 4, located in Burke County, Georgia.

The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

**DATES:** The exemption and amendment were issued on November 30, 2016.

**ADDRESSES:** Please refer to Docket ID NRC-2008-0252 when contacting the NRC about the availability of information regarding this document. You may access information related to this document, which the NRC possesses and is publicly available, using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0252. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "*Begin Web-based ADAMS Search.*" For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated August 23, 2016 (ADAMS Accession No. ML16236A265).

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

**FOR FURTHER INFORMATION CONTACT:** Paul Kallan, Office of New Reactors, U.S. Nuclear Regulatory Commission,

Washington, DC 20555-0001; telephone: 301-415-2809; email: [Paul.Kallan@nrc.gov](mailto:Paul.Kallan@nrc.gov).

## SUPPLEMENTARY INFORMATION:

### I. Introduction

The NRC is granting an exemption from paragraph B of section III, "Scope and Contents," of appendix D, "Design Certification Rule for the AP1000," to part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), and issuing License Amendment No. 58 to COLs, NPF-91 and NPF-92, to the licensee. The exemption is required by paragraph A.4 of section VIII, "Processes for Changes and Departures," appendix D, to 10 CFR part 52 to allow the licensee to depart from Tier 1 information. With the requested amendment, the licensee sought proposed changes that would revise the Updated Final Safety Analysis Report (UFSAR) in the form of departures from the incorporated plant-specific Design Control Document Tier 2 information. The proposed amendment also involves related changes to plant-specific Tier 1 information, with corresponding changes to the associated COL Appendix C information.

Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemption and issued the amendment concurrently, rather than in sequence. This included issuing a combined safety evaluation containing the NRC staff's review of both the exemption request and the license amendment. The exemption met all applicable regulatory criteria set forth in §§ 50.12, 52.7, and Section VIII.A.4 of appendix D to 10 FR part 52. The license amendment was found to be acceptable as well. The combined safety evaluation is available in ADAMS under Accession No. ML16280A378.

Identical exemption documents (except for referenced unit numbers and license numbers) were issued to the licensee for VEGP Units 3 and 4 (COLs NPF-91 and NPF-92). The exemption documents for VEGP Units 3 and 4 can be found in ADAMS under Accession Nos. ML16280A352 and ML16280A355, respectively. The exemption is reproduced (with the exception of abbreviated titles and additional citations) in Section II of this document. The amendment documents for COLs NPF-91 and NPF-92 are available in ADAMS under Accession Nos. ML16280A274 and ML16280A289, respectively. A summary of the

amendment documents is provided in Section III of this document.

### II. Exemption

Reproduced below is the exemption document issued to VEGP Units 3 and Unit 4. It makes reference to the combined safety evaluation that provides the reasoning for the findings made by the NRC (and listed under Item 1) in order to grant the exemption:

1. In a letter dated August 23, 2016, the licensee requested from the Commission an exemption from the provisions of 10 CFR part 52, appendix D, Section III.B, as part of license amendment request 16-014, "Fire Pump Head and Diesel Fuel Day Tank Changes (LAR 16-014)."

For the reasons set forth in Section 3.1, "Evaluation of Exemption," of the NRC staff's Safety Evaluation, which can be found in ADAMS under Accession No. ML16280A378, the Commission finds that:

- A. The exemption is authorized by law;

- B. the exemption presents no undue risk to public health and safety;

- C. the exemption is consistent with the common defense and security;

- D. special circumstances are present in that the application of the rule in this circumstance is not necessary to serve the underlying purpose of the rule;

- E. the special circumstances outweigh any decrease in safety that may result from the reduction in standardization caused by the exemption; and

- F. the exemption will not result in a significant decrease in the level of safety otherwise provided by the design.

2. Accordingly, the licensee is granted an exemption from the certified DCD Tier 1 information, with corresponding changes to Appendix C of the Facility Combined Licenses as described in the licensee's request dated August 23, 2016. This exemption is related to, and necessary for, the granting of License Amendment No. 58, which is being issued concurrently with this exemption.

3. As explained in Section 5.0, "Environmental Consideration," of the NRC staff's Safety Evaluation (ADAMS Accession No. ML16280A378), this exemption meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment needs to be prepared in connection with the issuance of the exemption.

4. This exemption is effective as of the date of its issuance.

### III. License Amendment Request

By letter dated August 23, 2016, the licensee requested that the NRC amend the COLs for VEGP, Units 3 and 4, COLs NPF-91 and NPF-92. The proposed amendment is described in Section I of this **Federal Register** notice.

The Commission has determined for these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

A notice of consideration of issuance of amendment to facility operating license or COL, as applicable, proposed no significant hazards consideration determination, and opportunity for a hearing in connection with these actions, was published in the **Federal Register** on September 27, 2016 (81 FR 66301). No comments were received during the 30-day comment period.

The Commission has determined that these amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments.

### IV. Conclusion

Using the reasons set forth in the combined safety evaluation, the staff granted the exemption and issued the amendment that the licensee requested on August 23, 2016.

The exemption and amendment were issued on November 30, 2016 as part of a combined package to the licensee (ADAMS Accession No. ML16279A341).

Dated at Rockville, Maryland, this 6th day of February 2017.

For the Nuclear Regulatory Commission.

**Jennifer Dixon-Herrity,**

*Chief, Licensing Branch 4, Division of New Reactor Licensing, Office of New Reactors.*

[FR Doc. 2017-02959 Filed 2-13-17; 8:45 am]

BILLING CODE 7590-01-P

### NUCLEAR REGULATORY COMMISSION

[Docket Nos. 52-025 and 52-026; NRC-2008-0252]

#### Southern Nuclear Operating Company, Inc., Vogtle Electric Generating Plant, Units 3 and 4; Relocation of Air Cooled Chiller Pump 3, VWS-MP-03

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Exemption and combined license amendment; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is granting an exemption to allow a departure from the certification information of Tier 1 of the generic design control document (DCD) and is issuing License Amendment No. 64 to Combined Licenses (COL), NPF-91 and NPF-92. The COLs were issued to Southern Nuclear Operating Company, Inc., and Georgia Power Corporation, MEAG Power SPVM, LLC, MEAG Power SPVJ, LLC, MEAG Power SPVP, LLC, Authority of Georgia, and the City of Dalton, Georgia (the licensee); for construction and operation of the Vogtle Electric Generating Plant (VEGP) Units 3 and 4, located in Burke County, Georgia.

The granting of the exemption allows the changes to Tier 1 information asked for in the amendment. Because the acceptability of the exemption was determined in part by the acceptability of the amendment, the exemption and amendment are being issued concurrently.

**DATES:** The exemption and amendment were issued on January 13, 2017.

**ADDRESSES:** Please refer to Docket ID NRC-2008-0252 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2008-0252. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: [Carol.Gallagher@nrc.gov](mailto:Carol.Gallagher@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select

"ADAMS Public Documents" and then select "*Begin Web-based ADAMS Search.*" For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The request for the amendment and exemption was submitted by letter dated April 26, 2016 (ADAMS Accession No. ML16117A531), and supplemented by letter dated August 28, 2016 (ADAMS Accession No. ML16239A422).

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

**FOR FURTHER INFORMATION CONTACT:** Chandu Patel, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-3025; email: [Chandu.Patel@nrc.gov](mailto:Chandu.Patel@nrc.gov).

### SUPPLEMENTARY INFORMATION:

#### I. Introduction

The NRC is granting an exemption from paragraph B of section III, "Scope and Contents," of appendix D, "Design Certification Rule for the AP1000," to part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), and issuing License Amendment No. 64 to COLs, NPF-91 and NPF-92, to the licensee. The exemption is required by Paragraph A.4 of Section VIII, "Processes for Changes and Departures," of appendix D, to 10 CFR part 52 to allow the licensee to depart from Tier 1 information. With the requested amendment, the licensee sought proposed changes to the Updated Final Safety Analysis Report Tier 2 and Tier 2\* information to modify the overall design of the Central Chilled Water subsystem to relocate the Air Cooled Chiller Pump 3 (VWS-MP-03) and associated equipment from the auxiliary building to the annex building, for each unit. The amendment also involves changes to plant-specific Tier 1 information, with corresponding changes to Appendix C of the COLs, to relocate the air cooled chiller pump from the auxiliary building to the annex building, for each unit.

Part of the justification for granting the exemption was provided by the review of the amendment. Because the exemption is necessary in order to issue the requested license amendment, the NRC granted the exemption and issued